

A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Clinton Water District
P.O. Box 358
Clinton, ME 04927

Date Printed: 05/13/2022
Work Order #: 2204-04166
Client Job #:
Date Received: 04/27/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. This report contains data that were produced by a subcontracted laboratory accredited for the fields of testing performed.
Alpha Analytical-Mansfield, 320 Forbes Boulevard, Mansfield, MA 02048 Accreditation # MA00030
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical, LLC: Accreditations: Massachusetts M-MA1118



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/13/2022
 CLIENT NAME: Clinton Water District

PWSID#: ME0090350

CLIENT ADDRESS: P.O. Box358
 Clinton, ME 04927

SAMPLE ID #: 2204-04166-001
 SAMPLED BY: Scott Noble

LOCATION: TP-1 EP (TP 1-2 WELLS)


MORE LOC INFO:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
11-chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid.*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
1H,1H,2H,2H-Perfluorohexanesulfonic Acid (4:2FTS).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
4,8-dioxa-3H-perfluorononanoic acid.*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid.*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
Date Extracted	-					No Limit	EPA 533	MA00030	05/10/2022 05:34PM
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
Perfluoro-3-methoxypropanoic acid (PFMPA).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
Perfluoro-4-methoxybutanoic acid (PFMBA).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	×
Attention	⚠

DATE AND TIME COLLECTED: 04/27/2022 08:00AM
 DATE AND TIME RECEIVED: 04/27/2022 09:45AM
 ANALYSIS PACKAGE: PFC-533-25-alpha-ME
 RECEIPT TEMPERATURE: ON ICE 5° CELSIUS
 CLIENT JOB #:

Rebecca L. Labranche
 Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/13/2022
CLIENT NAME: Clinton Water District

PWSID#: ME0090350

CLIENT ADDRESS: P.O. Box358
 Clinton, ME 04927

SAMPLE ID #: 2204-04166-001
SAMPLED BY: Scott Noble

LOCATION: TP-1 EP (TP 1-2 WELLS)

MORE LOC INFO:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Perfluorobutanesulfonic Acid (PFBS).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
Perfluorobutanoic Acid (PFBA).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
Perfluorodecanoic Acid (PFDA).*	<2.00	ng/L	✓		Sub Report	20 ng/L	EPA 533	MA00030	05/11/2022 03:25PM
Perfluorododecanoic Acid (PFDoA).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
Perfluoroheptanesulfonic Acid (PFHpS).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
Perfluoroheptanoic Acid (PFHpA).*	<2.00	ng/L	✓		Sub Report	20 ng/L	EPA 533	MA00030	05/11/2022 03:25PM
Perfluorohexanesulfonic Acid (PFHxS).*	<2.00	ng/L	✓		Sub Report	20 ng/L	EPA 533	MA00030	05/11/2022 03:25PM
Perfluorohexanoic Acid (PFHxA).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
Perfluorononanoic Acid (PFNA).*	<2.00	ng/L	✓		Sub Report	20 ng/L	EPA 533	MA00030	05/11/2022 03:25PM
Perfluorooctanesulfonic Acid (PFOS).*	<2.00	ng/L	✓		Sub Report	20 ng/L	EPA 533	MA00030	05/11/2022 03:25PM
Perfluorooctanoic Acid (PFOA).*	<2.00	ng/L	✓		Sub Report	20 ng/L	EPA 533	MA00030	05/11/2022 03:25PM
Perfluoropentanesulfonic Acid (PFPeS).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
Perfluoropentanoic Acid (PFPeA).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM
Perfluoroundecanoic Acid (PFUnA).*	<2.00	ng/L			Sub Report	No Limit	EPA 533	MA00030	05/11/2022 03:25PM

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	⊗
Attention	⚠

DATE AND TIME COLLECTED: 04/27/2022 08:00AM
DATE AND TIME RECEIVED: 04/27/2022 09:45AM
ANALYSIS PACKAGE: PFC-533-25-alpha-ME
RECEIPT TEMPERATURE: ON ICE 5° CELSIUS
CLIENT JOB #:

Rebecca L. Labranche
 Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/13/2022
 CLIENT NAME: Clinton Water District

PWSID#: ME0090350

CLIENT ADDRESS: P.O. Box358
 Clinton, ME 04927

SAMPLE ID #: 2204-04166-001
 SAMPLED BY: Scott Noble

LOCATION: TP-1 EP (TP 1-2 WELLS)

MORE LOC INFO:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
PFAS, Total Maine (6)	<2.00	ng/L	✓		Sub Report	20 ng/L	N/A Calculation	MA00030	05/11/2022 03:25PM

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	×
Attention	⚠

DATE AND TIME COLLECTED: 04/27/2022 08:00AM
 DATE AND TIME RECEIVED: 04/27/2022 09:45AM
 ANALYSIS PACKAGE: PFC-533-25-alpha-ME
 RECEIPT TEMPERATURE: ON ICE 5° CELSIUS
 CLIENT JOB #:

Rebecca L. Labranche
 Laboratory Director