CERTIFICATE

This is to certify that All Saint's High School, 1, Church Road, Mumbai-Pune Highway, Khadki Pune 411003. has made proper arrangement from fire point of view by keeping ABC Type Fire Extinguisher 4kg-14.Nos., ABC 2 Kg-01 No., ABC 5Kg-01 No., ABC 6Kg-03 Nos of portable fire extinguisher at different department/points in the School premises. Fire extinguisher installed in the School premises is in working condition and their due date is 16.04.2026. Fire safety report of All Saint's High School, Khadki & Completed fire safety audit on 17/07/2024 by NX Safety Fire services.

Fire suggestion & Recommendation:-

> To install fire alarm & detection system in All Saint's High School.

(S.R. PATKI)
HEALTH/GARDEN SUPERINTENDENT

No.11/4/Fire-fitting/P-) **₹**0 Office of the Cantonment Board Khadki. Pune 411 003.

Date: - 25 April 2025.

To,

All Saint's High School, 1, Church Road, Mumbai-Pune Highway, Khadki Pune 411003.

SUB:- ISSUE OF FIRE SAFETY EQUIPMENT CERTIFICATE.

Reference: - Your application dated 22/04/2025.

This certificate is issued on request made by the applicant

(S R PATKI)

HEALTH/GARDEN SUPERINTENDENT

Schatter

स्वास्थ्य / उद्यान अधीक्षक खड़की छावनी परिषद HEALTH / GARDEN SUPDT. KHADKI CANTT. BOARD

Govt. of Maharashtra Directorate of Maharashtra Fire Service

Vidyanagri, Hans Bhugra Marg, Santacruz (East), Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666 www.mahafireservice.gov.in

FORM N

[(See section 9 (3) and rule 14]
License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure

License No. MFS / LA / F-428 / D- 404

License is hereby granted under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to M/s. Nx Safety Fire Services having their registered office at Office No. 518, Bldg No. 11, Motlal Nehru Nagar, BKC, Bandra (E), Mumbai 400051 and their contact details are Office Number: 8080809689 and Email ID: nxsafetyfireservices1@gmail.com with PAN registration No. FXHPS7183D and GST No. 27FXHPS7183D1ZY to act as a Licensed Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

Fire Fighting and Sprinkler System: Class D
 Detection and Fire Suppression System: Class D

M/s. Nx Safety Fire Services shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

(ALL SAINTS' HIGH SCHOOL)

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from 17.07.2024 to 16.07.2026

Hatyal Digitally signed by Hatyal Kiran Date: 2024.07.30 20.40:18 +05'30'

Asst Director Mainuddin

Mainuddin Digitally signed by Mainuddin Mustaq Shaikh Date: 2024.07.29 19:21:59 +05'30'

Santosh Digitally signed by Santosh Warick Date: 2024.07.30 22:00:39 +05'30'

Date: 17.07.2024

(S S Warick)
Director
Maharashtra Fire Service

Digital Signature of Authorized Person to sign Form A or Form B

Note:

* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.



Help Line: 9 9323201155

8080809689

9 9322229689



NX Safety Fire Services

AN ISO 9001: 2015 Certified Company

(FIRE EXTINGUISHER DIVISION)

Pune Office: Plot No. PAP G/140, MIDC, G Block, Opp. Lotus Apartment, Behind Bharat Gas Godown, Chinchwad, Pune - 411019.

Tel.: 022 2650 0081 / 022 2650 0082 / 022 2652 0515 / 8451068125 / 9769578677

Registered Office: 518, Building No. 11, HDIL Commercial Tower, Next to Trade Centre, BKC, Bandra (E), Mumbai - 400051.

Tel.: 9766119689 / 7263888306 / 9323201155 • Web: www.nxsafetyfireservices.com e-Mail: nxsafetypune@gmail.com / info@nxsafetyfireservices.com / nxsafetyfireservices1@gmail.com

Ref No.: NXSFS / B / Jan-Jun / 78 / 24-25

FORM 'B'

Section 3 (3) and Rule 4 (2)

Six Monthly Certificates to be Given in every January and July by the Owner or the Occupier for Compliance of the Fire Prevention and Life Safety Measures.

CERTIFICATE

Certificated that We have carried out inspection of the Fire Prevention and life safety measures
Installed in the following Building or Premises namely:

M/S. ALL SAINTS' HIGH SCHOOL

1, CHURCH ROAD, PUNE - MUMBAI HIGHWAY, KHADKI, PUNE - 411003

We Further Certify That These Installations In Above Mentioned Building Are Maintained Good Repair And Efficient Condition During The Period From July 2024 To December 2024 As Required Under The Provision Of The Maharashtra Fire Prevention And Life Safety Measures Act 2006 (Mah. III Of 2007). The Details Of The Inspection Of Installation Carried By Us Are Mentioned In The Report Appended Herewith.

Mainuddin Mustaq Shaikh Digitally signed by Mainuddin Mustaq Shaikh

Date: 2025.04.17 18:01:18 +05'30'

Date : 17/04/2025 Place : Mumbai

NX SAFETY FIRE SERVICES
Office No. 518, 5th Floor, Building No. 11,
Motilal Nehru Nagar, Near Trade Center,
BKC, Bandra (E), Mumbai - 400051.
MFS / LA / F-428 / D- 404