



KARNATAKA GOVERNMENT
ZILLA PANCHAYAT, BENGALURU URBAN DISTRICT
OFFRICE OF THE TALUK HEALTH OFFICER, GENERAL HOSPITAL COMPOUND
ANEKAL. ANEKAL TALUK, BENGALURU URBAN DISTRICT
PHONE NO.: 080-29785533. Email ID: thoanekaltaluk@gmail.com

NO/THO/AKL/662/2025-26

Date: 24-03-2026

ANNEXURE C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Dr.RAVI C.R., Taluk Health Officer of Anekal Taluk Bangalore Urban District. Inspected the premises of AL-BASHEER INTERNATIONAL SCHOOL-MADRASA, SY.NO.40/4, 40/8 SAKALAVARA VILLAGE, JIGANI HOBLI, ANEKAL TALUK BANGALORE-560083, ON 23/03/2026 and found that, the institution has safe drinking water facilities for the students and members of the staff of the institution and is maintaining hygienic standards of sanitation in the school building and the campus as per the norms prescribed by the Central/State/U.T. Govt. The above valid for a period of One Year.

Dr. Ravi C.R.

Signature with Seal:

Name: Dr. RAVI C.R

Designation: Taluk Health Officer

TALUK HEALTH OFFICER

ANEKAL TALUK

BANGALORE URBAN DISTRICT

To,

AL-BASHEER INTERNATIONAL SCHOOL-MADRASA,

SY.NO.40/4, 40/8 SAKALAVARA VILLAGE,

JIGANI HOBLI, ANEKAL TALUK BANGALORE-560083

K S Hazaram Beevi


K S HAZARAM BEEVI

Principal

Al Basheer International School-Madrasa

Aff. No: 830912 School code : 45822





Test Report

Report Details:

PL/FOR/QA/018/01

ULR Number	TC158692600000886F		
Amended Report Date	Not Applicable	Original Report Date	12 March 2026
Sample Number	PL/W/25-26/04008	Sample Receipt Date	04 February 2026
Customer Details	AL Basheer International School Madrasa Sy No. 40/4, Sakalavara, Bannerghatta Road, Jigani Hobli, Anekal Taluk, Bangalore-560083		
Customer Contact Number	9538879433	Customer Mail ID	contact@albasheer.org
Analysis Start Date	05 March 2026	Analysis End Date	11 March 2026

Sampling Details:

Sample Name	RO Drinking Water	Sample Group/Matrix	Drinking Water
Sampling Location (If Any)	Not Applicable		
Sample Drawn By	Vasu	Sample Quantity Drawn	1250mL
Batch Number (If Any)	Not Applicable	Sample Package (If Any)	PP Bottle
Sampling Method	PL/SOP/QA/021	Sample Conditions	Good


Testing Environmental Conditions:

Temperature	20°C - 25°C	Humidity	45% - 75%
-------------	-------------	----------	-----------

Test Results:

Sl. No.	Test Parameters	Test Method	Test Results	IS 10500 : 2012 Drinking water specification requirement (Acceptable limit)
1	Colour	IS : 3025 (part 4)	<1	Maximum 5 Hazens
2	Odour	IS : 3025 (part 5)	Agreeable	Agreeable
3	Turbidity	IS : 3025 (part 10)	<0.5	Maximum 1 NTU
4	pH	IS : 3025 (part 11)	6.58	6.5 - 8.5
5	Total Dissolved Solids	IS : 3025 (part 16)	9.00	Maximum 500 mg/L
6	Total Hardness as CaCO ₃	IS : 3025 (part 21)	4.00	Maximum 200 mg/L
7	Calcium as Ca	IS : 3025 (part 40)	1.60	Maximum 75 mg/L
8	Magnesium as Mg	IS : 3025 (part 46)	<1	Maximum 30 mg/L
9	Chloride as Cl	IS : 3025 (part 32)	4.00	Maximum 250 mg/L
10	Total Alkalinity as CaCO ₃	IS : 3025 (part 23)	5.00	Maximum 200 mg/L
11	Sulphates as SO ₄	IS : 3025 (part 24)	<1	Maximum 200 mg/L
12	Fluoride as F	IS : 3025 (part 60)	0.1	Maximum 1 mg/L
13	Iron as Fe	IS : 3025 (part 53)	<0.075	Maximum 1 mg/L
14	Nitrate as NO ₃	APHA Method-4500	<0.2	Maximum 45 mg/L
15	Aluminium as Al	IS : 3025 (part 55)	<0.002	Maximum 0.03 mg/L

K. S. Hazaram B. Evi
Authorized Signatory
Kumar Swamy M V
Biological




K S HAZARAM B. EVI
Principal
Al Basheer International School-Madrasa
Page No.: 1 of 2
Sch No: 830912 School code : 45822

Sahana Shirali
Authorized Signatory
Sahana V Shirali
Chemistry
www.prewellabs.com

Prewel Labs Pvt. Ltd. +91-63669 42390 CIN : U85300KA2021PTC147708

#24, 22nd Main Road, Marenahalli, J.P. Nagar 2nd Phase, Bengaluru - 560 078 support@prewellabs.com





Test Report

Report Details:

PL/FOR/QA/018/01

ULR Number	TC158692600000886F		
Amended Report Date	Not Applicable	Original Report Date	12 March 2026
Sample Number	PL/W/25-26/04008	Sample Receipt Date	04 February 2026
Customer Details	AL Basheer International School Madrasa Sy No. 40/4, Sakalavara, Bannerghatta Road, Jigani Hobli, Anekal Taluk, Bangalore-560083		
Customer Contact Number	9538879433	Customer Mail ID	contact@albasheer.org
Analysis Start Date	05 March 2026	Analysis End Date	11 March 2026

Sampling Details:

Sample Name	RO Drinking Water	Sample Group/Matrix	Drinking Water
Sampling Location (If Any)	Not Applicable		
Sample Drawn By	Vasu	Sample Quantity Drawn	1250mL
Batch Number (If Any)	Not Applicable	Sample Package (If Any)	PP Bottle
Sampling Method	PL/SOP/QA/021	Sample Conditions	Good

Testing Environmental Conditions:

Temperature	20°C - 25°C	Humidity	45% - 75%
-------------	-------------	----------	-----------

Test Results:


Sl. No.	Test Parameters	Test Method	Test Results	IS 10500 : 2012 Drinking water specification requirement (Acceptable limit)
16	Total Coliform Bacteria	IS : 15185	Absent	Shall not be detectable in 100 mL sample
17	<i>Escherichia coli</i>	IS : 15185	Absent	Shall not be detectable in 100 mL sample


Statement of Conformity: The given sample conforms to IS 10500:2012 Drinking water specification (Acceptable limit) for the above tested parameters.


Amendment Details (If Any): Not Applicable

Note:

1. The reported findings are specific to the tested sample and relevant parameters.
2. In the event of a dispute, our liability is capped at the total invoiced amount received by us.
3. Upon request, samples will be stored for 15 days. Perishable samples will be promptly discarded immediately after analysis.
4. This report may not be reproduced in part without the laboratory's approval and is not admissible as evidence in legal proceedings.
5. The copyright for the Test Report, its information, and data (excluding customer-provided information) belongs to Prewel Labs Pvt. Ltd. and must not be replicated in any form.
6. Any proprietary knowledge developed by Prewel Labs Pvt. Ltd. during the assigned work remains the sole property of Prewel Labs Pvt. Ltd. The customer/client may not use or disclose this information without express written permission.
7. Any discrepancies in the Test Report must be reported to Prewel Labs Pvt. Ltd. within 30 days of a report being released.


Authorized Signatory
Kumar Swamy M V
Biological






K S HAZARAM BEEVI
Principal

Al Basheer International School-Madrasa
Aff. No: 830912 School code: 4002




Authorized Signatory
Sahana V Shirali
Chemistry
www.prewellabs.com

Page No.: 2 of 2


Prewel Labs Pvt. Ltd.

+91-63669 42390

CIN : U85300KA2021PTC147708

#24, 22nd Main Road, Marenahalli, J.P. Nagar 2nd Phase, Bengaluru - 560 078 support@prewellabs.com





Test Report

Report Details:

PL/FOR/QA/018/01

ULR Number	Not Applicable		
Amended Report Date	Not Applicable	Original Report Date	12 March 2026
Sample Number	PL/W/25-26/04008	Sample Receipt Date	04 February 2026
Customer Details	AL Basheer International School Madrasa Sy No. 40/4, Sakalavara, Bannerghatta Road, Jigani Hobli, Anekal Taluk, Bangalore-560083		
Customer Contact Number	9538879433	Customer Mail ID	contact@albasheer.org
Analysis Start Date	05 March 2026	Analysis End Date	11 March 2026

Sampling Details:

Sample Name	RO Drinking Water	Sample Group/Matrix	Drinking Water
Sampling Location (If Any)	Not Applicable		
Sample Drawn By	Vasu	Sample Quantity Drawn	1250mL
Batch Number (If Any)	Not Applicable	Sample Package (If Any)	PP Bottle
Sampling Method	PL/SOP/QA/021	Sample Conditions	Good

Testing Environmental Conditions:

Temperature	20°C - 25°C	Humidity	45% - 75%
-------------	-------------	----------	-----------

Test Results:


Sl. No.	Test Parameters	Test Method	Test Results	IS 10500 : 2012 Drinking water specification requirement (Acceptable limit)
1	Zinc as Zn	IS : 3025 (part 49)	<0.1	Maximum 5 mg/L
2	Boron as B	IS : 3025 (part 57)	<0.1	Maximum 0.5 mg/L

Statement of Conformity: The given sample conforms to IS 10500:2012 Drinking water specification (Acceptable limit) for the above tested parameters.

Note:


1. The reported findings are specific to the tested sample and relevant parameters.
2. In the event of a dispute, our liability is capped at the total invoiced amount received by us.
3. Upon request, samples will be stored for 15 days. Perishable samples will be promptly discarded immediately after analysis.
4. This report may not be reproduced in part without the laboratory's approval and is not admissible as evidence in legal proceedings.
5. The copyright for the Test Report, its information, and data (excluding customer-provided information) belongs to Prewel Labs Pvt. Ltd. and must not be replicated in any form.
6. Any proprietary knowledge developed by Prewel Labs Pvt. Ltd. during the assigned work remains the sole property of Prewel Labs Pvt. Ltd. The customer/client may not use or disclose this information without express written permission.
7. Any discrepancies in the Test Report must be reported to Prewel Labs Pvt. Ltd. within 30 days of a report being released.

End of the Report



K S Hazaram Beevi
K S HAZARAM BEEVI
Principal

Al Basheer International School-Madrasa
Aff. No: 830912 School code : 45822
Page No.: 1 of 1



Prewel Labs Pvt. Ltd.

+91-63669 42390



CIN : U85300KA2021PTC147708

www.prewellabs.com

#24, 22nd Main Road, Marenahalli, J.P. Nagar 2nd Phase, Bengaluru - 560 078



support@prewellabs.com

