



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner information is required for every page.

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

Inspection results must be submitted on this form. Inspection forms may not be altered in any way. Please see completeness checklist at the end of the form.

Important: When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



A. Inspector Information

Richard Judd

(rick.moraneng@gmail.com)

Name of Inspector

Moran Engineering Associates, LLC

Company Name

P. O. BOX 183 (941 Main Street)

Company Address

South Harwich

MA

02661

City/Town

State

Zip Code

508-432-2878

SI9584

Telephone Number

License Number

B. Certification

I certify that: I am a DEP approved system inspector in full compliance with Section 15.340 of Title 5 (310 CMR 15.000); I have personally inspected the sewage disposal system at the property address listed above; the information reported below is true, accurate and complete as of the time of my inspection; and the inspection was performed based on my training and experience in the proper function and maintenance of on-site sewage disposal systems. After conducting this inspection I have determined that the system:

- ☒ Passes
- ☐ Conditionally Passes
- ☐ Needs Further Evaluation by the Local Approving Authority
- ☐ Fails

Inspector's Signature

August 28, 2023

Date

The system inspector shall submit a copy of this inspection report to the Approving Authority (Board of Health or DEP) within 30 days of completing this inspection. If the system has a design flow of 10,000 gpd or greater, the inspector and the system owner shall submit the report to the appropriate regional office of the DEP. The original form should be sent to the system owner and copies sent to the buyer, if applicable, and the approving authority.

Please note: This report only describes conditions at the time of inspection and under the conditions of use at that time. This inspection does not address how the system will perform in the future under the same or different conditions of use.



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

C. Inspection Summary

Inspection Summary: Complete 1, 2, 3, or 5 and all of 4 and 6.

1) System Passes:

- ☒ I have not found any information which indicates that any of the failure criteria described in 310 CMR 15.303 or in 310 CMR 15.304 exist. Any failure criteria not evaluated are indicated below.

Comments:

2) System Conditionally Passes:

- ☐ One or more system components as described in the "Conditional Pass" section need to be replaced or repaired. The system, upon completion of the replacement or repair, as approved by the Board of Health, will pass.

Check the box for "yes", "no" or "not determined" (Y, N, ND) for the following statements. If "not determined," please explain.

The septic tank is metal and over 20 years old* **or** the septic tank (whether metal or not) is structurally unsound, exhibits substantial infiltration or exfiltration or tank failure is imminent. System will pass inspection if the existing tank is replaced with a complying septic tank as approved by the Board of Health.

* A metal septic tank will pass inspection if it is structurally sound, not leaking and if a Certificate of Compliance indicating that the tank is less than 20 years old is available.

☐ Y ☐ N ☐ ND (Explain below):



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

C. Inspection Summary (cont.)

2) System Conditionally Passes (cont.):

☐ Pump Chamber pumps/alarms not operational. System will pass with Board of Health approval if pumps/alarms are repaired.

☐ Observation of sewage backup or break out or high static water level in the distribution box due to broken or obstructed pipe(s) or due to a broken, settled or uneven distribution box. System will pass inspection if (with approval of Board of Health):

☐ broken pipe(s) are replaced ☐ Y ☐ N ☐ ND (Explain below):

☐ obstruction is removed ☐ Y ☐ N ☐ ND (Explain below):

☐ distribution box is leveled or replaced ☐ Y ☐ N ☐ ND (Explain below):

☐ The system required pumping more than 4 times a year due to broken or obstructed pipe(s). The system will pass inspection if (with approval of the Board of Health):

☐ broken pipe(s) are replaced ☐ Y ☐ N ☐ ND (Explain below):

☐ obstruction is removed ☐ Y ☐ N ☐ ND (Explain below):

3) Further Evaluation is Required by the Board of Health:

☐ Conditions exist which require further evaluation by the Board of Health in order to determine if the system is failing to protect public health, safety or the environment.

a. System will pass unless Board of Health determines in accordance with 310 CMR 15.303(1)(b) that the system is not functioning in a manner which will protect public health, safety and the environment:



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

Owner
information is
required for every
page.

C. Inspection Summary (cont.)

- ☐ Cesspool or privy is within 50 feet of a surface water
- ☐ Cesspool or privy is within 50 feet of a bordering vegetated wetland or a salt marsh

b. System will fail unless the Board of Health (and Public Water Supplier, if any) determines that the system is functioning in a manner that protects the public health, safety and environment:

- ☐ The system has a septic tank and soil absorption system (SAS) and the SAS is within 100 feet of a surface water supply or tributary to a surface water supply.
- ☐ The system has a septic tank and SAS and the SAS is within a Zone 1 of a public water supply.
- ☐ The system has a septic tank and SAS and the SAS is within 50 feet of a private water supply well.
- ☐ The system has a septic tank and SAS and the SAS is less than 100 feet but 50 feet or more from a private water supply well**.

Method used to determine distance: _____

** This system passes if the well water analysis, performed at a DEP certified laboratory, for fecal coliform bacteria indicates absent and the presence of ammonia nitrogen and nitrate nitrogen is equal to or less than 5 ppm, provided that no other failure criteria are triggered. A copy of the analysis must be attached to this form.

c. Other:

4) System Failure Criteria Applicable to All Systems:

You must indicate "Yes" or "No" to each of the following for all inspections:

Yes No

☐☒

Backup of sewage into facility or system component due to overloaded or clogged SAS or cesspool

☐☒

Discharge or ponding of effluent to the surface of the ground or surface waters due to an overloaded or clogged SAS or cesspool



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

C. Inspection Summary (cont.)

4) System Failure Criteria Applicable to All Systems: (cont.)

Yes	No	
☐	☒	Static liquid level in the distribution box above outlet invert due to an overloaded or clogged SAS or cesspool
☐	☒	Liquid depth in cesspool is less than 6" below invert or available volume is less than ½ day flow
☐	☒	Required pumping more than 4 times in the last year NOT due to clogged or obstructed pipe(s). Number of times pumped: _____.
☐	☒	Any portion of the SAS, cesspool or privy is below high ground water elevation.
☐	☒	Any portion of cesspool or privy is within 100 feet of a surface water supply or tributary to a surface water supply.
☐	☒	Any portion of a cesspool or privy is within a Zone 1 of a public water supply well.
☐	☒	Any portion of a cesspool or privy is within 50 feet of a private water supply well.
☐	☒	Any portion of a cesspool or privy is less than 100 feet but greater than 50 feet from a private water supply well with no acceptable water quality analysis. [This system passes if the well water analysis, performed at a DEP certified laboratory, for fecal coliform bacteria indicates absent and the presence of ammonia nitrogen and nitrate nitrogen is equal to or less than 5 ppm, provided that no other failure criteria are triggered. A copy of the analysis and chain of custody must be attached to this form.]
☐	☒	The system is a cesspool serving a facility with a design flow of 2000 gpd-10,000 gpd.
☐	☒	The system fails. I have determined that one or more of the above failure criteria exist as described in 310 CMR 15.303, therefore the system fails. The system owner should contact the Board of Health to determine what will be necessary to correct the failure.

5) Large Systems: To be considered a large system the system must serve a facility with a design flow of 10,000 gpd to 15,000 gpd.

For large systems, you must indicate either "yes" or "no" to each of the following, in addition to the questions in Section C.4.

Yes	No	
☐	☐	the system is within 400 feet of a surface drinking water supply
☐	☐	the system is within 200 feet of a tributary to a surface drinking water supply
☐	☐	the system is located in a nitrogen sensitive area (Interim Wellhead Protection Area – IWPA) or a mapped Zone II of a public water supply well



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

Owner
information is
required for every
page.

C. Inspection Summary (cont.)

If you have answered "yes" to any question in Section C.5 the system is considered a significant threat, or answered "yes" to any question in Section C.4 above the large system has failed. The owner or operator of any large system considered a significant threat under Section C.5 or failed under Section C.4 shall upgrade the system in accordance with 310 CMR 15.304. The system owner should contact the appropriate regional office of the Department.

6. You must indicate "yes" or "no" for each of the following for *all* inspections:

Yes No

- | | | |
|-------------------------------------|-------------------------------------|--|
| ☒ | ☐ | Pumping information was provided by the owner, occupant, or Board of Health |
| ☐ | ☒ | Were any of the system components pumped out in the previous two weeks? |
| ☒ | ☐ | Has the system received normal flows in the previous two week period? |
| ☐ | ☒ | Have large volumes of water been introduced to the system recently or as part of this inspection? |
| ☒ | ☐ | Were as built plans of the system obtained and examined? (If they were not available note as N/A) |
| ☒ | ☐ | Was the facility or dwelling inspected for signs of sewage back up? |
| ☒ | ☐ | Was the site inspected for signs of break out? |
| ☒ | ☐ | Were all system components, excluding the SAS, located on site? |
| ☒ | ☐ | Were the septic tank manholes uncovered, opened, and the interior of the tank inspected for the condition of the baffles or tees, material of construction, dimensions, depth of liquid, depth of sludge and depth of scum? |
| ☐ | ☒ | Was the facility owner (and occupants if different from owner) provided with information on the proper maintenance of subsurface sewage disposal systems? The size and location of the Soil Absorption System (SAS) on the site has been determined based on: |
| ☒ | ☐ | Existing information. For example, a plan at the Board of Health. |
| ☐ | ☒ | Determined in the field (if any of the failure criteria related to Part C is at issue approximation of distance is unacceptable) [310 CMR 15.302(5)] |



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

D. System Information

1. Residential Flow Conditions:

Number of bedrooms (design): 16 Number of bedrooms (actual): 16

DESIGN flow based on 310 CMR 15.203 (for example: 110 gpd x # of bedrooms): 1760

Description:

Number of current residents: 10

Does residence have a garbage grinder? ☐ Yes ☒ No

Does residence have a water treatment unit? ☐ Yes ☒ No

If yes, discharges to: _____

Is laundry on a separate sewage system? (Include laundry system inspection information in this report.) ☐ Yes ☒ No

Laundry system inspected? ☐ Yes ☐ No

Seasonal use? ☐ Yes ☒ No

Water meter readings, if available (last 2 years usage (gpd)): 2021 = 504
2022 = 458

Detail:

9-Units. Water use records include lawn irrigation consumption.

Sump pump? ☐ Yes ☒ No

Last date of occupancy: Current
Date



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

D. System Information (cont.)

2. Commercial/Industrial Flow Conditions:

Type of Establishment: _____

Design flow (based on 310 CMR 15.203): _____

Gallons per day (gpd) _____

Basis of design flow (seats/persons/sq.ft., etc.): _____

Grease trap present?

☐ Yes ☐ No

Water treatment unit present?

☐ Yes ☐ No

If yes, discharges to: _____

Industrial waste holding tank present?

☐ Yes ☐ No

Non-sanitary waste discharged to the Title 5 system?

☐ Yes ☐ No

Water meter readings, if available: _____

Last date of occupancy/use: _____

Date

Other (describe below):

3. Pumping Records:

Source of information: _____

systems pumped annually per manager

Was system pumped as part of the inspection?

☐ Yes ☒ No

If yes, volume pumped: _____

gallons

How was quantity pumped determined? _____

Reason for pumping: _____



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

D. System Information (cont.)

4. Type of System:

- ☒ Septic tank, distribution box, soil absorption system
- ☐ Single cesspool
- ☐ Overflow cesspool
- ☐ Privy
- ☐ Shared system (yes or no) (if yes, attach previous inspection records, if any)
- ☐ Innovative/Alternative technology. Attach a copy of the current operation and maintenance contract (to be obtained from system owner) and a copy of latest inspection of the I/A system by system operator under contract
- ☐ Tight tank. Attach a copy of the DEP approval.
- ☐ Other (describe):

Approximate age of all components, date installed (if known) and source of information:

System installed 1971 +/- per Health Department records.

Were sewage odors detected when arriving at the site?

☐ Yes ☒ No

5. Building Sewer (locate on site plan):

Depth below grade:

1.8'
feet

Material of construction:

☒ cast iron ☐ 40 PVC ☐ other (explain):

Distance from private water supply well or suction line:

NA. Building on Town Water
feet

Comments (on condition of joints, venting, evidence of leakage, etc.):

There were no observed signs of backup or leakage within the basement at the time of the field inspection.



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

D. System Information (cont.)

6. Septic Tank (locate on site plan):

Depth below grade:

Top: 1.8', In & Out: at grade
feet

Material of construction:

☒ concrete

☐ metal

☐ fiberglass

☐ polyethylene

☐ other (explain)

3000-gallon.

If tank is metal, list age:

years

Is age confirmed by a Certificate of Compliance? (attach a copy of certificate)

☐ Yes ☐ No

Dimensions:

11' x 6' x 7.8' flow line

Sludge depth:

24"

Distance from top of sludge to bottom of outlet tee or baffle

N/A - canister filter bottom not
determined.

Scum thickness

<1"

Distance from top of scum to top of outlet tee or baffle

6"

Distance from bottom of scum to bottom of outlet tee or baffle

N/A - canister filter bottom not
determined.

How were dimensions determined?

Sludge Judge and measuring tape

Comments (on pumping recommendations, inlet and outlet tee or baffle condition, structural integrity, liquid levels as related to outlet invert, evidence of leakage, etc.):

The tank contains metal rings and covers, at grade, above inlet and outlet access ports. There is a cast iron inlet line and tee at the sidewall and a PVC inlet line and tee at the headwall. Both inlet line pipe inverts are above the operating level. A Zabel canister filter is at the outlet and was cleaned on the day of the inspection. The inlet side of the tank contained 7" of measured scum. There were no observed signs of backup or leakage within or above the septic tank at the time of the field inspection. Maintenance pumping is scheduled per management.



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

Owner
information is
required for every
page.

D. System Information (cont.)

7. Grease Trap (locate on site plan):

Depth below grade:

feet

Material of construction:

☐ concrete

☐ metal

☐ fiberglass

☐ polyethylene

☐ other (explain):

Dimensions:

Scum thickness

Distance from top of scum to top of outlet tee or baffle

Distance from bottom of scum to bottom of outlet tee or baffle

Date of last pumping:

Date

Comments (on pumping recommendations, inlet and outlet tee or baffle condition, structural integrity, liquid levels as related to outlet invert, evidence of leakage, etc.):

8. Tight or Holding Tank (tank must be pumped at time of inspection) (locate on site plan):

Depth below grade:

Material of construction:

☐ concrete

☐ metal

☐ fiberglass

☐ polyethylene

☐ other (explain):

Dimensions:

Capacity:

gallons

Design Flow:

gallons per day



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

Owner
information is
required for every
page.

D. System Information (cont.)

8. Tight or Holding Tank (cont.)

Alarm present:

☐ Yes ☐ No

Alarm level: _____

Alarm in working order: ☐ Yes ☐ No

Date of last pumping:

_____ Date

Comments (condition of alarm and float switches, etc.):

* Attach copy of current pumping contract (required). Is copy attached?

☐ Yes ☐ No


9. Distribution Box (if present must be opened) (locate on site plan):

Depth of liquid level above outlet invert

0"

Comments (note if box is level and distribution to outlets equal, any evidence of solids carryover, any evidence of leakage into or out of box, etc.):

The distribution box is a DB-5 with one inlet line and two outlet lines. The outlet lines are fitted with leveling weirs and the liquid level was at their inverts. The box has a 16" diameter cover at grade in the paved parking area. There were no observed signs of solid carryover, backup, or leakage at the time of the field inspection.



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address:34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

10. **Pump Chamber** (locate on site plan):

Pumps in working order:

☐ Yes ☐ No*

Alarms in working order:

☐ Yes ☐ No*

Comments (note condition of pump chamber, condition of pumps and appurtenances, etc.):

* If pumps or alarms are not in working order, system is a conditional pass.

11. **Soil Absorption System (SAS)** (locate on site plan, excavation not required):

If SAS not located, explain why:

Type:

☒ leaching pits number: 2

☐ leaching chambers number: _____

☐ leaching galleries number: _____

☐ leaching trenches number, length: _____

☐ leaching fields number, dimensions: _____

☐ overflow cesspool number: _____

☐ innovative/alternative system

Type/name of technology: _____



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

D. System Information (cont.)

11. Soil Absorption System (SAS) (cont.)

Comments (note condition of soil, signs of hydraulic failure, level of ponding, damp soil, condition of vegetation, etc.):

SAS:

West Leach Pit: 24" steel cover at grade. Liquid: 1.3'. Staining indicators at 4.2' +/- above floor.

South Leach Pit: 24" steel cover at grade. Liquid: 3.5'. Staining indicators at 5' +/- above floor.

There were no observed signs of backup, breakout or hydraulic failure within or above the leaching areas at the time of the field inspection.

12. Cesspools (cesspool must be pumped as part of inspection) (locate on site plan):

Number and configuration

Depth – top of liquid to inlet invert

Depth of solids layer

Depth of scum layer

Dimensions of cesspool

Materials of construction

Indication of groundwater inflow

☐ Yes ☐ No

Comments (note condition of soil, signs of hydraulic failure, level of ponding, condition of vegetation, etc.):



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

Owner
information is
required for every
page.

D. System Information (cont.)

13. **Privy** (locate on site plan):

Materials of construction:

Dimensions

Depth of solids

Comments (note condition of soil, signs of hydraulic failure, level of ponding, condition of vegetation, etc.):



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

Owner
information is
required for every
page.

D. System Information (cont.)

14. Sketch Of Sewage Disposal System:

Provide a view of the sewage disposal system, including ties to at least two permanent reference landmarks or benchmarks. Locate all wells within 100 feet. Locate where public water supply enters the building. Check one of the boxes below:

- ☐ hand-sketch in the area below
☒ drawing attached separately

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address:34 Pelton Street

Owner's Name

MA
State

02132

9/28/23

~~September 15, 2020~~

West Roxbury

City/Town

Zip Code


Date of Inspection

D. System Information (cont.)

14. Sketch Of Sewage Disposal System:

Provide a view of the sewage disposal system, including ties to at least two permanent reference landmarks or benchmarks. Locate all wells within 100 feet. Locate where public water supply enters the building. Check one of the boxes below:

- ☒ hand-sketch in the area below
☐ drawing attached separately





Owner
information is
required for every
page.

Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

D. System Information (cont.)

15. Site Exam:

☒ Check Slope

☒ Surface water

☒ Check cellar

☐ Shallow wells

Estimated depth to high ground water:

> 4' below SAS
feet

Please indicate all methods used to determine the high ground water elevation:

☐ Obtained from system design plans on record

If checked, date of design plan reviewed:

Date

☐ Observed site (abutting property/observation hole within 150 feet of SAS)

☐ Checked with local Board of Health - explain:

☐ Checked with local excavators, installers - (attach documentation)

☒ Accessed USGS database - explain:

Brewster & Harwich Ground Water Elevation Map & USGS Quad.

You **must** describe how you established the high ground water elevation:

Approximate surface elevation at SAS:

El. 25

Ground Water Contour Elevation:

El. 6

Estimated Depth to Ground Water:

19'

Depth of SAS:

-13'

SAS floor to ground water elevation:

6'

Before filing this Inspection Report, please see Report Completeness Checklist on next page.



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

15 Pleasant Street Anchorage Condominiums - WEST BUILDING

Assessors Map 14 & Parcel F-4

Property Address

William Brinkert

Mailing Address: 34 Pelton Street

Owner's Name

West Roxbury

MA

02132

August 28, 2023

City/Town

State

Zip Code

Date of Inspection

E. Report Completeness Checklist

Complete all applicable sections of this form inclusive of:

☒ A. Inspector Information: Complete all fields in this section.

☒ B. Certification: Signed & Dated and 1, 2, 3, or 4 checked

☒ C. Inspection Summary:

1, 2, 3, or 5 completed as appropriate

4 (Failure Criteria) and 6 (Checklist) completed

☒ D. System Information:

For 8: Tight/Holding Tank – Pumping contract attached

For 14: Sketch of Sewage Disposal System drawn on pg. 16 or attached

For 15: Explanation of estimated depth to high groundwater included

TOWN OF HARWICH
ADDENDUM TO DEP SEPTIC INSPECTION REPORT

Inspection Location: 15 Pleasant St, West Building Map & Parcel: 14-F4


1. Residential Property

Bedrooms <i>(incl. den, sewing room, office)</i>	<u>16</u>
Family Rooms	<u> </u>
Living Rooms	<u>8</u>
Bathrooms	<u>16</u>
Dining Rooms	<u>8</u>
Kitchens	<u>8</u>
Other: _____	<u> </u>
Total:	<u>40</u>

Commercial Property

Employees	<u> </u>
Toilets	<u> </u>
Rooms with Bath	<u> </u>
Square Feet	<u> </u>

2. Floor Plan: Show all floors including basement: plan is attached.



I certify that I have verified the floorplan as current and correct: confirmed with condo association

Signature: *Paul J. Judd* date: August 28, 2023

3. Is the septic system, as inspected, in full compliance with either Yes X No
The 1978 (X) or 1995 () Title 5 code?
If not, list deficiencies .

4. Is the system in the Zone II (Water Resource Protection Yes No X
District)? Lot size:

TOWN OF HARWICH
ADDENDUM TO DEP SEPTIC INSPECTION REPORT

Inspection Location: 15 Pleasant St, West Building

Map & Parcel: 14-F4


5. Is there a 4' separation (1978 code) or a 5' separation (1995 code) Yes ____ No ____
between the bottom of the S.A.S. and adjusted groundwater?

Indicate how groundwater was verified:

USGS Maps X
& Groundwater
Contour Map

Engineers letter on file ____
(post 1995 installation)

Hand auger ____*
*perform in area of SAS and
verify elevation of the bottom
of the SAS




6. Town Water (X) or Private Well (____).
Distance from nearest septic system component: >10'
7. Wetlands or surface water within 100' of septic system? Yes ____ No X
Distance from nearest septic system component: _____
8. Type of pipe used in system
PVC X Orangeburg ____ Other _____
9. Sanitary tees or baffles in place (Yes – No – N/A?)
 Septic tank inlet YES
 Septic tank outlet YES-WITH EFFLUENT FILTER
 Pump chamber inlet _____
 D-box inlet if pumped system _____
 Grease trap inlet _____
 Grease trap outlet _____
 Risers – 1978 code within 12 inches of grade on septic tank: CAST IRON
COVERS AT GRADE.
 Risers – 1995 code within 6 inches of grade on all components _____
 One inspection port on S.A.S. (1995 code) _____

North

Plan Book 252 Page 76

Vest Bldg


96-252



RECEIVED
JAN 19 1972
RECORDS

EXHIBIT
- D -

CEILING ELEVATION 36'10 1/2" (4'11" Blower Surf of Ceiling Unit)
FLOOR ELEVATION 27'7 1/2" (8') ABV MSL (upper surf of sub-51)



FIRST FLOOR PLAN.
PHOTO REDUCTION 50%
I, BENJAMIN V. VICKERS, a duly
registered architect certify that
these plans fully and accurately
represent the design, location, and
dimensions of the
units as built.

BENJAMIN V. VICKERS
Architect

NO.	DESCRIPTION	DATE	BY
1	REVISION		
2	REVISION		
3	REVISION		
4	REVISION		
5	REVISION		
6	REVISION		
7	REVISION		
8	REVISION		
9	REVISION		
10	REVISION		

① **NOTED BY THE ARCHITECT**
CONFORMANCE WITH MASSACHUSETTS
REQUIREMENTS TO RECORD THE ABOVE
PLAN PERMANENTLY AND TO BE
RECORDED IN THE PUBLIC RECORDS
AND TO BE OPEN TO THE PUBLIC
FOR INSPECTION AT ALL TIMES.
BENJAMIN V. VICKERS
Architect



RECORD OF DEEDS
JAN 19 1972
1045
RECORD

252-87

First Floor

Wm + Dids




PHOTO REDUCTION 20%

I, BURNETT & VICKERS, a duly registered Architect, certify that these plans fully and accurately depict the layout, location, unit numbers and dimensions of the units as built.

Donna H. Vickers
BOBMY V. VICKERS

Архитектура Сериате



COMMONWEALTH OF MASSACHUSETTS

Then personally located the

above named Burnell V. Vickers and acknowledged the foregoing statements to be true, before me

Notary Public
McCOMMISSIONED AND CERTIFIED

Pauline

DRAWING OF ALANBUR AETH
 LOCATION DU ARCHEBISHOP "MIST"
POHMANBURG STREET
 6.18 JULY 20 PICT. 07.2. EIGHT
 2.26 ETT V. NO. 713 ABSTRACT
 ORLAND CAR CO. RAIL
 A14 461135 K. 14.4

B

RECORD OF DEEDS

JAN 19 1972


10415a
REC'D

φ
 ψ
 χ
 ι
 ∞
 ∞

2nd Floor

6/23 + 13/09

Plan Book 252 Page 86



FOUNDATION - BASEMENT - PLAN -
 PHOTO REDUCTION 50%

I, BURNETT VICKERS, a duly
 registered architect, certify that
 these plans fully and accurately
 depict the layout, location, unit
 numbers and dimensions of the
 units on this floor.

Burnett Vickers

ARCHITECT'S CERTIFICATE

CONFORMANCE WITH MASSACHUSETTS
 REGULATION OF DEEDS
 These plans were prepared by me
 or under my direct supervision and
 I am a duly registered architect
 in the State of Massachusetts.
 My commission expires Jan. 18, 1974

James Henry Poirer



DRAWN BY A. LEONARD
 LOCATION THE ARCHITECT'S OFFICE
 FOR BURNETT VICKERS, ARCHITECT
 DATE 11/15/72
 BURNETT V. VICKERS - ARCHITECT
 OFFICE 100 STATE ST. 02109 MASS.

RECORD OF DEEDS
 JAN 19 1972
 10 H 45 A
 REC.

Basement

West Bldg

252-86




West Bldg
Detail

Condominium Apartments

15 PLEASANT STREET
HARWICH PORT, MASS 02046
TEL. 617/432-0800
617/432-0163

2 BEDROOMS, 1 1/2 BATHS

1,000 sq. ft.



Apartment Nos.

S-1, 21

W-1, 21

Opposite Hand

S-4, 24

W-4, 24

APPROXIMATE DIMENSIONS SUBJECT TO CONSTRUCTION REVISIONS

