

Courtney Hammond- Operations Director
Administrative report
May 5, 2026

- Monroe Plumbing repaired a staff restroom where both the flange and connecting pipe had deteriorated due to rust. This was a little challenging due to the pipe being encased in the wall. The restroom is now fully operational.
- Monroe Plumbing also addressed multiple leaks at the concession stands caused by corroded underground main water lines and repaired a urinal affected by rusted plumbing components.
- Monroe Plumbing responded to a significant pipe burst in the high school tunnel. In addition, they performed a camera inspection of the crock drain and completed a cleaning to prevent further backups into the building.
- The high school and middle school boilers were taken offline for the season on April 13, 2026.
- Continued support of spring athletic programs, including field lining and installation of new screening on the baseball warning track.
- Lutz Roofing was on-site to repair several roof leaks at the high school.
- Planning for summer maintenance projects is underway. Current items being evaluated and quoted include:
 - Trees that are safety concerns or cause structural or electrical concerns
 - Asphalt repairs along the roadway between the middle school and high school, including the bus drive and bus lot