

Annual Water Quality Report Certification Form

Water System Name: Village of Ravenna

Public Water Supply ID #: NY 0100201

The community water system named above hereby confirms that its Annual Water Quality Report (AWQR) has been distributed to customers and appropriate notices of availability have been given. Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the health department.

Certified by: Name: Jason Leonard
Title: Chief waterplant operator
Phone #: 518-756-2024 Date: 5-14-25

Please indicate how your report was distributed to your customers:

- ☐ AWQR was distributed to bill-paying customers by mail.
- ☐ AWQR was distributed by other direct delivery method(s) (check all that apply)
 - ☐ Hand delivered.
 - ☐ Published in local paper (i.e., *Penny Saver*) that was directly delivered or mailed to all bill-paying customers.
 - ☐ Published in local municipal newsletter that was directly delivered or mailed.
 - ☐ Mailed a notification that AWQR is available on a public website via a direct URL
 - ☐ Emailed with a message containing a direct URL link to the AWQR
 - ☐ Emailed with AWQR sent as an attachment to the email
 - ☐ Emailed with AWQR sent as an embedded image in the email
 - ☒ Additional electronic delivery that meets "otherwise directly deliver" requirement
 - ☒ Other (please specify) Facebook page and village website www.villageofravenna.com
- ☐ System does not have bill-paying customers.
- ☐ For systems serving at least 100,000 persons: in addition to direct delivery to bill-paying customer the AWQR was posted on a publicly-accessible website at www.villageofravenna.com

Please indicate what "Good Faith" efforts were used to reach non-bill paying consumers (check all that apply).

- ☒ Posting the Annual Water Quality Report on the Internet at www.villageofravenna.com
- ☐ Mailing the Annual Water Quality Report to postal patrons within the service area
- ☐ Advertising the availability of the Annual Water Quality Report in the news media
- ☐ Publication of the Annual Water Quality Report in a local newspaper
- ☐ Posting the Annual Water Quality Report in public places (attach a list of locations)
- ☐ Delivery of multiple copies to single-bill addresses serving several persons such as: apartments, businesses, and large private employers
- ☐ Delivery to community organizations
- ☐ Other (please specify) _____

Annual Drinking Water Quality Report for 2024

Village of Ravena

15 Mountain Road, Ravena, NY 12143
(Public Water Supply Identification Number NY0100201)

INTRODUCTION

To comply with State regulations, the Village of Ravena, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your drinking water met all State drinking water health standards. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to New York State standards. Our constant goal is and always has been, to provide to you a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and to protect our water resources. If you have any questions concerning this report or concerning your drinking water please contact: *Mr. Jason T. Leonard, Chief Plant Operator, Village of Ravena Water Department, 42 Skyview Drive, Ravena, NY 12143; Telephone (518) 756-2024.* We want our valued customers to be informed about their water service. If you want to learn more, please attend any of our regularly scheduled Village Board meetings. They are held on the 1st and 3rd Tuesday of each month, 7:00 PM at the *Village Hall, 15 Mountain Road, Ravena, NY 12143; Telephone (518) 756-8233.*

WHERE DOES OUR WATER COME FROM?

The Village of Ravena draws its water from a "surface water" supply. Our 15-million-gallon raw water storage reservoir is fed by the Hanacroix Creek. Our supply is supplemented by water from the Alcove Reservoir. Raw water flows into the Ravena Water Treatment Plant (RWTP), a complete treatment facility. The treatment process at the RWTP consists of: chlorination to protect against contamination from harmful bacteria and other organisms; coagulation using poly aluminum chloride (PC 180) to cause small particles to stick together when the water is mixed; making larger heavier particles; sedimentation to allow the newly formed larger particles to settle out naturally; filtration to remove smaller particles by trapping them in sand filters; post chlorination to prevent bacterial contamination and fluoridation at low levels to protect teeth. Additionally, we add Sweetwater CP-7670 for corrosion control. Finished water is pumped from the Clearwell into the Low Service and High Service Tanks and then into the distribution system. These tanks have a combined capacity of 1.797 million gallons to meet consumer demand and to provide adequate fire protection.

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and EPA prescribe regulations, which limit the amount of certain contaminants in water, provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

FACTS AND FIGURES

The Village provides water through 1,200 service connections to a population of approximately 4,500 people. The total water pumped in 2024 was 219,500,000 gallons. Approximately 95 % of the total was billed directly to customers. The balance, or unaccounted for water was used for fire fighting purposes, distribution system leaks and unauthorized use. Our average daily demand is 579,000 gallons. Our single highest day was 972,000 gallons. Residents pay a flat rate for water. All commercial services are metered. The charge for water in 2024 was \$112.50 for unlimited usage billed Bi-annually, March & September for accounts in the Village of Ravena. The rate was \$168.75 for unlimited usage billed twice a year for customers in the Coeymans Water District and \$225.00 for unlimited usage billed twice a year for customers in the New Baltimore Water District.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

In accordance with State regulations, the Village of Ravena routinely monitors your drinking water for numerous contaminants. We test your drinking water for inorganic contaminants, radiological contaminants, lead and copper, nitrate, volatile organic contaminants, and synthetic organic contaminants. In addition, we test 5 samples for coliform bacteria each month. The table presented below depicts which contaminants were detected in your drinking water. The state allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one-year old and. For a listing of the parameters we analyzed that were not detected along with the frequency of testing for compliance with the NYS Sanitary Code, see Appendix A

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Albany County Health Department at (518) 447-4620.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table on page 4, our system had one violation. We did not meet the minimum TOC compliance ratio of 1 in the monitoring period January- March 2024. Our measured compliance ratio was 0.44. We received a Notice of Violation (NOV) dated 12/27/23. It was November 2023 that we did achieve the required Total Organic Carbon (TOC) removals. We returned to compliance in December 2023 with some adjustment to our coagulant feed to achieve better TOC removals. As a result of the NOV we are required to furnish the following health effects information:

TOC

Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

Additionally we had an MCL violation for odor and are required to provide the following health effects information:

Odor

Odor as measured by this standard procedure has no health effects; although several contaminants exert odors when they are present at levels near their MCLs. Odor is an important quality factor affecting the drinkability of water.

We have learned through our monitoring and testing that some contaminants have been detected; For the violations We have corrected those problems and the duration of the problem was in the short term.

New York State has adopted the first in the nation drinking water standard for 1,4-Dioxane along with one of the lowest maximum contaminant levels for PFOA and PFOS. Public Water Supplies in NYS are required to test for PFOA, PFOS and 1,4-Dioxane. PFOA and PFOS have Maximum Contaminant Levels (MCL) of 10 parts per trillion each while 1,4-Dioxane has an MCL of 1.0 parts per billion. The Village of Ravena Water Department has completed its 4th quarter 2024 monitoring with no detects for PFOA, PFOS & 1,4-Dioxane.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2024, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbiological pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

INFORMATION ON LEAD SERVICE LINE INVENTORY

The Lead and Copper Rule Revisions (LCRR) requires every federally defined community and non-transient, non-community water system to develop a service line inventory (also called a lead service line inventory (LSLI)).

A Lead Service Line (LSL) is defined as any portion of pipe that is made of lead which connects the water main to the building inlet. An LSL may be owned by the water system, owned by the property owner, or both. The inventory includes both potable and non-potable SLs within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR) our system has prepared a lead service line inventory and have made it publicly accessible.

The Village of Ravena distribution system has lead service lines, galvanized requiring replacement, or lead status unknown service lines. The inventory is viewable at the following website:

https://www.health.ny.gov/environmental/water/drinking/service_line/NY0100201.htm

INFORMATION ON LEAD

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is *primarily from materials and parts used in service lines and in home plumbing*. The Village of Ravena is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact *Mr. Jason T. Leonard., Chief Plant Operator (518) 756-2024*. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

INFORMATION ON FLUORIDE ADDITION

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at an optimal range from 0.8 to 1.2 mg/l (parts per million). To ensure that the fluoride supplement in your water provides optimal dental protection, the State Department of Health requires that we monitor fluoride levels on a daily basis. During 2024 monitoring showed fluoride levels in your water were in the optimal range 95% of the time. None of the monitoring results showed fluoride at levels that approach the 2.2 mg/l MCL for fluoride.

WHAT IS THE SOURCE WATER ASSESSMENT PROGRAM (SWAP)?

To emphasize the protection of surface and ground water sources used for public drinking water, Congress amended the Safe Drinking Water Act (SDWA) in 1996. The amendments require that New York State Department of Health's Bureau of Public Water Supply Protection is responsible for ensuring that source water assessments are completed for all of New York's public water systems.

A source water assessment provides information on the potential contaminant threats to public drinking water sources:

- ◆ each source water assessment will: determine where water used for public drinking water comes from (delineate the source areas)
- ◆ Inventory potential sources of contamination that may impact public drinking water sources
- ◆ Assess the likelihood of a source water area becoming potential contaminated

A SWAP summary for our water supply is attached to this report.

WATER CONSERVATION TIPS

The Village of Ravena encourages water conservation. There are a lot of things you can do to conserve water in your own home. Conservation tips include:

- ◆ Only run the dishwasher and clothes washer when there is a full load
- ◆ Use water saving showerheads

- ◆ Install faucet aerators in the kitchen and the bathroom to reduce the flow from 4 to 2.5 gallons per minute
- ◆ Water gardens and lawn for only a couple of hours after sunset
- ◆ Check faucets, pipes and toilets for leaks and repair all leaks promptly
- ◆ Take shorter showers

CAPITAL IMPROVEMENTS

There were no major modifications to the water plant or distribution system in 2024

CLOSING

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit our customers. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

VILLAGE OF RAVENA TABLE OF DETECTED CONTAMINANTS Public Water Supply Identification Number NY0100201							
Contaminant	Violation Yes/No	Date of Sample	Level Detected	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely source of Contamination
Microbiological Contaminants							
Turbidity ¹ (Highest turbidity sample)	N	12/12/24	0.06 ¹	NTU		TT=1.0 NTU	Soil runoff
			100%			TT= 95% of samples <0.3 NTU	
Inorganic Contaminants							
Barium	N	3/18/24	11.1	µg/l	2000	MCL=2000	Erosion of natural deposits
Chloride	N	3/18/24	30.1	mg/l	N/A	MCL=250	Erosion of natural deposits
Chromium	N	3/18/24	1.9	µg/l	100	MCL=100	Erosion of natural deposits
Copper Range of copper concentration	N	8/20/24-8/21-24	0.0672 ² 0.0012-0.00693	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems
Fluoride	N	3/18/24	0.228	mg/l	N/A	MCL=2.2	Water additive that promotes strong teeth;
Lead Range of lead concentration	N	8/20/24-8/21-24	1 ³ ND-5.5	µg/l	N/A	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nickel	N	3/18/24	0.5	µg/l	N/A	N/A	Erosion of natural deposits
Nitrate	N	3/18/24	0.140	mg/l	10	MCL=10	Erosion of natural deposits
Odor	Y	3/18/24	8.0	units	N/A	MCL=3	Natural sources
pH	N	3/18/24	7.47	units	N/A	NA	6.5-8.5
Sodium ⁴	N	3/18/24	18.1	mg/l	N/A	N/A ³	Naturally occurring; Road salt; Water softeners; Animal waste
Zinc	N	3/18/24	41.5	µg/l	N/A	MCL=5000	Geology
Total Organic Carbon ⁶							
Raw Water Treated Water	Y	Jan-Dec 2024	2.05-17.5 1.8-6.2	mg/l	N/A	TT	Organic material both natural and manmade; Organic pollutants, decaying vegetation.
Disinfection Byproducts (Quarterly samples)							
Haloacetic Acids (HAA5) ⁵ Average Range of values for HAA5 (High School)	N	3/18/24 6/11/24 9/10/24	52.65 31.1-70.3	µg/l	N/A	MCL=60	By-product of drinking water chlorination
Total Trihalomethanes (TTHM) Average) ⁵ Range of values for TTHM (High School)	N	12/18/24	75.35 41.6-102	µg/l	N/A	MCL=80	By-product of drinking water chlorination
Chlorine Residual (average) range	N	Daily	1.42 1.28-1.53	mg/l	N/A	MCL=4	Water additive used to control microbes

FOOTNOTES-

1. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. Level detected represents the highest level detected. We also monitor turbidity in the distribution system 5 days a week with 0.19 NTU being the average turbidity; 0.01 NTU being the lowest turbidity and 0.42 NTU being the highest distribution turbidity.
2. The level presented represents the 90th percentile of the 20 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 20 samples were collected at your water system and the 90th percentile value was the sample with the third highest value (level detected 0.0672 mg/l). The action level for copper was not exceeded at any of the sites tested.
3. The level presented represents the 90th percentile of 20 test sites. The action level for lead was not exceeded at any of the 20 sites tested.
4. Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.
5. The average is based on a Locational Running Annual Average. The average shown represents the highest LRAA for the HAA5's and the THM's. The highest LRAA for the THM's was in the 1st quarter of 2024 and HAA5 was in the 3rd quarter of 2024.
6. The Interim Enhanced Surface Water Treatment Rule (IESWTR) requires monitoring of raw and finished water Total Organic Carbon (TOC). Depending on the raw water alkalinity value, proper water treatment should remove between 15% to 35% of the raw water TOC. Our 1st qtr. finished water compliance ratio was only 1.5 and 6% for February and March resulting in a Notice of Violation for the first quarter of 2024.

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (µg/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

90th Percentile Value - The values reported for lead and copper represent the 90th percentile. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead and copper values detected at your water system.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Locational Running Annual Average (LRAA): The LRAA is calculated by taking the average of the four most recent samples collected at each individual site.

N/A - not applicable

Hannacroix Creek PWSID NY0100201 Source Water Assessment Summary

The NYS DOH has completed a Source Water Assessment for the Hannacroix Creek. The assessment is summarized below. The assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how likely contaminants could enter the creek. The susceptibility rating is an estimate of the potential for contamination. It does not mean that the water delivered to your home is or will become unsafe to drink. See section "Are there contaminants in our drinking water?" of this report, for information concerning low levels of contaminants in your water.

The assessment found the amount of pasture in the assessment area results in a potential for protozoa contamination. There is also possible contamination susceptibility associated with facilities such as landfills and a golf course. It should be noted that relatively high flow velocities make large stream drinking water supplies highly sensitive to existing and new sources of microbial contamination.

Ravena's water treatment plant performs multi level treatment to insure you receive safe drinking water. Additionally, as this annual report shows your water is routinely monitored for a great number of potential contaminants.

A copy of the full Source Water Assessments, including a map of the assessment area, is available for review by contacting us at the number provided in this report.

Appendix A
New York State Sanitary Code Compliance Monitoring Requirements- Compounds Analyzed that were Below Limits of Detection

New York State Sanitary Code Compliance Monitoring Requirements- Compounds Analyzed that were Below Limits of Detection					
VILLAGE OF RAVENA TEST RESULTS					
Public Water Supply Identification Number NY0100201					
CONTAMINANT		MONITORING FREQUENCY	CONTAMINANT	CONTAMINANT	MONITORING FREQUENCY
Asbestos		Every 9 years Sample from 12/22/20	POC's (Volatile Organic Compounds)		
			Benzene	Trans-1,3-Dichloropropene	Monitoring requirement is one sample annually. Sample from 3/18/24 Non-Detect
			Chloromethane	Chloroethane	
			Bromobenzene	Ethylbenzene	
Antimony	Monitoring requirement is 1 sample annually Sample from 3/18/24		Bromochloromethane	Hexachlorobutadiene	
Arsenic			Bromomethane	Isopropylbenzene	
			N-Butylbenzene	p-Isopropyltoluene	
			sec-Butylbenzene	Methylene Chloride	
Beryllium			Tert-Butylbenzene	n-Propylbenzene	
Cadmium			Carbon Tetrachloride	Styrene	
Chromium		Non-Detect	Chlorobenzene	1,1,1,2-Tetrachloroethane	
Cyanide		2-Chlorotoluene	1,1,2,2-Tetrachloroethane		
Mercury		4-Chlorotoluene	Tetrachloroethene		
Selenium		Dibromethane	Toluene		
Silver		1,2-Dichlorobenzene	1,2,3-Trichlorobenzene		
Thallium		1,3-Dichlorobenzene	1,2,4-Trichlorobenzene		
Beryllium		1,4-Dichlorobenzene	1,1,1-Trichloroethane		
Cadmium		Dichlorodifluoromethane	1,1,2-Trichloroethane		
		1,1-Dichloroethane	Trichloroethene		
		1,2-Dichloroethane	Trichlorofluoromethane		
Manganese	Monitoring requirement is at State discretion Sample from 3/18/24		1,1 Dichloroethene	1,2,3-Trichloropropane	
Iron			cis-1,2 Dichloroethene	1,2,4-Trimethylbenzene	
Color			Trans-1,2-Dichloroethene	1,3,5-Trimethylbenzene	
			1,2 Dichloropropane	m-Xylene	
			1,3 Dichloropropane	o- Xylene	
			2,2 Dichloropropane	p-Xylene	
		Non-Detect	1,1 Dichloropropene	Vinyl Chloride	
		Cis-1,3-Dichloropropene	MTBE		
			E. coli	Total coliform	Monitoring is 5 samples/ month Non-Detect