

## Addendum Two (AD2)

PROJECT TITLE: Repair Maintenance Shop, Bldg 8040  
PROJECT NUMBER: FNWZ 12-0053

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents.
---

SERIES 100 – STATEMENT OF WORK (No items this addendum.)

SERIES 200 – ATTACHMENTS (No items this addendum.)

SERIES 300 – DRAWINGS

- Item 301 AD2 Sheet A103, keynote 06 41 00.A1; change to “Solid wood cabinets with solid surface counter top with integrated backsplash & sink.”
- Item 302 AD2 Sheet A402, A500, A501, Delete General Finish Note #1.

SERIES 400 – SPECIFICATIONS

- Item 401 AD2 Appendix B – Environmental Remediation: Clarification, all items not specifically identified as Salvaged in the contract documents shall become the property of the contractor. All items inside the facility shall be remediated per this Appendix B. The contractor is responsible for all permits, testing, remediation, storage, transportation, & disposal costs of all debris.
- Item 402 AD2 Appendix B – Environmental Remediation: 3.0 Remedial Objectives; section 3.1 Clarification: The level of “cleanliness” required in the renovated facility is all surfaces should be at or below the level of detection for each contaminant (see below) following remediation. Please note, this is for surface contamination and not airborne concentrations.

Limit of Detection (Wipe/Swipe method)

Cadmium	0.1 ug/100cm <sup>2</sup>
Chromium VI	0.03 ug/100cm <sup>2</sup>
Lead	0.1 ug /100cm <sup>2</sup>

- Item 403 AD2 Appendix B – Environmental Remediation: 3.0 Remedial Objectives; delete entire section “3.2.”
- Item 404 AD2 Appendix B – 4.0 Remedial Action Plan, Clarification: Dyess is non-industrial. The material is either hazardous or not; there is no classification for it. The contractors must have 24 hour HAZWHOPER to work in the contamination area.
- Item 405 AD2 Appendix B – 4.0 Remedial Action Plan, Paragraph 5: Change “*Power wash both sides of exterior walls and roof.*” To “*Power wash interior face of exterior walls and roof.*”

\*\*\* END OF ADDENDUM \*\*\*

Please sign below and turn in with your proposal as page 3 after the cover page to acknowledge that you have been informed of this addendum.

---

Signature

Date