

Richmond State Supported Living Center

2100 Preston Street

Richmond, TX 77469

The required services to be provided are for the removal of one (1) existing insulated pad mount switch, and installing a new insulated pad mount switch preferably the **15.5 kV, 110kV BIL SF6 Insulated Padmount Switch, Catalog No. SPRAM66-376F-40PI** on the Richmond State Supported Living Center (RSSLC) campus. Installation shall include all switchgear accessories and parts required to complete a fully operational and turnkey system. New system shall be “Like for Like” and meet or exceed all current governmental codes and existing electrical distribution system requirements.