



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	8140-2380:0001
CATEGORY:	8140 - EXTERIOR WALL SIDING AND SHEATHING FOR WILDLAND URBAN INTERFACE (W.U.I)
LISTEE:	Canyon Lumber Company 205-346 Lawrence Avenue, , CA, Contact: ALaloge, Kenneth (250) 763-3400 Email: klaloge@canyonlumber.com
DESIGN:	Canyon Lumber Company nominal 1" X 6" X 19/32" thick Western Red Cedar Tongue & Groove Siding Panels. Wall assembly consists of 2 in. x 4 in. SPF lumber spaced 16 in. on center, 1/2 in. exterior grade OSB sheathing, Typar building wrap. 4' to 7' lengths and 8' to 16' lengths laminated onto a western red finger jointed, edge glued cedar core. Refer to the manufacturer's installation instructions and product data sheets.
RATING:	Tested to SFM 12-7A-1 and SFM 12-7A-3
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee name, Model number, rating and SFM label.
APPROVAL:	Listed as exterior siding for use in the Wildland Urban Interface areas.
NOTES:	

12-15-2023 DC



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 01/22/2024

Listing Expires: 06/30/2024

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division