


**Certification of Compliance with Parking Lot Illumination  
Standards in Chapter 8C of the Code of Miami-Dade County**

Date: 04-01-24

Property Address: 2600 Collins Ave. Miami Beach, FL 33134  
Folio No.: 02-3226-033-0001  
Building Description: Apartments  
Bldg.: 5story-cbs

The undersigned states the following:

1. I am a Florida registered professional engineer or architect with an active license.
2. On 04-01-24, 20 24, I measured the level of illumination in the parking lot(s) serving the above referenced building.
3. Maximum 3.7 foot candle per SF,  
Minimum 1.1 foot candle per SF,  
Maximum to Minimum ratio 1 : 3.36, foot candle 1.9 average per SF.
4. The level of illumination provided in the parking lot ☒ meets ☐ does not meet the minimum standards for the occupancy classification of the building as established in Section §8C-3 of the Code of Miami-Dade County.

  
Signature and Seal of  
Professional Engineer or Architect

Rafael L. Gonzalez, P.E. 11057  
Print Name