

Groundhog Dam Intake Structure Modification Bid Addendum #2

Date: July 1st, 2021

AG Job No.: 19-106

Bidders,

The following document is provided for revision to the bid documents and to address questions that have been submitted to date.

Bid Documents can be access from this link:

<https://applegategroup.sharefile.com/d-s3ef68b5b902343eb87b526ee71110872>

General Notes and Revisions

1. Due date to receive Bids is extended to **Tuesday July 13th, 2021 by 1PM local time.** MVIC board members intend to meet that night to review the bids.

Questions from Contractors

1. Will the micropile contractor be responsible for running the Verification and Proof testing while Trautner will only observe the tests? Will the micropile contractor be responsible for providing the reaction beam, test ram, dial gauges, and pump to perform Verification and Proof testing?
 - a. Trautner Geotech will supply all the necessary equipment and perform the Verification and Proof testing of production and non-productions micropiles.