

ELECTRICAL REQUIREMENTS

FOR SANITARY GRINDER PUMP STATION

**The property owner shall provide electrical power to the
Grinder Station.**

30 AMP 2 Pole Breaker

240 Volt Circuit

New 240 Volt UF Cable,

Buried 24" minimum

Wire size to be #10-3 w/ ground

2 Hot leads

1 True Neutral

1 Ground wire