



WE MAKE ENERGY HAPPEN

NYSE: WMB | williams.com

Williams' Digital Transformation

Gas and Electric Partnership Conference / Feb 6, 2020 / Mike Teter / Houston Tx



VIRGINIA SOUTHSIDE II CONSTRUCTION




KENSINGTON GAS PROCESSING PLANT




SUMAS COMPRESSOR STATION

Williams' Assets



Williams' Journey of Digital Transformation



Reliability Programs

- > **Downtime tracking**
 - Utilization, Reliability, Availability
 - Reporting, Power BI, Custom Application for event Coding

- > **Equipment Dashboards**
 - Access to Equipment visualization and trending Graphics, Reports, Custom Trends

- > **Data Mining**
 - Deviation from defined Normal operations Reports and Analysis

- > **Turbine Specific Analysis**
 - T5 Spread, T5 Vector, Performance Calculations

- > **Equipment Comparisons**
 - Like equipment under like operations, Looking for statistical anomalies

- > **Custom Notifications**
 - for deviations from define limits

- > **Integration with Maintenance Management**
 - Operating Run Hours and Automatic work request generation

Downtime

Downtime Overview

Equipment type: Compressor
 4/1/2019 to 6/30/2019

7/12/2019 1:49:09 AM

Utilization
63.95 %



Total Number of Events

Availability
92.97 %



Reliability
96.53 %





Uncoded
3.14 %



Total Downtime (Hrs) by Downtime Cause

✕ 🔍 📧 ⋮



Dashboards



Turbine Dashboard

Last Refreshed at: 2/3/2020 7:40:03 AM

- Click on any unit, and links to additional views will be available on the right side of the screen
- Units that are highlighted are not currently running
- Report data refreshes every five minutes

Unit	Equipment Number	Model	Run Status	Starts (30 Days)	Utilization % (30 Days)
Discovery-Larose: Unit 01	CAX320	Mars100	ON	2	45.1
Discovery-Larose: Unit 02	CAX220A	Mars100	ON	1	94
Discovery-Larose: Unit 03	CAX220B	Mars100	OFF	1	54.7
Gulf East-Mobile Bay: Unit 01	CG3201	Mars100	ON	3	97.6
Gulf East-Mobile Bay: Unit 02	CG3301	Mars100	OFF	1	2.2
Gulf East-Mobile Bay: Unit 03	CG3401	Mars100	ON	3	99.4
Gulf West-Markham: C1100	C1100	Saturn10	OFF	2	1.7
Gulf West-Markham: C1200	C1200	Saturn10	OFF	13	38.5
Gulf West-Markham: C140	C140	Mars100	ON	0	99.9
Gulf West-Markham: C240	C240	Taurus70	OFF	0	0
LMM-Shamrock: Mars	GT2011	Mars100	ON	8	70.3
NWP-Albany: Unit 01	Unit 01	Saturn10	OFF	21	80.6
NWP-Boise: Unit 01	Unit 01	Taurus60	ON	4	92.5
NWP-Boise: Unit 02	Unit 02	Taurus60	OFF	1	1.1
NWP-Buhl: Unit 01	Unit 01	Centaur50	OFF	4	3.8
NWP-Buhl: Unit 02	Unit 02	Centaur40	OFF	1	3.6
NWP-Burley: Unit 01	Unit 01	Taurus60	OFF	1	22.6
NWP-Burley: Unit 02	Unit 02	Taurus70	ON	3	56.1
NWP-Chehalis: Unit 02	Unit 02	Taurus70	OFF	5	7.4
NWP-Cisco: Unit 01	Unit 01	Centaur50	OFF	0	0
NWP-Cisco: Unit 02	Unit 02	Centaur50	OFF	0	0
NWP-Eugene: Unit 01	Unit 01	Saturn10	OFF	6	2.1
NWP-Columbia: Unit 01	Unit 01	Centaur50	OFF	0	0

- [LMM-Shamrock: Mars](#)
- [Ad Hoc / Vision](#)
- [Alarm Shutdown](#)
- [Compressor Map](#)
- [Compressor Trends](#)
- [Fleet Comparison](#)
- [Fuel PCD Flow Trends](#)
- [Ignition Report](#)
- [Operations Overview](#)
- [Performance Overview](#)
- [T5 Profile](#)
- [T5 Radar Plot Comparison](#)
- [T5 Spread \(Fleet Exceptions\)](#)
- [T5 Spread Trend](#)
- [Turbine Trends](#)

Recip Dashboard

Last Refreshed at:

- Click on any unit, and links to additional views will be available on the right side of the screen
- Units that are highlighted are not currently running
- Report data refreshes every five minutes

Unit	Model	Run Status	Starts (30 Days)	Utilization % (30 Days)	
ABA-Central: Elec North	EM ICD-CHCNW	2			ABA-Church: Recip 03
ABA-Central: Elec South	EM ICD-CHCNW	2			Catalyst Trend
ABA-Central: Recip 01	Caterpillar G3612LE	0			Compressor Temp Dev Trend
ABA-Central: Recip 02	Caterpillar G3612LE	1	6	49	Compressor Temp Trend
ABA-Central: Recip 03	Caterpillar G3612LE	0	8	15	Ignition Voltage Trend
ABA-Central: Turb 02	Solar Taurus60	2			Efficiency Parameter Trend
ABA-Church: Recip 01	Caterpillar G3516B ULB	1	7	97	Engine Operation Trend
ABA-Church: Recip 02	Caterpillar G3516B ULB	1	1	100	Exhaust Temp Trend
ABA-Church: Recip 03	Caterpillar G3516B ULB	1	7	98	Overview Display
ABA-Church: Recip 04	Caterpillar G3516B ULB	1	2	99	
ABA-Church: Recip 05	Caterpillar G3608LE	1	0	100	
ABA-Church: Recip 06	Caterpillar G3608LE	1	2	99	
ABA-Church: Recip 07	Caterpillar G3612LE	1	0	100	
ABA-Church: Recip 08	Caterpillar G3612LE	1	1	100	
ABA-Dunbar: Recip 01	Caterpillar G3606LE	0	5	37	


Data Mining

Baseline Maintenance Report

Franchise:
 Start Date: 8/7/2019 12:00:00 AM
 End Date: 8/15/2019 12:00:00 AM
 Last Refreshed at: 2/3/2020 7:11:47 AM

Excursions / Status:

Process Value	Status Tracker	Low Excursions (Hours)	High Excursions (Hours)	Low Threshold	Min Value During Excursions	High Threshold	Max Value During Excursions	Number of Events	Last Excursion Time (Click to view in BLM DM) Orange indicates still in of report
Comp Vib Cyl 1		0	80	0.001	.5	0.5	1.6	22	
Stg 2 Comp Cyl Discharge Temp Spread		0	34	-0.001	13.2	13	24.3	4	
Stg 2 Cyl 4 Discharge Temp		0	2	100	241.0	240	241.5	1	
Stg 2 Cyl 6 Discharge Temp		0	17	100	240.0	240	252.0	3	



Comparison Reports

Caterpillar G3600 Driver Comparison

Start Time: * Interval: 1h Report Execution Time: 2/3/2020 7:23:06 AM
 0 - 1000 RPM and Selected Load Range: 90 - 100%

Aggregates all the available data records that meet the RPM and Load Criteria for the time period and interval selected and displays 1 Average record for each unit
 Legend: Data values below 1.25* StdDev and Red backfill represent values greater than 1.25* StdDev
 * Left Column (Franchise/Station/Unit) will link to the Overview display if active
 Underlined and shown in Blue Links to Coesight for data trending

Reporting	Model	RPM	Load	JW Outlet Temp	JW to Oil Temp	Engine Oil Pres	Engine Oil Temp	Engine Oil Filter Dp	Comp Oil Pres	Comp Oil Temp	Fuel Flow	Fuel Flow Offski	Fuel Temp	Fuel Cor Fct	Fuel LHV Quality	Air Man Pres	Air Man Temp	Air to Fuel Ratio	Burn Time Sp	Burn Time Avg	Burn Time Dev	Timing	Exhaust Temp Avg	Catalyst Inlet Temp	Catalyst Out Temp	Catalyst Dp	Turbo Inlet Temp	Turbo Out Temp	Turbo RB Inlet Temp	Turbo RB Out Temp	Ign Volt Avg	Ign Volt Dev	Battery V
	G3616LE	955	97	178	-	80.9	177.0	6.94	60.6	149.3	32.6	31.9	55	100.0	908	32.9	130.2	19.06	4.31	4.3	0.4	16.3	989	820	837	0.0	1.093	851	1.059	996	76.3	5.0	23
	G3616LE	985	91	181	-	81.3	177.0	4.97	58.4	153.6	29.7	29.9	49	100.0	967	30.9	129.5	20.14	4.20	4.2	0.1	16.3	975	873	886	0.0	1.073	828	1.068	979	68.5	4.3	25
	G3616LE	997	93	180	-	80.2	176.0	4.78	73.8	158.9	31.1	29.0	40	100.0	958	31.9	129.3	20.20	4.16	4.2	0.7	16.5	975	872	856	2.6	1.068	843	1.064	964	78.0	5.1	24
	G3616LE	997	92	180	-	80.1	176.2	7.77	60.1	163.9	31.6	26.8	38	99.7	931	32.1	129.1	19.89	4.26	4.3	0.6	18.4	995	871	882	2.6	1.082	845	1.072	981	74.2	7.3	24
	G3616LE	998	100	181	-	75.1	172.0	4.92	64.7	168.4	34.7	34.7	73	100.0	918	34.8	129.8	19.46	4.20	4.1	0.8	16.5	985	762	770	2.6	1.067	817	1.055	920	65.3	3.7	23
	G3616LE	999	91	181	7.0	82.1	174.3	7.99	68.9	166.1	30.5	36.9	37	100.2	955	31.5	132.7	20.06	4.15	4.1	0.5	16.4	973	872	875	1.3	1.061	837	1.058	954	73.1	3.9	24
Deviation		17	4	1.2		2.50	1.9	1.51	5.96	7.47	1.77	3.79	14	0.2	24	1.38	1.3	0.45	0.06	0.1	0.3	0.8	9	46	44	0.6	12	7	27	4.8	1	0	
Average		968	93.9	180.2	7.0	79.9	175.4	6.23	64.4	160.0	31.7	31.5	49	100.0	940	32.34	130.1	19.80	4.21	4.2	0.5	16.7	982	845	851	2.3	1.074	837	1.063	966	72.6	4.91	24

Caterpillar G3500 Driver Comparison

Start Time: * Interval: 1h Report Execution Time: 2/3/2020 7:25:59 AM
 Selected Speed Range: 1350 - 1400 RPM and Selected Load Range: 90 - 100% StdDev Threshold: 1.25

Aggregates all the available data records that meet the RPM and Load Criteria for the time period and interval selected and displays 1 Average record for each unit
 Legend: Data values below 1.25* StdDev and Red backfill represent values greater than 1.25* StdDev
 * Left Column (Franchise/Station/Unit) will link to the Overview display if active
 Underlined and shown in Blue Links to Coesight for data trending

Model	RPM	Load	JW Outlet Temp	JW to Oil Temp	Engine Oil Pres	Engine Oil Temp	Engine Oil Filter Dp	Comp Oil Pres	Comp Oil Temp	Fuel Flow	Fuel Flow Offski	Fuel Temp	Fuel Cor Fct	Fuel LHV Quality	Throttle Pos	Air Man Pres	Air Man Temp	Air to Fuel Ratio	Exhaust Inlet Temp	Exhaust Out Temp	Exhaust Temp Avg	Catalyst Inlet Temp	Catalyst Out Temp	Catalyst Dp	Turbo Inlet Temp	Turbo Out Temp	Turbo RB Inlet Temp	Turbo RB Out Temp	Ign Volt Avg	Ign Volt Dev	Battery Volt	Values In Avg			
G3516B ULB	1,352	91.0	188	-1.7	99.3	191.0	11.07	60.67	168.2	10.2	10.29	84	99.0	907	52.7	44.98	124.6	28.19	55.1	55.0	28.2	1.155	20.7	904	888	0.0	1.267	928	1.288	959	47.8	5.6	23.0		
G3516B ULB	1,353	91.6	188	-2.0	98.5	189.7	11.20	61.12	167.3	10.4	10.56	89	99.0	900	53.1	45.19	124.4	28.08	54.9	55.0	28.3	1.172	19.6	887	903	0.0	1.274	936	1.308	951	46.4	4.3	23.0		
G3516B ULB	1,353	93.4	190	-0.6	99.8	190.3	11.05	58.34	167.6	10.4	10.50	81	100.8	913	54.2	44.09	125.6	28.04	57.4	55.0	28.5	1.183	17.0	973	957	0.0	1.320	994	1.319	1,004	39.9	3.2	22.6		
G3516B ULB	1,354	91.1	190	-2.6	97.6	192.3	10.70	60.20	166.3	10.2	10.16	49	100.0	910	53.1	43.12	117.4	28.06	52.1	52.0	28.3	1.138	18.2	901	919	0.0	1.289	938	1.288	971	39.7	4.2	23.0		
G3516B ULB	1,354	91.7	185	-4.4	88.2	189.7	11.35	60.76	167.6	10.4	10.58	87	101.8	900	52.2	44.67	119.0	27.28	57.0	53.0	28.4	1.161	18.5	1,005	999	0.0	1.294	989	1.303	1,015	33.7	5.1	23.5		
G3516B ULB	1,354	95.2	188	-1.3	88.4	190.4	10.91	59.18	166.7	10.7	10.52	86	99.0	908	55.5	46.10	119.6	28.48	52.0	52.0	28.7	1.119	18.0	894	912	0.0	1.244	920	1.261	928	45.1	4.0	23.0		
G3516B ULB	1,355	93.1	188	-2.8	99.0	189.0	10.74	59.93	169.2	10.7	10.62	81	100.1	885	53.4	46.20	121.0	27.31	49.9	50.0	28.5	1.135	25.2	900	909	0.0	1.277	947	1.266	928	46.8	4.4	23.0		
G3516B ULB	1,370	92.8	191	-0.1	97.2	191.0	9.90	58.88	160.7	10.5	10.29	89	101.5	912	54.0	44.12	125.8	27.74	57.1	55.0	28.9	1.147	12.6	968	988	0.0	1.274	958	1.287	970	20.7	5.3	24.7		
G3516B ULB	1,378	99.0	193	-0.4	94.8	193.0	10.65	60.26	167.8	11.5	11.50	48	101.9	887	57.2	45.12	134.7	27.14	53.3	53.8	29.4	1.204	20.7	925	935	0.0	1.321	917	1.321	960	41.8	5.1	27.4		
G3516B ULB	1,377	98.8	188	-2.5	88.7	191.6	11.26	60.10	153.9	11.3	11.35	73	100.0	888	57.3	47.25	135.3	27.93	49.4	45.0	29.4	1.184	24.8	946	940	0.0	1.311	954	1.311	973	33.5	3.6	27.5		
G3516B ULB	1,387	90.2	188	-4.0	88.4	192.0	11.46	59.58	167.6	10.4	10.48	44	99.0	910	53.5	44.13	128.0	28.30	55.9	55.0	29.3	1.157	22.2	904	904	0.0	1.298	973	1.287	969	38.6	3.4	23.5		
G3516B ULB	1,387	93.0	188	-2.5	88.4	192.0	10.74	58.56	170.8	11.3	11.17	89	99.0	882	55.2	45.48	129.6	27.01	52.1	52.0	29.4	1.212	17.7	947	955	0.0	1.339	1,002	1,341	1,014	43.7	3.9	25.2		
	1,370	3	5.6	3,041.8	1.84	4.2	0.80	116.6	5.54	1.8	1.86	11	1.9	189	1.6	3.49	19.0	0.82	5.0	5.1	0.6	26	4.4	161	219			594	23	48	22	8.2	1	1.9	
			95.3	188.2	3	68.5	189.4	10.92	87.5	167.4	9.32	9.2	65	98.7	1,058	54.8	43.31	124.1	28.27	58.4	57.7	28.5	1.162	18.2	853	818			1,478	956	1,281	974	39.9	5.15	25.4

Turbine Fleet Comparison

Scope: 1/27/2019 - 2/3/2020
 Data Interval: 1 Hour
 Models: Centaur50, Centaur50, Electric, Mars100, Mars50, Saturn10, Saturn20, Turan50, Turan70, Titan130, Titan150
 Franchises: Discovery, Gulf East, Gulf West, Picoance, SSW, Transco, Wamsutter

Compressor: RPM: 0 - 50000
 Operating Mode: T5 Topped: Ignore
 NGP Topped: Ignore
 Full Load: Ignore
 NPT: Ignore

Running	Battery Voltage	T1 Temp	Inlet Dp	Fuel Consumption Specific	Fuel Flow Corrected	Fuel Flow Predicted	Fuel Flow Delta	NPT	NGP	NGP Predicted	NGP Delta	Oil Header Press	Oil Header Temp	PCD	PCD Predicted	PCD Delta	Bleed Valve Cnd	Bleed Valve Flow	Bleed Valve Deck Temp	Power Shaft	Power Shaft Predicted
JMK01	1	27.37	60.8	7.15	2.869	309.49	309.73	0.22	98.88	101.47	303.99	-2.12	41.97	136.2	225.7	235.4	-4.1	38.47	38.68	33,913	34,620
SR	1	27.95	34.3	2.83	2.721	92.24	92.98	0.23	88.83	102.09	103.80	-1.59	34.98	139.8	398.5	398.6	-0.9	33.79	33.86	863.4	11,877
RL LNK 18	1	22.67	48.8	4.92	2.859	139.99	132.57	-1.58	82.33	101.80	103.00	-1.21	41.85	124.8	225.4	246.2	-2.1	-	-	14,528	14,582
RL LNK 18	1	26.85	60.8	4.21	2.544	333.03	332.45	-0.59	88.44	105.38	103.92	-3.83	34.12	124.4	219.1	224.8	-6.8	-	-	13,863	13,923
RL LNK 09	1	26.37	48.0	5.97	2.683	388.19	312.57	-3.89	93.14	102.26	103.60	-1.34	47.11	115.5	231.7	246.8	-3.8	-	-	14,698	14,554
RL LNK 01	1	26.38	29.9	11.39	32.81	97.33	38.37	-38.37	98.32	101.48	103.80	-2.33	38.88	112.2	368.2	367.3	-0.8	-	-	8,598	13,198
RL LNK 03	1	22.33	46.2	4.88	2.784	352.92	313.01	-3.93	93.90	102.01	103.60	-1.59	36.47	125.1	226.2	241.7	-6.4	-	-	14,550	14,653
RL LNK 18	1	22.53	59.8	5.55	0	0.00	189.95	189.95	88.98	103.00	103.00	0.00	41.96	138.3	201.1	233.4	-6.7	-	-	14,139	14,519
RL LNK 18	1	27.22	44.8	4.98	2.939	387.85	312.17	-3.88	95.71	103.00	103.60	-0.69	38.73	129.8	229.6	239.8	-4.3	0.84	0.88	279.6	33,995
RL LNK 15	1	27.58	49.9	6.79	2.889	384.94	310.66	-1.18	92.27	103.25	103.60	-0.65	38.72	132.6	222.8	236.8	-6.3	0.80	0.79	184.5	13,332
RL LNK 06	1	27.25	29.8	4.91	2.842	386.82	311.19	-4.64	92.31	102.36	103.60	-1.25	37.31	112.3	226.0	242.8	-6.8	1.92	1.99	891.7	13,320
an	1.80	27.17	42.04	18.85	879.17	199.58	198.17	-15.65	93.41	102.14	103.60	-1.49	41.86	124.8	241.58	231.26	-8.94	5.94	5.99	496.16	1,871.89
	0.00	0.72	11.39	20.04	1458.19	15.85	6.87	29.92	4.80	0.82	0.00	0.78	9.42								

T5 Monitoring



T5 temperature plot as it is shown in a Pi Vision trend. This actual graph of a step change in a Turbine temperature spread associated with further degradation of the insulation.



These photos are representative of the problems that can be identified by looking more closely at changes that occur within Manufacturer safe operating limits. Loosened insulation can lodge in fuel nozzles causing uneven burn.



Performance

Summary

Taurus70 / T10802S_59_G

Elevation 0 ft
Compression Stages 1

Driver Setup

Fuel Gas		Gas Component	Mole Percent
Mole Fraction Total	100 %	Methane	98.05
Molecular Weight	16.33 gmol	Ethane	1.38
LHV	915 BTU/scf	Propane	0.05
HHV	1016 BTU/scf	iButane	0.00
Specific Gravity	0.56	nButane	0.00
		iPentane	0.00
		nPentane	0.00
		HexanePlus	0.00
		Carbon Dioxide	0.07
		Nitrogen	0.45

Driver Data

Process Data Values		Calculated Values		Performance			
Inlet Temperature	63.7 °F	Shaft Power	4.976 hp	Parameter	Value	Prediction	Dev (Pct)
GP Speed	98.0 %	Fuel Consumption	10.615 BTU/hp-hr	Inlet Temperature	63.70		°F
PT Speed	75.7 %	Fuel Standard Flow	57.74 MSCFH	Air Inlet dP	2.57		inH2O
TS Average	1,355 °F	Fuel Mass Flow	2,495 lbm/hr	PT Speed	75.65		%
Air Inlet dP	2.57 inH2O	Fuel Energy Rate	52.82 MMBTU/hr	GP Speed	97.96	100.00	-2.0 %
Exhaust Back Pressure	0.00 inH2O			TS Average	1,355	1,400	-3.2 °F
PCD	145.7 psig			Shaft Power	4.976	9.354	-49.9 hp
Fuel Mass Flow	No Data lbm/hr			PCD	145.74	224.21	-35.0 psig
				Fuel Energy Rate	52.82	78.41	-32.6 MMBTU/hr

Compressor Setup

Thru-put Gas		Gas Component	Mole Percent	Gas Properties	
Mole Fraction Total	100 %	Methane	98.05	Suction Gas Density	1.65 lbm/ft ³
Molecular Weight	16.33 gmol	Ethane	1.38	Discharge Gas Density	2.38 lbm/ft ³
LHV	915 BTU/scf	Propane	0.05	Suction Gas Enthalpy	361 BTU/lbm
Specific Gravity	0.56	iButane	0.00	Discharge Gas Enthalpy	400 BTU/lbm
Critical Pressure	695 psia	nButane	0.00	Suction Gas Compressibility	0.93
Critical Temperature	343 °R	iPentane	0.00	Discharge Gas Compressibility	0.94
		nPentane	0.00		
		HexanePlus	0.00		
		Carbon Dioxide	0.07		
		Nitrogen	0.45		

HP Compressor Data


Process Data Values		Calculated Values		Value		Prediction		Dev (Pct)	
Flow dP	135.6 inH2O	Iaentropic Head	25,321						
Suction Pressure	509.2 psig	Actual Flow	3,265						
Discharge Pressure	864.3 psig	Iaentropic Efficiency	84.78	84.37	0.4				
Suction Temp	60.5 °F	Mass Flow	323,290						
Discharge Temp	140.6 °F	Standard Flow	179.57						
A.S.V Position	100 %CL	Shaft Power	4.976						
		Compressor Speed	0	3,263	-100.0				
		Pressure Ratio	1.68						



Centrifugal Compressor Map

2/1/2020 6:55:29 AM - 2/3/2020 7:55:29 AM

- Hover over speed and efficiency lines to see labels
- Darker operating points are more recent than lighter points (Centriperfrt Calculated Points - Grey to Black) (PLC Points - light Orange to Red)



Custom Analysis

> Event Frames to Capture and report Key Events

Turbine Startup and Shutdown and Out of SoloNox Duration

Note: Report Times Central Time

Last Refreshed at: 2/3/2020 7:16:59 AM

MU01		Month	Start Time	End Time	Duration	On-Load	Mode	Pi Vision URL
Starts: 10	Stops: 10	November	11/4/2019 10:59:17 AM	11/4/2019 11:04:28 AM	00:05:11	0	Cooldown stop	Trends
Duration On-load/Solonox Off: 0.00		November	11/4/2019 3:26:04 PM	11/4/2019 3:30:44 PM	00:04:40	0	Starting	Trends
		November	11/5/2019 9:03:32 AM	11/5/2019 9:08:41 AM	00:05:09	0	Cooldown stop	Trends
		November	11/9/2019 9:30:00 AM	11/9/2019 9:35:00 AM	00:05:00	0	Starting	Trends
		November	11/9/2019 6:45:29 PM	11/9/2019 6:50:40 PM	00:05:12	0	Cooldown stop	Trends
		November	11/29/2019 7:51:39 PM	11/29/2019 7:55:50 PM	00:04:11	0	Starting	Trends
		November	11/30/2019 3:37:14 AM	11/30/2019 3:37:14 AM	00:00:00	0	Shutdown Stop	Trends
		Month HOURS			0.49			
		December	12/25/2019 12:39:25 PM	12/25/2019 12:43:41 PM	00:04:16	0	Starting	Trends
		December	12/26/2019 2:42:42 AM	12/26/2019 2:42:42 AM	00:00:00	0	Shutdown Stop	Trends
		December	12/26/2019 4:49:58 AM	12/26/2019 4:53:57 AM	00:03:59	0	Starting	Trends
		December	12/26/2019 11:04:16 AM	12/26/2019 11:04:16 AM	00:00:00	0	Shutdown Stop	Trends
		December	12/26/2019 3:16:23 PM	12/26/2019 3:20:15 PM	00:03:52	0	Starting	Trends
		December	12/26/2019 3:21:41 PM	12/26/2019 3:21:41 PM	00:00:00	0	Shutdown Stop	Trends
		December	12/26/2019 8:30:14 PM	12/26/2019 8:35:04 PM	00:04:50	0	Starting	Trends
		December	12/27/2019 7:14:15 AM	12/27/2019 7:19:24 AM	00:05:10	0	Cooldown stop	Trends
		December	12/29/2019 10:03:15 AM	12/29/2019 10:07:25 AM	00:04:10	0	Starting	Trends
		December	12/29/2019 1:50:20 PM	12/29/2019 1:55:31 PM	00:05:11	0	Cooldown stop	Trends
		Month HOURS			0.52			
		January	1/6/2020 12:30:25 PM	1/6/2020 12:35:31 PM	00:05:05	0	Starting	Trends
		January	1/9/2020 7:15:02 AM	1/9/2020 7:20:11 AM	00:05:09	0	Cooldown stop	Trends
		January	1/10/2020 2:59:51 PM	1/10/2020 3:04:52 PM	00:05:01	0	Starting	Trends
		Month HOURS			0.25			
		Total HOURS			1.26			
MU02		Month	Start Time	End Time	Duration	On-Load	Mode	Pi Vision URL
Starts: 8	Stops: 7	November	11/10/2019 2:49:06 AM	11/10/2019 2:53:57 AM	00:04:52	0	Starting	Trends
Duration On-load/Solonox Off: 0.00		November	11/25/2019 11:45:28 PM	11/25/2019 11:50:38 PM	00:05:10	0	Cooldown stop	Trends
		November	11/28/2019 9:48:39 AM	11/28/2019 9:53:34 AM	00:04:55	0	Starting	Trends
		November	11/29/2019 7:57:39 PM	11/29/2019 8:02:45 PM	00:05:07	0	Cooldown stop	Trends
		November	11/30/2019 3:53:05 AM	11/30/2019 3:57:07 AM	00:04:02	0	Starting	Trends
		Month HOURS			0.25			

Equipment Performance Monitoring

