

Customer2	10 day AVG	Difference	Percent Increase			
		0.31.kWh	2.33%			
		Load	Solar PV	Battery	Battery	Grid
average				charged	discharged	used
after	----->		13.64.kWh			
clean						
	Aug-19	21.8 kWh	17.80.kWh	11.2 kWh	10.0 kWh	8.0 kWh
	Aug-18	16.1 kWh	13.40.kWh	12.0 kWh	9.3 kWh	7.9 kWh
	Aug-17	16.2 kWh	13.00.kWh	10.0 kWh	10.7 kWh	5.1 kWh
	Aug-16	18.2 kWh	18.00.kWh	9.9 kWh	8.8 kWh	4.0 kWh
	Aug-15	22.7 kWh	15.90.kWh	11.9 kWh	11.4 kWh	10.0 kWh
	Aug-14	14.5 kWh	11.30.kWh	10.9 kWh	6.9 kWh	9.5 kWh
	Aug-13	11.7 kWh	11.30.kWh	8.2 kWh	7.3 kWh	3.8 kWh
	Aug-12	10.8 kWh	9.70.kWh	7.9 kWh	7.2 kWh	3.9 kWh
	Aug-11	15.9 kWh	15.00.kWh	10.7 kWh	10.2 kWh	3.8 kWh
	Aug-10	15.8 kWh	11.00.kWh	10.1 kWh	9.9 kWh	7.3 kWh
CLEANED	Aug-09	22.0 kWh	20.60.kWh	10.5 kWh	9.7 kWh	4.9 kWh
	Aug-08	16.6 kWh	13.60.kWh	11.3 kWh	8.1 kWh	8.9 kWh
	Aug-07	12.4 kWh	11.30.kWh	8.0 kWh	8.0 kWh	3.4 kWh
	Aug-06	14.2 kWh	12.30.kWh	8.8 kWh	7.5 kWh	5.5 kWh
	Aug-05	15.5 kWh	15.10.kWh	7.9 kWh	7.9 kWh	3.0 kWh
	Aug-04	14.8 kWh	14.70.kWh	8.8 kWh	7.4 kWh	4.1 kWh
	Aug-03	21.7 kWh	7.90.kWh	11.9 kWh	11.4 kWh	15.9 kWh
	Aug-02	21.4 kWh	14.90.kWh	12.2 kWh	10.9 kWh	10.4 kWh
	Aug-01	19.3 kWh	15.10.kWh	11.2 kWh	9.3 kWh	8.8 kWh
	Jul-31	21.5 kWh	13.30.kWh	11.3 kWh	10.8 kWh	11.0 kWh
	Jul-30	22.5 kWh	15.10.kWh	14.1 kWh	12.8 kWh	11.3 kWh
average						
before clean	----->		13.33.kWh			