

**SUPERVISOR REPORT**

APRIL 2026

MONTHS	April 2025	May 2025	June 2025	July 2025	Aug 2025	Sept 2025	Oct 2025	Nov 2025	Dec 2025	JAN 2026	FEB 2026	March 2026	APRIL 2026
<b>TOTAL WATER PRODUCED (GAL.)</b>	1,757,100	2,663,900	4,001,600	4,623,900	4,840,100	3,381,000	2,184,800	1,751,200	1,744,900	1,627,300	1,556,200	1,893,400	1,863,300
<b>DAILY AVERAGES (GAL.)</b>	58,600	85,100	133,400	149,100	140,200	112,700	70,900	70,900	60,300	52,500	55,600	61,000	62,100
<b>WATER PRODUCED LAST MONTH (GAL.)</b>	1,416,900	1,757,100	2,663,900	4,001,600	4,623,900	4,840,100	3,381,000	2,184,800	1,751,200	1,744,900	1,627,300	1,556,200	1,893,400
<b>WATER PRODUCED LAST YEAR (GAL.)</b>	2,097,700	3,327,900	4,038,100	5,654,800	3,647,200	3,111,300	2,245,400	1,359,800	1,465,900	1,389,300	1,339,900	1,416,900	1,757,100
<b>WATER SOLD (GAL.)</b>	1,484,780	2,390,608	3,281,476	3,876,884	4,357,848	3,254,548	2,024,088	1,348,644	1,333,684	1,119,006	1,258,884	1,368,840	1,499,740
<b>HIGH DAY (GAL.)</b>	123,300	120,800	163,900	194,100	202,300	165,700	146,200	157,700	156,200	147,700	137,600	71,800	89,800
<b>LOW DAY (GAL.)</b>	22,100	58,100	100,200	125,700	133,000	83,200	2,000	29,900	27,900	22,600	26,600	52,800	23,700
<b>WATER QUALITY</b>													
<b>CHLORINE RESIDUAL (LESS THEN 4.0)</b>	0.96	0.92	0.88	0.88	0.86	0.91	0.94	0.93	1.01	0.97	1	0.96	0.99
<b>CT RATIO*</b>	2.4	2.3	3	3.8	2.9	3.1	2.4	2.5	2.1	2	2.2	2.3	2.4
<b>AVERAGE RAW WATER TURBIDITY (NTUS)</b>	0.86	0.86	0.33	0.3	0.27	0.27	0.28	0.29	0.68	0.41	0.37	0.23	0.24
<b>AVERAGE FINISHED WATER TURBIDITY NTU'S (LESS THAN 0.3, 95 % OF THE TIME IS THE REQUIREMENT.)</b>	0.02	0.021	0.021	0.022	0.02	0.02	0.021	0.022	0.02	0.02	0.02	0.03	0.03

\* = CT/REQ/AVA

**PLANT MAINTENANCE**

<b>SERVICING CLEANING METER BOXES, REPLACING FAULTY METERS,CHECKING SYSTEM FOR LEAKS, EXERCISING STREET VALVES AND FIRE HYDRANTS ONGOING</b>												
Hydrants have been cleared , ready for paint												
Booster pump #2 failed had to replace, looking for electrician to diagnose electrical issue that caused it to fail												
McCullough Construction will be purchasing water from us starting 5/11/26 -???												

<b>TOTAL WATER PUMPED GALLONS 12 MONTHS</b>	<b>33,888,700</b>	<b>TOTAL WATER PUMPED GALLONS THIS MONTH</b>	<b>1,863,300</b>		
<b>TOTAL WATER SOLD GALLONS 12 MONTHS</b>	<b>29,784,466</b>	<b>TOTAL WATER SOLD GALLONS THIS MONTH</b>	<b>1,499,740</b>		
		Loss	363,560		
<b>PERCENTAGE 12 MONTH AVERAGE</b>	<b>88%</b>	<b>PERCENTAGE THIS MONTH</b>	<b>80%</b>		