



## Gasquet CSD CA0800555: MPN, Microbiology Report

Total Coliform and Escherichia coli  
Colilert: Quantitray 2K

Date of Report: 5/7/2026  
Report Period thru

Sample ID	LOCATION	Date and Time Collected	Sample Type	Total Coliform MPN	Escherichia coli MPN	Free Chlorine, field mg / L
2605061113	RAW_001_001	5/6/2026 8:15:00 AM	OTHER	435	1.00	Not Applicable

NDA = No Data Available. All samples for bacteriological analyses are analyzed by EPA approved methods selected to meet the requirements for reporting under 40 CFR 141. Unless specifically requested by the client, the laboratory will choose the most suitable method for analysis including Free Chlorine (SM 4500- Cl G-2000), Multiple Tube Fermentation (SM 9221 B, E), Colilert (SM 9223B, Idexx). NOTE: When determining the result for Quantitray the following rules are used: If all trays are >2420, the higher dilution is reported. If all trays are < 0.99, the lower dilution is reported. If only 1 dilution has > or < values, the average of other dilutions is reported.