



Notes:

- PM/PE to have awareness of Pressure Systems Testing training
- SAP to be qualified to City & Guilds SCQF Level 6: Pressure Testing for Technicians
- RAMS to include Emergency Plan in the event of the test going wrong
- Suitable test rig to be hired for the pressure test & be complete with calibrated test gauges, isolation valves and drain facility
- Pneumatic tests only permitted with written justification and Director authorisation on each occasion.

Process Owner: Steve Spencer
 Date: 27/01/17
 Revision: 0