



Brown City Pool Safety Checklist

This checklist is to be used as a guide for homeowners with pools to make sure they are in compliance with City Ordinance 150.03.

Pool Inspections will be performed annually for any pool 24 inches or higher.

Item	Compliant (✓)	Non-Compliant (X)	Comments/Notes
48 inch barrier or fence must enclose the pool.			
Barrier / Fence may only have a gap of 2 inches at the bottom.			
Barrier / Fence must have a self closing gate with a latch.			
The gate must have a lockable latch or a way to lock the gate.			
The gate lock must be 3 inches from the top of the gate.			

The full ordinance can be found on the City of Brown City website.

<https://cityofbrowncity.net/>

If you have any questions please contact the Police Chief or City Manager.



Inspector Signature:_____

Address:_____