

SOLID PLASTIC

ACCU TEC FIRE RATED

ASTM E84 – Class B Fire Performance

CRITERIA	RESULT
Flame Spread Index (FSI)	35
Smoke Developed Index (SD)	175
Classification	Class B

Testing conducted in accordance with ASTM E84 (Standard Test Method for Surface Burning Characteristics of Building Materials). Results confirm that AccuTec solid plastic (HDPE) partitions qualify as Class B material under IBC Chapter 8.