


COLOR CODING AND LABELING


GASOLINE 10% Ethanol




E10 Gasoline with Coaxial Vapor Recovery



DIESEL AND DISTILLATES



Other




ALCOHOL-BASED FUELS

Where an alcohol based product is offered for sale in addition to the three primary grades, color code as follows:




In the above example, "E" represents ethanol and "85" refers to the percentage of ethanol in the fuel.

TEMPORARILY OUT OF SERVICE



Waste Product



Color coding of monitoring wells is only required when the well covers or caps are not permanently labeled by their manufacturer
If a color code for a product you are storing is not shown above, use the products common name to identify it

UST LABELING REQUIREMENTS

UST's installed after December 27, 1985 must have a label permanently installed at the fill port with the following information on it:

- 1) The unique tank identification number (from registration certificate)
- 2) The dimensions, design and working capacity, and model number of the tank
- 3) The name of the manufacturer of the tank
- 4) The standard of design by which the tank was manufactured
- 5) The petroleum products and percentages of volume of petroleum additives which may be stored permanently and compatibly within the tank
- 6) The year in which the tank was manufactured
- 7) The date of installation of the tank
- 8) Manufacturer's statement that, "This tank conforms with 6NYCRR Part 614"

AST LABELING REQUIREMENTS

All AST's must bear a labeled or placarded with the following information:

- 1) The color code for the product stored in the tank
- 2) The unique tank identification number (from registration certificate)
- 3) The total capacity of the tank
- 4) The working capacity of the tank (90% of the tanks total capacity)