## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER LAUREL RIDGE SUBDIVISION WATER SYSTEM FLUORIDE MCL VIOLATION

Our Community Water System (CWS) violated drinking water standard. Although this is not an emergency, as our customers, you have the right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. We have been notified by the State that **our water system exceeded the maximum contaminant level (MCL) for Flouride.** The MCL for Fluoride is 4 mg/L. During the 01/01/2024 – 03/31/2024 compliance period the RAA for the Laurel Ridge Water System was 5.2 mg/L.

## What should you do?

- There is nothing you need to do. You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care provider about drinking this water.

## What does this mean?

\*Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years olf. Mottling, also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums\*

**What is being done?** What this notice means is that Laurel Ridge Water has exceeded maximum contaminant level for fluoride for over 4 quarters. We continue to work with American Water Specialties and we have submitted a Corrective Action Plan to mitigate the problem.

For more information, please contact Bart Threatte at 770-317-4050 or threatte@bellsouth.net

This notice is provided by LAUREL RIDGE SUBDIVISION WATER SYSTEM

State Water System ID# GA2410119

Date distributed: March 28, 2024