APRIL 2025 PUBLIC WORKS REPORT

Water:

- All bac-t samples for April were negative of any coliform.
- Water meters were read as usual from the 15th to the 25th of the month.
- There were 2 water meters changed out in system and 3 water meter boxes changed out.
- Made 3 water taps.

Gas:

- · Checked odorant at regulator station.
- Made 4 gas taps.
- Repaired 4 gas leaks.

Sewer:

- Customer called for 2 jet outs.
- Cleaned discharge line at lagoons.
- Washington St. sewer line has blockage.

Streets:

- Installed culvert at new park location for Blue Oval on Main St.
- Cut grass on streets all over town.
- Picked up trash around streets.