

03/17/2025

PUBLIC WORKS REPORT

Water:

- All bac-t samples for February were negative of any coliform.
- Water meters were read as usual from the 15th to the 25th of the month.
- There were 24 water meters changed out in system.
- Made water tap on Hwy 179.

Gas:

- Public awareness ads have been submitted to Tennessee Public Utility Commission (TPUC) for review.
- Public works are in the process of turning gas valves as ordered by TPUC every 12 to 15 months. Also greased and sprayed some valves.
- Checked odorant at regulator station.

Sewer:

- Customer called for 3 jet outs.
- Cleaned discharge line at lagoons.

Streets:

- Put down salt for snow at intersection.
- Put rock in potholes.