



HS7 Solenoid Valve

Specifications, Applications, Service Instructions & Parts

HS7 SOLENOID VALVE 3/4", 1", 1-1/4" PORT (20, 25, 32 mm)

Flanged
3/4" thru 1 1/4"
FPT, SW, WN, ODS
for refrigerants



INTRODUCTION

This flanged, heavy duty, pilot-operated, industrial refrigeration solenoid valve controls the flow of refrigerant. When electrically energized, a slight pressure difference across the valve causes it to open wide; when de-energized, a spring promptly closes the main Teflon seat to stop all flow in the arrow direction on the valve body.

APPLICATIONS


This advanced design valve is ideal as a standard, stock, ammonia liquid line solenoid valve. While primarily for ammonia, this valve is also suitable for R22, R134a, CO2 and other approved refrigerants. Most common use is to automatically stop liquid line feed to recirculating liquid overfeed evaporators, to float switch controlled accumulators, and to thermal expansion valves; it is also suitable for hot gas defrost, and evaporator suction. (Note: for gravity liquid drain or equalization applications use low pressure drop HCK2 gas-powered suction stop valve or HS9B gas-powered solenoid valve.)

MAXIMUM RATINGS, AMMONIA†

PORT SIZE	3/4" (20mm)	1" (25mm)	1 1/4" (32mm)
Liquid, Receiver Pressure Tons (kW), .2 bar Δ P	200 (765)	263 (983)	400 (1530)
Recirculation, 4 to 1 Tons (kW), .2 bar Δ P	45 (228)	63 (293)	90 (455)
Hot Gas, for 0°F Tons (kW)	21 (73)	27 (94)	40 (140)
Suction, 2 psi drop at 20°F Tons (kW), .15 drop at -7°C	12 (42)	16 (56)	24 (84)
Flow Factor Cv (Kv)	8.0 (7.0)	10.5 (9.0)	16.3 (14)

† For flow near maximum ratings, piping should be one size larger than port.

KEY FEATURES



ADDITIONAL FEATURES

- Encapsulated Hansen standard coil
- 300 psi (20 bar) MOPD, 500 psi (34 bar) for CO2
- Teflon main & pilot seats
- Manual opening stem
- Available close-coupled strainer
- Heavy duty, pilot-operation
- Vertical or horizontal installation
- CSA Certified Status
- Non-asbestos gaskets
- Wireless pilot lights
- CE Available

MATERIAL SPECIFICATIONS

Body: Ductile iron (Nodular Iron GGG-40)
 Bonnet-Cartridge: Steel, plated
 Piston: Stainless steel
 Plunger: Stainless steel
 Solenoid Tube: Stainless steel
 Pilot Orifice: Stainless steel
 Seat: Teflon
 Safe Working Pressure: 400 psig (27 bar) 600 psig (41 bar) for CO₂
 Operating Temperature: -60°F to +240°F
 (-50°C to +115°C)

ADVANTAGES


Power saving, low-wattage molded coil; Teflon seats; stainless steel trim including piston; spring-closing; double seal manual opening stem. One standard molded coil fits all Hansen valves.

INSTALLATION

Protect interior of valve from dirt during installation; normally use close-coupled inlet strainer. Allow 2.25" (57mm) above valve for coil removal, 3" (76 mm) below strainer for screen removal. Match arrow on body with system flow direction. If a pressure reversal can occur, as during hot gas defrost with liquid recirculation, use a check valve on the outlet side of the HS7. For proper flange gasket sealing, care must be taken when threading or welding to assure flanges are parallel to each other and perpendicular to pipe. Also, gaskets should be lightly oiled and all bolts must be tightened evenly.


INSTALLATION DIMENSIONS

INCHES (MILLIMETERS)




PARTS LIST

Item	Description	Qty	Part No.
1a	Coil Kit (115V) 1/2" Fitting w/leads	1	70-1085
1b	Coil Kit (208/230V) 1/2" Fitting w/leads	1	70-1086
1c	Coil Kit (24V) 1/2" Fitting w/leads	1	70-1087
1d	Coil Kit (Other Voltages)	1	FACTORY
	<i>Above kits consist of:</i>		
1	Bare Coil	1	N/A
2	Coil Knob	1	70-0579
3	Coil O-Ring	1	75-0340
	Solenoid Tue/Plunger Kit	1	70-1059
	<i>Above kit consists of:</i>		
5	Plunger	1	70-0295
6	Solenoid Tube	1	70-0298
7	Solenoid Tube O-Ring	1	72-0066
8	Tube Screws	4	70-0297
2	Coil Knob	1	70-0579
3	Coil O-Ring	1	75-0340
	Gasket Kit	1	70-1017
	<i>Above kit consists of:</i>		
7	Solenoid Tube O-Ring	1	72-0066
9	Upper Body O-Ring	1	70-0131
10	Lower Body O-Ring	1	70-0130
11	Flange Gasket Stem	3	70-0132
12	O-Ring	1	70-0010
13	Stem Washer	1	70-0026
14	Packing Nut	1	70-0499
16	Stem Packing	1	70-0025
15	Seal Cap O-Ring	1	70-0011
	Bonnet Cartridge Kit	1	70-1018
	<i>Above kit consists of:</i>		
17	Cartridge Assembly	1	70-0162
	Gasket Kit	1	70-1017
	Solenoid Tube/Plunger Kit	1	70-1059
	Piston Assembly Kit 3/4"	1	70-1019
	Piston Assembly Kit 1"	1	70-1020
	Piston Assembly Kit 1 1/4"	1	70-1021
	<i>Above kits consist of:</i>		
18a	Piston Assembly 3/4"	1	70-0166
18b	Piston Assembly 1"	1	70-0163
18c	Piston Assembly 1 1/4"	1	70-0167
19	Closing Spring	1	70-0155
9	Upper Body O-Ring	1	70-0131
10	Lower Body O-Ring	1	70-0130
	Stem Kit	1	70-1022
	<i>Above kit consists of:</i>		
20	Stem	1	70-0128
	Gasket Kit	1	70-1017
	Seal Cap Kit	1	70-1023
	<i>Above kit consists of:</i>		
21	Seal Cap	1	50-0411
15	Seal Cap O-Ring	1	70-0011
	Bolt and Nut Kit		
	For HS7 less Strainer (a)		70-1024
	For HS7 with Strainer (b)		70-1025
	<i>Above kits consist of:</i>		
22	Nut	4	70-0136
23a	Bolt (less Strainer) 2.75"	4	70-0339
23b	Bolt (with Strainer) 2.75"	2	70-0339
23b	Bolt (with Strainer) 6.5"	2	70-0134
24	Body		N/A
25	Flange Kit (FPT,SW,WN,ODS)		FACTORY
	<i>Includes (2) Flanges only; Specify Style and Size.</i>		




Voltage	Frequency (Hertz)	Inrush Amps	Holding Amps	Resistance at Room Temperature (Ohms)
115 VAC	60	0.73	0.24	56 ± 6
	50	0.93	0.31	
208/230 VAC	60 (208V)	0.32	0.11	226 ± 23
	60 (240V)	0.41	0.14	
	50 (230V)	0.47	0.16	
24 VAC	60	3.42	1.14	2 ± .2
	50	4.56	1.52	
24 VDC	DC	1.20	1.20	20 ± 2

STANDARD



DIN PLUG COIL



ELECTRICAL

The coil draws 16 watts and will operate properly between 85% and 110% of rated voltage (24V coil draws 19 watts). Standard coil connection is a 1/2" fitting (NPSM) for conduit, with two 18" wire leads and ground wire. Coils with DIN plug or 1/2" NPSM quick disconnect plug are available. Contact the factory. All coils are totally encapsulated and meet NEMA 3R (rainproof) and NEMA 4 (splashproof, approx. IP65) requirements. The coil should only be energized while on the solenoid tube. Otherwise, immediate coil burnout may occur. To avoid bending the solenoid tube, remove the coil from valve before connecting any electrical conduit. Pilot lights are available.

SERVICE AND MAINTENANCE

Failure to open: wrong voltage coil; low line voltage; controlling switch or thermostat not contacting; coil is burned-out; inlet/outlet pressure differential too high; less than 2 psi (0.14 bar) pressure drop across valve; piston or plunger is jammed closed with dirt.

Failure to close: controlling switch or thermostat not opening contacts; manual opening stem is turned in; piston or plunger is jammed upward by dirt; damage or dirt at main valve seat or pilot valve seat.

Before opening the valve for service, be sure it is isolated from the system and all refrigerant is removed. Disconnect electrical power from coil. Remove the coil by unscrewing the coil knob. Use a large wrench to unscrew the bonnet-cartridge proceeding cautiously to avoid any refrigerant still remaining inside the valve. Remove closing spring and piston. Check for dirt on piston or seat. Polish with fine emery cloth and replace or else install new parts. Check and replace bonnet-cartridge O-rings if necessary, using refrigerant oil or grease.

To check pilot section of valve, loosen four solenoid tube screws, break seal between solenoid tube and bonnet-cartridge; being careful to avoid any refrigerant which may remain. Check face of Teflon seat in plunger, plunger spring, and pilot seat orifice on bonnet-cartridge. Clean, polish or replace parts as necessary. Always replace plunger and solenoid tube as a set. Pilot seat is integral with bonnet-cartridge. Install new solenoid tube gasket and oil lightly. Reassemble bonnet-cartridge to valve body, using 75 foot-pounds torque to tighten secondary, metal, knife edge seal. Carefully check the valve for leaks before restoring to service.

CAUTION

Hansen valves are only for refrigeration systems. These instructions must be completely read and understood before selecting, using or servicing Hansen valves. Only knowledgeable, trained refrigeration mechanics should install, operate, or service these valves. Stated temperature and pressure limits should not be exceeded. Bonnets, solenoid tubes, etc. should not be removed from valves unless system has been evacuated to zero pressure. Must also see Safety Precautions in current List Price Bulletin and Safety Precautions Sheet supplied with product.

WARRANTY

All Hansen products, except electronics, are guaranteed against defective materials or workmanship for one year F.O.B. factory. Electronics are guaranteed against defective materials or workmanship for 90 days F.O.B. factory. No consequential damages or field labor is included.

ORDERING INFORMATION

Flange Connection Style & Sizes Inches (Millimeters)		
FPT, SW, WN		ODS
STD	ALSO	STD
3/4" (20)	1" (25) 1 1/4" (32)	7/8" (22)
1" (25)	3/4" (20) 1 1/4" (32)	1 1/8" (28)
1 1/4" (32)	3/4" (20) 1" (25)	1 3/8" (35)

FPT: Female Pipe Thread (American National Standard)

SW: Socket Weld to accommodate American and API pipe

WN: Weld Neck to match American Schedule 40 pipe

ODS: Outside Diameter Sweat, for copper tube size

Standard encapsulated solenoid coil is included for 50/60Hz 208/230, 115, or 24 volts; other voltages offered. Standard coil connection is a 1/2" fitting (NPSM). Coils with DIN plug or 1/2" NPSM quick disconnect plug are available; please specify when ordering. Pilot lights are also available.

OPTIONAL BEACON PILOT LIGHTS

Pilot Light Kit includes Beacon pilot light, knob and o-ring. A/C Coils Only.

Beacon Pilot Light Kits	
Color	Part No.
Red	70-1100
Amber	70-1101
Green	70-1102



TO ORDER:

Specify type, connection type and size, volts, and strainer if required. Unless otherwise specified, standard coil with 1/2" connection will be supplied.

TYPICAL SPECIFICATIONS

"Refrigerant solenoid valves shall have encapsulated, watertight coils, Teflon seats, steel or ductile iron bodies, spring closing pilot and main valve seats, and be suitable for a safe working pressure of 400 psig (27 bar), as manufactured by Hansen Technologies Corporation or approved equal."



Hansen Technologies Corporation

681 Commerce Street

Burr Ridge, Illinois 60527 USA

Tel: 630.325.1565 Fax: 630.325.1572 Toll: 800.426.7368

Email: info@hantech.com Web: www.hantech.com

USA • Asia • Europe • India • Latin America • Middle East

© 2019 Hansen Technologies Corporation