

1.1 ADDENDA

- .1 The following changes to the plans and specifications are to be incorporated in the tender documents:
 - .1 Dessin E6 – ELECTRICAL – SPEAKER SYSTEM DIAGRAM:
 1. Replace the TOA #DA-250DH amplifier with a TOA A-848D mixer amp or approved equal.
 2. Replace the TOA #WT-D5800, WMD5300 AND WMD5200 with a TOA WT-5800 and WM-5265 or approved equal instead.
 3. Contractor to supply and install an additional YW-4500 antenna to the system. The two antennas shall be installed according to manufacturer recommendations to allow the users the use of the wireless microphone at the ice rink. Relocate previously shown antenna on the building as required by manufacturer. Provide mounting hardware as needed.
 4. Add note 3: Contractor to supply and install all necessary wiring and conduit for the connection of this system and its components.
 5. Add a TOA MW-41B as a local audio source input at the stage. Coordinated exact location on site, install with lockable surface mount box. Contractor to supply and install additional underground PVC conduit for this connection.
 - .2 Dessin E7 – ELECTRICAL – SCHEDULES:
 1. New panel “B” is a 1 ϕ -3W panel instead of 3 ϕ -4W. Circuiting to be modified to provide better balancing if necessary.
 2. The new panel “B” 400A Main breaker must be rated 22 kAIC with its branch breakers being series rated at 10 kAIC
 - .3 Section 26 12 16.01 – DRY TYPE TRANSFORMERS UP TO 600V PRIMARY:
 1. Remove Item 2.1.4.14
 2. Remove Item 2.1.4.15
 3. Remove Item 2.1.4.16
 4. Modify Item 2.1.4.12 as follows:
 - .12 Copper windings, aluminum also acceptable.
 - .4 Section 26 24 16.01 – PANELBOARDS BREAKER TYPE: Modify item 2.1.2 and 2.1.3 as follows:
 2. 250 V panelboards: bus and breakers rated (symmetrical) interrupting capacity as indicated on drawings.
 3. 600 V panelboards: bus and breakers rated (symmetrical) interrupting capacity as indicated on drawings.

- .5 Section 26 50 00 – LUMINAIRES: Add item 2.5.2 as follows:
 - .2 Approved equals from Signify, StandPro and Cooper Lighting will also be accepted.

END OF SECTION