



## Consumer Confidence Report For Calendar Year 2016

Este informe contiene información muy importante sobre el agua usted bebe. Tradúscalo o hable co

### I. Public Water System (PWS) Information

PWS ID Number	PWS Name		
AZ04 -15123	CIBOLA MUTUAL WATER COMPANY		
Contact Person and Title	Phone Number	E-Mail Address	
KATHY FRICE OFICE MANAGER	928-857-3506	CIBOLAMUTUALWATER@HOTMAIL.COM	
We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or to attend any of our regularly scheduled meetings, please contact <u>OFFICE</u> at <u>928-857-3506</u> for additional opportunity and meeting dates and times.			

### II. Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

The report must contain a brief explanation regarding contaminants which may reasonably be expected to be found in drinking water. This explanation may include the language of paragraph 40 CFR 141.153 (h)(1)(iii) shown below, or the system may use their own comparable language:

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

**Our water source(s):** Surface water from the Colorado River

### III. Consecutive Connection Sources

A public water system that receives some or all of its finished water from one or more wholesale systems by means of a direct connection or through the distribution system of one or more consecutive systems. Systems that purchase water from another system report regulated contaminants detected from the source water supply in a separate table.

**PWS ID # AZ04 - 15123, CIBOLA MUTUAL WATER COMPANY DOES NOT HAVE A CONSECUTIVE CONNECTION SOURCE WATER, provides a consecutive connection source of water.**

### IV. Drinking Water Contaminants

Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides that may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.



Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban stormwater runoff, and septic systems.

Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

#### V. Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

#### VI. Source Water Assessment

CIBOLA DID NOT HAVE AN ASSESSMENT COMPLETED

#### VII. Definitions

AL = Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements.

MCL = Maximum Contaminant Level – The highest level of a contaminant that is allowed in drinking water.

MCLG = Maximum Contaminant Level Goal - The level of a contaminant in drinking water below which there is no known or expected risk to health.

MFL = Million fibers per liter.

MRDL = Maximum Residual Disinfectant Level. The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap.

MRDLG = Maximum Residual Disinfectant Level Goal. The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur.

MREM = Millirems per year – a measure of radiation absorbed by the body.

NA = Not Applicable, sampling was not completed by regulation or was not required.

NTU = Nephelometric Turbidity Units, a measure of water clarity.

PCi/L = Picocuries per liter - picocuries per liter is a measure of the radioactivity in water.

PPM = Parts per million or Milligrams per liter (mg/L).

PPB = Parts per billion or Micrograms per liter (µg/L).

PPT = Parts per trillion or Nanograms per liter.

PPQ = Parts per quadrillion or Picograms per liter.

TT = Treatment Technique - A required process intended to reduce the level of a contaminant in drinking water.

ppm x 1000 = ppb

ppb x 1000 = ppt

ppt x 1000 = ppq

#### VIII. Health Effects Language

**Nitrate** in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. "High nitrate levels in drinking water can cause blue baby syndrome." Nitrate levels may rise quickly for short periods-of-time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.



If **arsenic** is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

**LEAD:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. **CIBOLA MUTUAL WATER COMPANY** is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

#### IX. Water Quality Data

Microbiological	Violation Y or N	Number of Samples Present <u>OR</u> Highest Level Detected	Absent (A) or Present (P) <u>OR</u> Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
<b>Total Coliform Bacteria</b> (System takes ≥ 40 monthly samples) 5% of monthly samples are positive; (System takes ≤ 40 monthly samples) 1 positive monthly sample	Y	1		0	0	2016	Naturally Present in Environment
<b>Fecal coliform and E. Coli</b> (TC Rule)	N			0	0		Human and animal fecal waste
<b>Fecal Indicators</b> (E. coli, enterococci or coliphage) (GW Rule)	N			TT	n/a		Human and animal fecal waste
<b>Total Organic Carbon</b> (ppm)	N			TT	n/a		Naturally present in the environment
<b>Turbidity</b> (NTU), surface water only	N		0.04-0.20	TT	n/a	2016	Soil Runoff
Disinfectants	Violation Y or N	Running Annual Average (RAA)	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
<b>Chloramines</b> (ppm)	N			MRDL = 4	MRDLG = 4		Water additive used to control microbes
<b>Chlorine</b> (ppm)	N	0.1	.13 .03	MRDL = 4	MRDLG = 4	2016	Water additive used to control microbes
<b>Chloride dioxide</b> (ppb)	N			MRDL = 800	MRDLG = 800		Water additive used to control microbes
Disinfection By-Products	Violation Y or N	Running Annual Average (RAA) <u>OR</u> Highest Level Detected	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
<b>Haloacetic Acids</b> (ppb) (HAA5)	N			60	n/a		Byproduct of drinking water disinfection
<b>Total Trihalomethanes</b> (ppb) (TTHM)	Y	86 87	75-87	80	n/a	1/2016 4/2016 7/2016 10/2016	Byproduct of drinking water disinfection
<b>Bromate</b> (ppb)	N			10	0		Byproduct of drinking water disinfection
<b>Chlorite</b> (ppm)	N			1	0.8		Byproduct of drinking water disinfection



Lead & Copper	Violation Y or N	90 <sup>th</sup> Percentile AND Number of Samples Over the AL	Range of All Samples (L-H)	AL	ALG	Sample Month & Year	Likely Source of Contamination
Copper (ppm)	N	90 <sup>th</sup> Percentile = 0.47		AL = 1.3	ALG = 1.3	07/2016	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	N	90 <sup>th</sup> Percentile = 3		AL = 15	0	07/2016	Corrosion of household plumbing systems; erosion of natural deposits
Radionuclides	Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Beta / photon emitters (mrem/yr.)	N			4	0		Decay of natural and man-made deposits
Alpha emitters (pCi/L) (this is Gross Alpha 4002)	N	1.7	1.7	15	0	03/2015	Erosion of natural deposits
Combined Radium 226 & 228 (pCi/L)	N			5	0	03/2015	Erosion of natural deposits
Uranium (ug/L)	N			30	0		Erosion of natural deposits
Inorganic Chemicals (IOC)	Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Antimony (ppb)	N			6	6	03/2015	Discharge from petroleum refineries; fire retardants; ceramics, electronics and solder
Arsenic (ppb)	N			10	0	03/2015	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
Asbestos (MFL)	N	N/A		7	7		Decay of asbestos cement water mains; Erosion of natural deposits
Barium (ppm)	N	0.11	0.11-.011	2	2	03/2015	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	N			4	4	03/2015	Discharge from metal refineries and coal- burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	N			5	5	03/2015	Corrosion of galvanized pipes; natural deposits; metal refineries; runoff from waste batteries and paints
Chromium (ppb)	N			100	100	03/2015	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide (ppb)	N			200	200	03/2015	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories
Fluoride (ppm)	N	0.33	0.33-.033	4	4	03/2015	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (ppb)	N			2	2	03/2015	Erosion of natural deposits; Discharge from refineries and factories;



							Runoff from landfills and cropland.
Nitrate (ppm)	N	0.42	0.23-0.42	10	10	10/2016	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (ppm)	N			1	1	2/2013	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium (ppb)	N			50	50	3/2015	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium (ppm)	N	100	100	N/A	N/A	3/2015	N/A
Thallium (ppb)	N			2	0.5	3/2015	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
Synthetic Organic Chemicals (SOC)	Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
2,4-D (ppb)	N			70	70	3/2015	Runoff from herbicide used on row crops
2,4,5-TP (a.k.a. Silvex) (ppb)	N			50	50	3/2015	Residue of banned herbicide
Acrylamide	N	NA		TT	0		Added to water during sewage / wastewater treatment
Alachlor (ppb)	N			2	0	3/2015	Runoff from herbicide used on row crops
Atrazine (ppb)	N			3	3	3/2015	Runoff from herbicide used on row crops
Benzo (a) pyrene (PAH) (ppt)	N			200	0	3/2015	Leaching from linings of water storage tanks and distribution lines
Carbofuran (ppb)	N			40	40	3/2015	Leaching of soil fumigant used on rice and alfalfa
Chlordane (ppb)	N			2	0	3/2015	Residue of banned termiticide
Dalapon (ppb)	N			200	200	3/2015	Runoff from herbicide used on rights of way
Di (2-ethylhexyl) adipate (ppb)	N			400	400	3/2015	Discharge from chemical factories
Di (2-ethylhexyl) phthalate (ppb)	N			6	0	3/2015	Discharge from rubber and chemical factories
Dibromochloropropane (ppt)	N			200	0	3/2015	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
Dinoseb (ppb)	N			7	7	3/2015	Runoff from herbicide used on soybeans and vegetables
Diquat (ppb)	N			20	20	3/2015	Runoff from herbicide use
Dioxin [a.k.a. 2,3,7,8-TCDD] (ppq)	N			30	0	3/2015	Emissions from waste incineration and other combustion; discharge from chemical factories
Endothall (ppb)	N			100	100	3/2015	Runoff from herbicide use



Endrin (ppb)	N			2	2	3/2015	Residue of banned insecticide
Epichlorohydrin	N	NA		TT	0		Discharge from industrial chemical factories; an impurity of some water treatment chemicals
Ethylene dibromide (ppt)	N			50	0	03/2015	Discharge from petroleum refineries
Glyphosate (ppb)	N			700	700	03/2015	Runoff from herbicide use
Heptachlor (ppt)	N			400	0	03/2015	Residue of banned termiticide
Heptachlor epoxide (ppt)	N			200	0	03/2015	Breakdown of heptachlor
Hexachlorobenzene (ppb)	N			1	0	03/2015	Discharge from metal refineries and agricultural chemical factories
Hexachlorocyclopentadiene (ppb)	N			50	50	03/2015	Discharge from chemical factories
Lindane (ppt)	N			200	200	03/2015	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor (ppb)	N			40	40	03/2015	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa,
Oxamyl (a.k.a. Vydate) (ppb)	N			200	200	03/2015	Runoff/leaching from insecticide used on apples, potatoes and tomatoes
PCBs [Polychlorinated biphenyls] (ppt)	N	NA		500	0		Runoff from landfills; discharge of waste chemicals
Pentachlorophenol (ppb)	N			1	0	03/2015	Discharge from wood preserving factories
Picloram (ppb)	N			500	500	03/2015	Herbicide runoff
Simazine (ppb)	N			4	4	03/2015	Herbicide runoff
Toxaphene (ppb)	N			3	0	3/2015	Runoff/leaching from insecticide used on cotton and cattle
Volatile Organic Chemicals (VOC)	Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Benzene (ppb)	N			5	0	2/2016	Discharge from factories; leaching from gas storage tanks and landfills
Carbon tetrachloride (ppb)	N			5	0	2/2016	Discharge from chemical plants and other industrial activities
Chlorobenzene (ppb)	N			100	100	2/2016	Discharge from chemical and agricultural chemical factories



o-Dichlorobenzene (ppb)	N			600	600	2/2016	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	N			75	75	2/2016	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	N			5	0	2/2016	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	N			7	7	2/2016	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	N			70	70	2/2016	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	N			100	100	2/2016	Discharge from industrial chemical factories
Dichloromethane (ppb)	N			5	0	2/2016	Discharge from pharmaceutical and chemical factories
Ethylbenzene (ppb)	N			5	0	2/2016	Discharge from industrial chemical factories
Tetrachloroethylene (ppb)	N			700	700	2/2016	Discharge from petroleum refineries
1,2,4-Trichlorobenzene (ppb)	N			5	0	2/2016	Discharge from factories and dry cleaners
1,1,1-Trichloroethane (ppb)	N			70	70	2/2016	Discharge from textile-finishing factories
1,1,2-Trichloroethane (ppb)	N			200	200	2/2016	Discharge from metal degreasing sites and other factories
Trichloroethylene (ppb)	N			5	3	2/2016	Discharge from industrial chemical factories
Toluene (ppm)	N			5	0	2/2016	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	N			1	1	2/2016	Discharge from petroleum factories
Xylenes (ppm)	N			2	0	2/2016	Leaching from PVC piping; discharge from chemical factories
	N			10	10	2/2016	Discharge from petroleum or chemical factories

#### XI. Violations

Type / Description	Compliance Period	Corrective Actions taken by PWS
TTHM/DPBS	2016	We now run the storage tank down to only 2 days of water usage so the water sets in storage less time.

An explanation of the violation(s) in the above table, the steps taken to resolve the violation(s) and any required health effects information are required to be included with this report. (Attach copy of Public Notice if available.)