

THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION CREATED BY EJS ASSOCIATES. THAT CANNOT BE REPRODUCED OR DIVULGED, IN WHOLE OR IN PART, WITHOUT WRITTEN AUTHORIZATION FROM EJS ASSOCIATES.



CLIENT



HEB BLALOCK
WAREHOUSE

4501 BLALOCK RD

HOUSTON, TX 77041

PROJECT

INTERIOR &
EXTERIOR LED
UPGRADE

REVISIONS

NO.	DESCRIPTION	DATE

DRAWN BY: E. REEVES
 CHECKED BY:
 APPROVED BY: E. REEVES
 DRAWING DATE: 7/19/21
 JOB NUMBER: P21016

DRAWING TITLE:


**WAREHOUSE
161WATT LED
HIGHBAY
PHOTOMETRIC**

SHEET NO.

E1.0



SCALE



Luminaire Schedule						
Symbol	Qty	Label	LLF	Lum. Watts	Total Watts	Lum. Lumens
☐	629	EHB2-162-850_11102016	0.900	161.2	101394.8	20717

Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
Room_1_Workplane	Illuminance	Fc	26.32	29.4	8.3	3.17	3.54
Room_2_Workplane	Illuminance	Fc	26.29	29.5	10.0	2.63	2.95

SHEET NOTES:

1. ILLUMINATING ENGINEERING SOCIETY OF NORTH AMERICA (IESNA) HANDBOOK 10TH ADDITION, CHAPTER 22 COMMON APPLICATIONS FOR BLDGS RECOMMENDS 10-30 FOOTCANDLES FOR SHIPPING AND RECEIVING SPACES FOR PEOPLE 25-65 YEAR OF AGE HAS BEEN FOLLOWED TO CREATE THIS LAYOUT.

2. LAYOUT IS BASE ON 25FT BY 25FT SPACING.

FLAG NOTES:

▶ NOT USED