

Greater Ouachita Water System Lakeshore Swartz Water System Lead Copper Rule Materials Inventory

To the best of Greater Ouachita Water System knowledge from repairing and replacing numerous lines in the Lakeshore Swartz Water System LA1073071, the following materials have been found to be in use in the water distribution system:

- A/C
- Cast iron
- Copper
- Galvanized iron
- Polypipe
- Steel

No lead main lines have been observed in the Lakeshore Swartz Water distribution system.

Types of service lines that have been observed in the Lakeshore Swartz Water system:

- Copper
- PEX
- PVC

No lead service lines have been observed in the Lakeshore Swartz Water System.

The following home plumbing materials may be used in the homes of the Lakeshore Swartz Water System:

- Cast Iron
- Copper
- PEX
- PVC

The following is a summary of the historical lead and copper results in mg/L for the Lakeshore Swartz Water System:

Location	2010 Copper	2010 Lead	2013 Copper	2013 Lead	2016 Copper	2016 Lead
Lakeshore Dr	0.1	0.002				
Lincoln Rd. Apts	0.0	0.000	0.0	0.000	0.1	0.006
Cedarbrook Dr	0.0	0.001				
Southwood Cir	0.1	0.007	0.0	0.000	0.1	0.015
Timberwood Dr	0.0	0.003	0.0	0.000	0.1	0.001
Winchester Cir	0.0	0.000	0.0	0.000	0.0	0.000
Wheeler Dr	0.0	0.001	0.0	0.000	0.0	0.000
Wheeler Dr	0.0	0.001	0.1	0.032	0.1	0.000
Caney Ridge Rd	0.0	0.000	0.0	0.000	0.2	0.001
Joe White Rd	0.0	0.000	0.0	0.000	0.0	0.000
Ashlawn Dr	0.1	0.001	0.1	0.000	0.0	0.001
Cedarbrook Dr	0.0	0.001	0.0	0.001	1.4	0.000
Barkley Dr	0.0	0.000	0.0	0.000	0.0	0.002
Clayton Dr	0.0	0.002				
Sun Valley Dr	0.0	0.001	0.0	0.000	0.0	0.001
Rowland Dr	0.0	0.001	0.0	0.000	0.0	0.000
Connie Lynn Dr	0.0	0.000	0.0	0.001	0.0	0.000
Margaret Dr	0.0	0.000	0.0	0.000	0.3	0.000
Briarwood St	0.0	0.079	0.0	0.001	0.0	0.004
Timberwood Dr	0.0	0.002	0.0	0.002	0.0	0.001
Lincoln Rd Apts			0.0	0.000	0.0	0.001
Lincoln Rd Apts			0.0	0.000	0.0	0.002
Rowland Dr			0.0	0.000	0.0	0.000
Jerold Dr					0.5	0.003
Jerold Dr					0.0	0.000
Love					0.0	0.000

Location	2010 Copper	2010 Lead	2013 Copper	2013 Lead	2016 Copper	2016 Lead
Topic St					0.0	0.001
Topic St					0.6	0.003
Current					0.0	0.001
Swartz Fairbanks					1.4	0.001
Lisa					0.1	0.003
Jerold					1.0	0.003
Topic St					0.0	0.000

The action level for lead is 0.015 mg/L. The action level for copper is 1.3 mg/L