



SEAL REPORT

Envelope sealing performed for:


Mueller

Austin, TX 78723

Date: 2/2/2026

Floor Area: 2209.00 ft²

Structure Volume: 24179.00 ft³



ACH@50Pa

8.03 ACH@50Pa	2.12 ACH@50Pa
-------------------------	-------------------------

Leakage equivalent to

389.6 Sq.In	103.0 Sq.In
--------------------	--------------------

● Before ● After

73.6%
Reduction in
Envelope
Leakage

02:16
hh:mm
Seal Time

99 Note: Envelope leakage and air-change results are calculated at a STANDARD OPERATING PRESSURE OF 50 Pa. series-1-1286.40 99

Envelope sealing performed by:

Kevin Holder
787 Development

Phone: (512) 537 6464

Aeroseal Case ID: 8340

Hardware: AeroBarrier Connect

