


Envelope sealing performed for:

Austin, TX 78723

Date: 2/12/2026
 Floor Area: 2209.00 ft²
 Structure Volume: 24179.00 ft³



ACH@50Pa

5.98 ACH@50Pa	1.83 ACH@50Pa
-------------------------	-------------------------

Leakage equivalent to

290.0 Sq.In	88.7 Sq.In
--------------------	-------------------

● Before ● After

69.4%
Reduction in
Envelope
Leakage

02:00
hh:mm
Seal Time

59
 series-1-1314-80
 59
 Envelope leakage and air-change results are calculated at a STANDARD OPERATING PRESSURE of 50 Pa.

Envelope sealing performed by:

Kevin Holder
 787 Development

Phone: (512) 537 6464

Aeroseal Case ID: 8340
 Hardware: AeroBarrier Connect

