


Envelope sealing performed for:

Austin, TX 78723

Date: 1/7/2026
 Floor Area: 607.00 ft²
 Structure Volume: 6634.00 ft³



ACH@50Pa

8.27 ACH@50Pa	2.15 ACH@50Pa
-------------------------	-------------------------

Leakage equivalent to

110.1 Sq.In	28.7 Sq.In
--------------------	-------------------

● Before ● After

74%
Reduction in
Envelope
Leakage

01:34
hh:mm
Seal Time

49
 Note: Envelope leakage and air-change results are calculated at a STANDARD OPERATING PRESSURE OF 50 Pa.
 series-1-456.30
 49

Envelope sealing performed by:

Kevin Holder
 787 Development

Phone: (512) 537 6464

Aeroseal Case ID: 8340
 Hardware: AeroBarrier Connect

