

Recognised since 1968

School No.- 23011

0172-2697332

Estd.: 1968

Affiliation no.- 2630025

balniketan37@rediffmail.com, 23011@cbseshiksha.in

BAL NIKETAN MODEL SENIOR SEC. SCHOOL

(Recognised) Affiliated To C.B.S.E

Sector 37- A, Chandigarh, 160036

Lab test report of drinking water (Annexure 1) being supplied directly by the Municipal Corporation is attached alongwith **Building Safety & Sanitation Certificate (Annexure 2)**.



Principal
Bal Niketan Model Sr. Sec. School
(Recognised) Affiliated to C.B.S.E.
Sector 37-A, Chandigarh



Manager
Bal Niketan Model Sr. Sec. School
(Recognised) Affiliated to C.B.S.E.
Sector 37-A, Chandigarh



Annexure - 1

MUNICIPAL CORPORATION CHANDIGARH
Public Health Laboratory at Water Works, Sector 39.

TEST - REPORT

Not for legal use

Ref. No. & Date :- No. BN/C - R01/2022-23 dated 04.07.2022
Issued to :- The Principal,
Bal Niketan Model Sr. Sec. School,
Sector - 37 - A, Chandigarh.
Quantity of sample :- Approximate 1200 ml.
Date of Collection :- 08.07.2022
Client reference :- Sample collected by Laboratory Staff.
Packing of sample :- Sample filled in P.P. and Glass Bottle.
Source of sample :- from School tap of Bal Niketan Model Sr. Sec.
School, Sector - 37 - A, Chandigarh

S. No.	Examination	Quality Standard	Units	Results
1.	Turbidity	<1.0	N.T.U	0.9
2.	pH	7.0-8.5	----	7.79
3.	Residual Chlorine	0.2 - 0.4	mg/L	0.2
4.	Total Alkalinity (as CaCO ₃)	200	-do-	84
5.	Total Hardness (as CaCO ₃)	200	-do-	70
6.	Chlorides (as Cl)	200	-do-	04
7.	Free & Saline Ammonia	Nil	-do-	Nil
8.	Total Dissolved Solids	500	-do-	130
9.	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No.07/2022-23/083575, dated 06.07.2022, Amount Rs.3300/-.

Note:- Water is fit for drinking.

Attested

Lab. No. MCPHL/22/ 3090

Dated: -11.07.2022

Sh
Manager

Bal Niketan Model Sr. Sec. School
(Recognised) Affiliated to C.B.S.E.
Sector 37-A, Chandigarh

2

Jan
Chemist,
MCPH Laboratory,
Chandigarh

Kant. Kishan
Sub Divisional Engineer,
M.C.P.H. Sub Division No. 2,
Chandigarh

01/11/2022

Endst No. MCPHL/22/ _____

Dated _____

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh for information please.

Attested

Rita Kapoor
Principal

Bal Niketan Model Sr. Sec. School
(Recognised) Affiliated to C.B.S.E.
Sector 37-A, Chandigarh

2

Sd/-
Chemist
MCPH Laboratory
Chandigarh

Sd/-
Sub Divisional Engineer,
M.C.P.H. Sub Division No. 2,
Chandigarh

Aakriti

ARCHITECTS - BUILDERS

Annexure - II

ENGINEERS, REGD. VALUERS, INTERIOR DESIGNERS & CONSTRUCTION CONSULTANTS

Dated: 24-06-2024

TO WHOM IT MAY CONCERN

Certified that the construction of building including sanitation work of **Bal Niketan Model Senior Secondary School, Sector: 37A, Chandigarh**, has been done under my supervision as per the building construction norms / codal provisions of Chandigarh Administration and building is quite safe, the inspection of which was carried out by me along with the Principal of the school , Mrs. Rita Kapoor. The school building is three storeyed and comprises of two blocks. Sanitary condition is also satisfactory.

Sunil Chauha

Er. Sunil Chauha
B.Sc. Engg., M.E.,
H.No.: 1032, Sector:4, Panchkula
Mob: 9814032677

Attested

Rita Kapoor

Principal
Bal Niketan Model Sr. Sec. School
(Recognised) Affiliated to C.B.S.E.
Sector 37-A, Chandigarh

R

Attested

SR

Manager
Bal Niketan Model Sr. Sec. School
(Recognised) Affiliated to C.B.S.E.
Sector 37-A, Chandigarh

R