

Eastmont Water Company
PO BOX 896
Boring, OR 97009

Project: Water Testing
Project Number:
Project Manager: Chuck Meservy

Work Order #:
2608043
Reported:
08/12/2026 17:05

Sample Results

Sample: EP-A Well Site Hose Bib
2608043-01 (Drinking Water)

Sampling 10810 SE Eastmont Drive Damascus
Location: OR 97089

Analyte	Result	Limit	LOQ	Units	Date Analyzed	Date Prepared	Method	Note
PFAS								
11CI-PF3OUdS	ND	--	0.004000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
ADONA	ND	--	0.002000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
9CI-PF3ONS	ND	--	0.002000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
HFPO-DA	ND	0.01	0.002000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
NEtFOSAA	ND	--	0.004000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
NMeFOSAA	ND	--	0.004000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
PFBS	ND	--	0.002000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
PFDA	ND	--	0.004000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
PFDaA	ND	--	0.004000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
PFHpA	ND	--	0.002000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
PFHxS	ND	0.01	0.002000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
PFHxA	ND	--	0.002000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
PFNA	ND	0.01	0.004000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
PFOS	ND	0.004	0.002000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
PFOA	ND	0.004	0.002000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
PFTA	ND	--	0.004000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
PFTTrDA	ND	--	0.004000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	
PFUnA	ND	--	0.004000	ng/mL	8/12/26 7:18	8/6/26 22:00	EPA 537.1	

Notes and Definitions

Item	Definition
ND	Analyte NOT DETECTED at or above the LOQ.
LOQ	Limit of Quantitation

The laboratory holds ORELAP accreditation for arsenic, beryllium, cadmium, chromium, copper, lead, manganese, nickel, selenium, thallium, vanadium, zinc, nitrate, total coliforms (P/A), E. Coli (P/A), and PFAS in drinking water. Test results meet all requirements of NELAP and the Rose City Laboratories quality assurance plan unless otherwise noted. Samplings performed by RCL personnel follow sampling SOP 30. Samples not collected by RCL personnel are analyzed in "as received" condition. These results relate only to the sample(s) included on this report. The report may not be reproduced except in full, without the written permission of Rose City Labs.