



WATER CONTAMINANTS IN BONNERS FERRY, IDAHO

CONTAMINANT	THIS UTILITY	EWG'S GUIDELINES	LEGAL LIMIT	POTENTIAL HARM	POSSIBLE SOURCE
Haloacetic acids (HAA5)	35.7 ppb	0.1 ppb	60 ppb	cancer	disinfectant byproduct
Radium, combined (-226 & -228)	1.40 pCi/L	0.05 pCi/L	5 pCi/L	cancer	erosion of natural deposits
Total trihalomethanes (TTHMs)	31.7 ppb	0.15 ppb	80 ppb	cancer	disinfectant byproduct
Barium	7.20 ppb	700 ppb	2,000 ppb	gastrointestinal issues	erosion of natural deposits
Nitrate	0.00886 ppm	0.14 ppm	10 ppm	cancer	erosion of natural deposits