

NOTES:

SERVICING NOTES:

- SERVICING 22 LOTS WITH CUSTOMER SUPPLIED METERING 200A 120/240V 1Ø 3W

GENERAL NOTES:

- CUSTOMER MUST COMPLY WITH THE ELECTRICAL SERVICE REQUIREMENT AVAILABLE AT WWW.SASKPOWER.COM
- CUSTOMER IS RESPONSIBLE FOR LOCATING ALL NON-UTILITY OWNED UNDERGROUND FACILITIES IN THE AREA OF PROPOSED CONSTRUCTION. ANY DAMAGE TO INCORRECTLY LOCATED OR UNDEFINED FACILITIES ARE THE RESPONSIBILITY OF THE CUSTOMER
- CUSTOMER RESPONSIBLE FOR REPAIR OF PAVEMENT AND LANDSCAPE
- CUSTOMER RESPONSIBLE FOR CONDUIT AND SERVICE CABLE FROM METERING AS PER ELECTRICAL CODE
- CUSTOMER TO PROVIDE CLEAR PATH FOR SASKPOWER CREW
- SITE MUST BE TO FINAL GRADE AND CLEAR OF OBSTRUCTIONS BEFORE SASKPOWER WILL INSTALL FACILITIES
- SASKPOWER WILL BE RESPONSIBLE FOR PUBLIC UTILITY LOCATES REQUIRED ALONG THE TRENCHING/ DIRECTIONAL BORING PATH AND WILL BE RESPONSIBLE FOR ANY DAMAGE TO INCORRECTLY LOCATED OR UNDEFINED FACILITIES

LANDSCAPING NOTES:

- SASKPOWER DOES NOT APPROVE ANY IRRIGATION FACILITIES OR LARGE TREES PLANTED WITHIN THE UTILITY EASEMENT
- SASKPOWER PERMITS BUSHES AND SHRUBS TO BE PLANTED WITHIN THE EASEMENT; THOSE WITH SMALL, SHALLOW, NON-AGGRESSIVE ROOT SYSTEMS. PLEASE BE AWARE THAT ANY BUSHES AND SHRUBS, PLANTED TO SCREEN ABOVE GROUND INFRASTRUCTURE, SHALL NOT IMPEDE ACCESS TO THE DOORS OF THE EQUIPMENT
- A 3.0m CLEAR ZONE IS REQUIRED ON THE DOOR FACING SIDE AND A 1.0m CLEAR ZONE ON THE REMAINING SIDES
- REFER TO THE CONSENT AND AGREEMENT FORM, EASEMENT AGREEMENT AND EASEMENT MAP FOR ADDITIONAL DETAILS.