

NFPA 70 NEC
IFC 319 Mobile Food Preparation vehicles
NFPA 58 LP Gas Code
NFPA 96

FOOD TRUCK / CONCESSION TRAILERS / TENTS

VENDOR NAME: _____ DATE: _____

CONTACT NAME: _____ PHONE#: () _____

ITEM	ITEM	
GENERAL SAFETY		
1) Current City Business License	1) Portable ABC Fire Extinguisher IFC 319.4.2 NFPA 96: 10.9	
2) Current Health Department Permit	A. Minimum 2A:10BC (Non Propane Units)	
3) No public seating inside unit	B. Minimum 4A:40BC (Propane Units)	
4) Minimum 10 ft. clearance around unit NFPA 96:17.2.1	C. Travel distance <30 feet	
5) Adequate fire department access	D. Current certification tag NFPA 10	
POWER SOURCE (GENERATORS) & FUEL SUPPLY		
1) Fuel tanks filled to capacity	E. Visible and accessible NFPA 10	
REFUELING IS ONLY ALLOWED DURING NON-OPERATING HOURS		
2) Portable Generator Exhaust System Does not apply to vehicle mounted unit	2) Portable Class K Fire Extinguisher IFC 319.4.2 NFPA 96:11.7.2	
A. Min 10 ft from opening and intakes NFPA 96:17.2.3	A. Minimum 2.5 gallon Class K	
B. Min 10 ft from means of egress NFPA 96:17.2.1	B. Travel distance <30 feet	
C. Directed away from buildings/ vendors NFPA 96:17.2.1	C. Current certification tag NFPA 10	
3)Electrical receptacles GFCI protected NFPA 70: 210.8.B	D. Visible and accessible NFPA 10	
A. No open junction boxes/unsafe conditions	3) Hood System	
TYPE 1 HOOD SYSTEM REQUIRED FOR FRYING OR GRILLING OPERATIONS		
LP-GAS SYSTEM Pressure test conducted? NFPA 58:16.11.4. IFC 319.10.3	A. Current certification tag (6 Months) NFPA 96	
1) Main shut off valve accessible NFPA 58: 6.26.4.1(3)	B. Manual pull station/ along path of egress NFPA 96:11.4.1	
2) Portable containers upright and secure IFC 319.8	C. Filters clean / in place NFPA 96:6.1	
3) Leak test completed and documented NFPA 58: 6.26.5.1	D. UL-300 compliant NFPA 96:11.2.2	
4) Leak test supplies available at event NFPA 58:	E. Proper head placement with appliances NFPA 96:11.2.3.4	
5) Flex connector at regulator/fixed pipe NFPA 58 6	F. Utility controls / Auto shutoffs installed NFPA 96: 11.3.1	
6) Gas detector installed and tested IFC 319.8.5 NFPA 58: 6.26.5.1	SOLID FUEL SAFETY (WOOD, CHARCOAL, OTHER SOLID FUEL USE)	
7) Container within 10 yr manufacturer date NFPA 58	1) No fuel storage above appliances/vents NFPA 96: 15.9.2.2	
8) Tank Condition (rust, pits, dents, damage) NFPA 58	2) Fuel storage >3 ft to cooking appliance NFPA 96: 15.9.2.2	
9) Hose assembly marked for LPG use IFC 319.8	3) Fuel storage not near any combustibles NFPA 96: 15.9.2.7	
10) Hose equipped with factory fittings IFC 319.5	4) Fuel storage not in path of ash removal NFPA 96: 15.9.2.4	
11) No CSST Piping installed in trailer/truck IFC 319.5	5) Fuel storage not near removed ashes NFPA 96: 15.9.2.4	
12) Gas connections/ T's located beneath unit NFPA 58: 6.26.5.1 (J)	6) Firebox emptied minimum once per day NFPA 96: 15.9.8.3.1	
13) Grommets around all pipe penetrations NFPA 58: 6.26.5.1(H)3	7) Ash stored in closed, metal container NFPA 96: 15.9.3.8.1	
14)ANSI Z 21.69 flexible appliance connector IFC 319.5	8) Removed ash > 3 ft. to any appliance NFPA 96: 15.9.3.8.1	
LPG CYLINDERS THAT APPEAR TO BE OVERFILLED OR HAVE ANY DISCREPANCIES MUST BE REMOVED FROM THE PROPERTY PRIOR TO THE EVENT		
ON SITE EVENT INSPECTION TENT/CANOPY/MEMBRANE STRUCTURE		
OPERATIONAL SAFETY		
1) Hot surfaces attended at all times	1) Original Manufacture Label present NFPA 102.10.3	
2) Gas valves closed when not in use NFPA 58:16.9.1	LABEL MUST PROVIDE INFORMATION ON SIZE, FABRIC AND FIRE RESISTANCE RATING	
3) Cooking equipment in clean condition NFPA 96: 12.4	2) No Smoking / Exit Signs posted NFPA 102:8.5	
4) Operate units with vents / window open NFPA 96: 12.1.1	3) No Flammable liquids inside tent / canopy NFPA 102:8.5	
	4) No combustible material inside tent / canopy NFPA 102:8.5	
	5) Properly secure / fastened down NFPA 102:8.4	
	6)Protective barrier around generator	

This APPROVED inspection form is valid until December 31 of this year Any modifications or alterations of appliances, operating procedures, or safety equipment may void this permit, and the Fire Marshal's office shall be notified to schedule a reinspection.

CORRECTIVE ACTION SHALL BE CARRIED OUT IMMEDIATELY TO CORRECT ALL VIOLATIONS NOTED.

THE FIRE MARSHAL'S OFFICE DOES NOT GRANT PERMISSION OR APPROVAL OF A BUSINESS/OPERATION WHERE VIOLATIONS EXIST.

NOTIFY THIS OFFICE AS CORRECTIVE ACTIONS ARE COMPLETED.

RE OFFICIAL: _____ OCCUPANT: _____