



June 12, 2023

Chris Martin

New Water 333 Cyprus Run Ste 146 Houston, TX 77094

SATL Report No.: 2306120 RE: State - Oak Hill NWS Project Number: 0150156

Dear Chris Martin

SATL received 1 Sample(s) on 06/08/2023 for analyses identified on the chain of custody. The analyses were performed using methods indicated on the laboratory report. Any deviations observed at sample receiving are notated on the Sample Receipt Checklist and/or Chain of Custody documents attached as part of this analytical report.

Sincerely,

For San Antonio Testing Laboratory, Inc.

Richard Hawk, General Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.





New Water 333 Cyprus Run Ste 146 Houston TX, 77094

Additional Notes:

Project Manager: Chris Martin Project: State - Oak Hill NWS Project Number: 0150156 **Reported:** 06/12/23 15:13 **Received:** 06/08/23 10:06

Report No. 2306120

SAMPLE SUMMARY

Total Samples received in this work order: <u>1</u>

The following samples were requested for analysis as per the CoC. Any re-runs or re-analyses requested are identified as such.

Sample ID	<u>Laboratory ID</u>	<u>Matrix</u>	Sampling Method	Date Sampled	Date Received
Tank Site	2306120-01	Drinking Water	Grab	06/08/23 09:14	06/08/23 10:06

Notes

All quality control samples and checks are within acceptance limits unless otherwise indicated.

Test results pertain only to those items tested.

All samples were in good condition when received by the laboratory unless otherwise noted.

1610 S. Laredo Street, San Antonio, Texas 78207-7029 (210) 229-9920 Fax (210) 229-9921





New Water 333 Cyprus Run Ste 146 Houston TX, 77094

Additional Notes:

Project Manager: Chris Martin Project: State - Oak Hill NWS Project Number: 0150156 **Reported:** 06/12/23 15:13 **Received:** 06/08/23 10:06

Report No. 2306120

Sample ID #: Tank Site Sampling Method: Grab Lab Sample ID #: 2306120-01

Sample Matrix: Drinking Water Date/Time Collected: 06/08/23 09:14

Sample Matrix. Drinking wa	itti			Date/Time Concetta. 00	100125 07.	17		
Analyte	Result	Units	PQL	Prep Method	Batch	Analyzed	Method	Analyst Notes
Microbiological Parameters								
Total Coliforms *	Absent	-		Start 06/08/23 11:17/En	nd 06/09/23	12:03	Colilert	JA
E. Coli *	Absent	-		Start 06/08/23 11:17/En	nd 06/09/23	12:03	Colilert	JA
Field Parameters								
Residual Chlorine	1.70	mg/L						

1610 S. Laredo Street, San Antonio, Texas 78207-7029 (210) 229-9920 Fax (210) 229-9921





New Water 333 Cyprus Run Ste 146 Houston TX, 77094

Additional Notes:

Project Manager: Chris Martin Project: State - Oak Hill NWS

Project Number: 0150156

Reported: 06/12/23 15:13 **Received:** 06/08/23 10:06

Report No. 2306120

DEFINITIONS

* TNI / NELAC accredited analyte
PQL Practical Quantitation Limit
MCL Maximum Contaminant Level

mg/Kg Milligrams per Kilogram (Parts per Million) mg/L Milligrams per Liter (Parts per Million)

PPM Parts per Million

L LCS recovery is outside QC acceptance limits, the results may have a slight bias.

M MS recovery is outside QC limits, the results may have a slight bias due to possible matrix interferences.

NR Not Recovered due to source sample concentration exceeds spiked concentration.

RMCCL Recommended Maximum Concentration of Contaminants Level

Surr L Surrogate recovery is low outside QC limits.
Surr H Surrogate recovery is high outside QC limits.

HT Sample received past holdtime
IC Improper Container for this analyte(s)
IP Improper preservation for this analyte(s)

IT Improper Temperature
 V Inssuficient Volume
 B Sample collected in Bulk
 S RPD is outside QC limits.
 AB VOA Vial contained air bubbles.

OP ortho-Phosphate was not filtered in the field within 15minutes of collection.

CCV Continuing Calibration Verification Standard.
ICV Initial Calibration Verification Standard.

Test Methods followed by the laboratory are referenced in the following approved methodology, unless otherwise specified.

Standard Methods for the Examination of Water and Wastewater, 23rd Edition, 2017

Methods for Chemical Analysis of Water and Wastes, EPA 600/4-79-020, Rev. March 1983

EPA SW Test Methods for the Examination of Solid Waste, SW-846, 1996

1610 S. Laredo Street, San Antonio, Texas 78207-7029 (210) 229-9920 Fax (210) 229-9921





New Water 333 Cyprus Run Ste 146 Houston TX, 77094

Additional Notes:

Project Manager: Chris Martin Project: State - Oak Hill NWS

Project Number: 0150156

Reported: 06/12/23 15:13 **Received:** 06/08/23 10:06

Report No. 2306120

Aimee Landon For Sairam Abburu, Lab Director For

Richard Hawk, General Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

TCEQ Microbial Reporting Form Water System Identification & Sample Collection Information (Please type or use block print) TX TX0150156	Test Results must meet all accreditation / certification req	SHADED AREA FOR LABORATORY USE ONLY	SYSTEMS Yes	STE 146	18.3 °C Asomrected Remo Received By 1 1/1	att Himelan was un	Other Contact: Office@newwatersystem.com Aested By:	Signature: Time: 11/7 Laboratory Approval: Date:	Wowner ☑ Operator Other: Report to Client By: Report to Client By: Date: Date:	Chlorine Residual water samples is a crime punishable under state and/or federal law. (Texas Penal Code, Title 8, Chapter 37.10) By signing this form, the sampler and this form that all information is accurate. Chlorine Residual Lab Results.	Sample ID & Date of Rejection Code Test Originating Sample Occur, Imm. 6. T. (If applicable) Mark-od-	ulion) (All Repeat, Curde T. for Tree, Tr	Color Colo	4€	1 2			an	No. of the control	Head Head	m instructions: www.toeq.texas.gov/drinkingwater/microbial/revised-total-coliform-rule * Special and Contruction samples are NOT FOR COMPLIANCE Lab Rejected Code (LR) - Document Reason:	
TCEQ Microbia Water System Identification & San Public Water System ID: TX (Must be 7 digits, include all zeros)	Public Water System Name: OAK HILL NW	County: BEXAR	Name: NEW WATER	Address: 333 CYPRESS RUN	City: HOUSTON	State: TX	Phone #: (713) 882-3165	_	Operator License #: WG001856	Falsification of this form or tampering with water samples is a crime punishat acknowledges that samples were collected according to the systems establish	Sample Identification/Location Use Specific Address / Location identified in Sample	Siting Plan	Raw Wells - Use Source ID for Well Sampled (Example: G1234567A)	TANK SITE								of 7



Sample Receipt Checklist

Client: New Water	•	Project Manager: Saira	m Abburu
Project: State - Oak	Hill NWS	Project Number: 01501	156
Report To: Chris Martin		SATL Report 1	Number: 2306120
CIIIIS IVIAITHII			
Work Order Due by:	06/13/23 17:00 (3 day TA		10.00
Received By:	Aimee Landon	Date Received: 06/08/23 Date Logged In: 06/08/23	
Logged In By:	Aimee Landon	Date Logged III. 00/08/23	10.27
Sample(s) Received of	on ICE/evidence of Ice (cooler	with melted ice,etc):	Yes
Sample temperature a			18.3°C
Custody Seals Presen	t:		No
All containers intact:			Yes
Sample labels/COC a	gree:		Yes
Samples Received wi			Yes
Samples appropriatel			Yes
	proken/damaged/leaking:		No
	n VOA vials for VOC/TPH and	alyses, if applicable:	Not Applicable
TRRP 13 Reporting r			No
	filled to volume (100mL mark), if applicable:	Yes
	filled to volume (1 Liter mark)		Not Applicable
Subcontracting requir			No
RUSH turnaround tin			Yes
Requested Turnaroun			3 Business days
Samples delivered via			Hand Delivered
Air bill included if Sa			No
	meeting SATL sample accepta	nce criteria notated on CoC:	Notated on CoC, if any
Notes: * Samples delivered to	the laboratory on the same day th	nat they are collected may not meet therma	al preservation criteria (>0°C but <6°C)
Checked By:	Aimee Landon	Date: 06/08/23 10:06	SATL#F000 Revised 09/15/202
1610 S L	aredo Street, San Antonio,	Texas 78207-7029 (210) 229-99	20 Fax (210) 229-9921
1010 0. 17	are and per delly per i and and y	www.cotostinglah.com	Page 7 of