



TEST REPORT

No. : SHCCM150601630

Date : Jun. 03, 2015

Page: 1 of 2

PANELWAY (CHINA) LIMITED
DONGNANCUN, LAIZHOU, SHANDONG 261418, CHINA

The following sample(s) was/ were submitted and identified on behalf of the client as:

Sample Name : RAISED FLOOR PANEL/PEDESTAL/STEEL BLOCK
Sample Number : SHCCM150501285
Test Required : Concentrated load
Test Method : CISCA and client's requirement
Product or Lot No. : ST660-B/ST-3C150
Manufacturer : PANELWAY (CHINA) LIMITED
Date of Receipt : May. 12, 2015
Test Period : May. 12, 2015 to May. 20, 2015
Test result(s) : For further details, please refer to the following page(s)
***** To be continued*****

Signed for SGS-CSTC Standards
Technical Services (Shanghai) Co., Ltd.

Erin Huang
Authorized signatory



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.
Testing Center for Mechanical Testing and Calibration Laboratory

No.69, Block 1159, East Kang Qiao Road, Pudong District, Shanghai, China. 201319 t(86-21)61196300 f(86-21)61191853/68183920 www.sgsgroup.com.cn
中国·上海·浦东康桥东路1159弄69号 邮编:201319 t(86-21)61196300 f(86-21)61191853/68183920 e sgs.china@sgs.com

TEST REPORT

No. : SHCCM150601630

Date : Jun. 03, 2015

Page: 2 of 2

Test conducted: CISCA Recommended test procedures for access floors and client's requirement

Test results:

Test location	Bottom surface Deflection (mm)	Bottom surface Permanent set (mm)
At the centre of the panel	1.18	0.14
At the centre of edge of the panel	1.33	0.13
At the point along a diagonal 70 mm beyond the edge of the pedestal head on the panel	0.58	0.05

Remark:

- 1) The test load was 2950N required by client.
- 2) The test load was applied for one minute.

Statement: Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

Sample photos:



Panel



Pedestal

***** End of report *****



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-Client Standards Technical Services (Shanghai) Co., Ltd.
Testing Center for Client Standards Technical Laboratory

No.69, Block 1159, East Kang Qiao Road, Pudong District, Shanghai, China. 201319 t(86-21)61196300 f(86-21)61191853/68183920 www.sgsgroup.com.cn
中国·上海·浦东康桥东路1159弄69号 邮编:201319 t(86-21)61196300 f(86-21)61191853/68183920 e sgs.china@sgs.com