

CPO Facility Operations Calendar: Year-at-a-Glance with MAHC Alignment

- January
 - Task: Review SDS sheets
 - MAHC Reference: 5.7.3 – Chemical Handling & SDS
- February
 - Task: Inspect heaters & HVAC systems
 - MAHC Reference: 4.7.1 – HVAC Ventilation
- March
 - Task: Order new test reagents
 - MAHC Reference: 5.7.2 – Testing Supplies
- April
 - Task: Inspect VGB covers, ladders, and grates
 - MAHC Reference: 4.8.2 – Suction Fitting Compliance
- May
 - Task: Start daily log reviews
 - MAHC Reference: 5.7.1.1 – Water Quality Log
- June
 - Task: Mid-season equipment inspection
 - MAHC Reference: 4.10.1 – Circulation System Maintenance
- July
 - Task: Recheck cyanuric acid levels
 - MAHC Reference: 5.7.3.2 – Stabilizer Monitoring
- August
 - Task: Clean surge pit and skimmer wells
 - MAHC Reference: 4.10.4.1 – Surge Chamber Cleaning
- September
 - Task: Inspect pool lights and anchoring
 - MAHC Reference: 4.8.3.1 – Lighting & Electrical Safety
- October
 - Task: Winterize pumps and drain tanks
 - MAHC Reference: 4.10.5 – Seasonal Shutdown
- November
 - Task: Annual maintenance recap and report
 - MAHC Reference: 4.10.6 – Maintenance Records
- December
 - Task: Update emergency response plan and training calendar
 - MAHC Reference: 6.1.1 – Emergency Response Plan