

1456 Dupree Creek Road, Awardaw, SC 29466 Phone: 843-408-0126

Project Information

For: Best Builder
 123 Main Street, Charleston, SC

Design Conditions

Location:		Indoor:		Heating	Cooling
Charleston Intl AP, SC, US		Indoor temperature (°F)		70	75
Elevation: 49 ft		Design TD (°F)		40	17
Latitude: 33°N		Relative humidity (%)		50	50
Outdoor:	Heating	Cooling	Infiltration:		
Dry bulb (°F)	30	92	Method		Simplified
Daily range (°F)	-	16 (M)	Construction quality		Semi-tight
Wet bulb (°F)	-	78	Fireplaces		0
Wind speed (mph)	15.0	7.5			

Heating

Component	Btuh/ft²	Btuh	% of load
Walls	3.4	8103	38.4
Glazing	13.1	2737	13.0
Doors	0	0	0
Ceilings	2.0	1594	7.5
Floors	1.5	1177	5.6
Infiltration	2.2	5765	27.3
Ducts		1751	8.3
Piping		0	0
Humidification		0	0
Ventilation		0	0
Adjustments		0	0
Total		21126	100.0



Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	2.0	4809	34.1
Glazing	17.6	3691	26.1
Doors	0	0	0
Ceilings	1.3	1006	7.1
Floors	0.7	508	3.6
Infiltration	0.5	1315	9.3
Ducts		1197	8.5
Ventilation		0	0
Internal gains		1590	11.3
Blower		0	0
Adjustments		0	0
Total		14116	100.0



Latent Cooling Load = 3768 Btuh
 Overall U-value = 0.085 Btuh/ft²-°F, Window / Floor Area = 27.1 %
 WARNING: window to floor area ratio = 27.1% - more than 25%.

Page 1 is the Building Analysis summary page. This outlines the;

- 1 – project address which determines the location and design temperatures used for the HVAC system sizing
- 2 – Which Air Handler unit the analysis is associated with. If there are multiple Air Handler units, there will be a separate design analysis for each unit. The naming convention used would include; AH Entire House / AH 1st Floor / AH 2nd Floor / AH Master Suite ect,
- 3 - A summary of where the heating and cooling losses are coming from with a visual from a pie chart.



1456 Dupree Creek Road, Awardaw, SC 29466 Phone: 843-408-0126

Project Information

For: Best Builder
 123 Main Street, Charleston, SC

Design Conditions

Location:		Indoor:		Heating	Cooling
Charleston Intl AP, SC, US		Indoor temperature (°F)		70	75
Elevation: 49 ft		Design TD (°F)		40	17
Latitude: 33°N		Relative humidity (%)		50	50
		Moisture difference (gr/lb)		35.1	55.5
Outdoor:	Heating	Cooling	Infiltration:		
Dry bulb (°F)	30	92	Method		
Daily range (°F)	-	16 (M)	Simplified		
Wet bulb (°F)	-	78	Construction quality		
Wind speed (mph)	15.0	7.5	Fireplaces		
			Semi-tight		
			0		

Construction descriptions

	Or	Area	U-value	Insul R	Htg HTM	Loss	Cig HTM	Gain
		ft ²	Btu/h ² -F	ft ² -R/Btu	Btu/h ²	Btu	Btu/h ²	Btu
Walls								
12D-0sw: Fm wall, wd ext, 1/2" wood shth, r-15 cav ins, 1/2" gypsum								
	ne	469	0.086	15.0	3.41	1598	2.02	948
board int fnsh, 2"x6" wood frm, 16" o.c. stud								
	se	660	0.086	15.0	3.41	2247	2.02	1334
	sw	561	0.086	15.0	3.41	1911	2.02	1134
	nw	689	0.086	15.0	3.41	2347	2.02	1393
	all	2379	0.086	15.0	3.41	8103	2.02	4809

Partitions

(none)

Windows

Low E - 33 SHGC - 19: Double Pane Low E, U=0.33, SHGC=0.19; NFRC rated (SHGC=0.19); 6.67 ft head ht								
	ne	50	0.330	0	13.1	653	18.0	901
	se	20	0.330	0	13.1	261	19.6	392
	sw	90	0.330	0	13.1	1176	19.6	1764
	nw	10	0.330	0	13.1	131	18.0	180
	all	170	0.330	0	13.1	2222	19.0	3237
Low E - 33 SHGC - 19: Double Pane Low E, U=0.33, SHGC=0.19; NFRC rated (SHGC=0.19); 6 ft overhang (6.66 ft window ht, 2 ft sep.); 6.67 ft head ht								
	ne	20	0.330	0	13.1	261	12.6	252
Low E - 33 SHGC - 19: Double Pane Low E, U=0.33, SHGC=0.19; NFRC rated (SHGC=0.19); 50 ft overhang (6.66 ft window ht, 2 ft sep.); 6.67 ft head ht								
	se	19	0.330	0	13.1	254	6.68	130

Doors

(none)

Ceilings

18B-19al: Rt/cig ceiling, asphalt shingles roof mat, frm cons, 1/2" gypsum board int fnsh, 10" thkns, r-19 cell ins		789	0.051	19.0	2.02	1594	1.27	1006
---	--	-----	-------	------	------	------	------	------

Floors

19A-19cvhp: Fir floor, frm fir, 6" thkns, hrd wd fir fnsh, r-19 cav ins, leaky cowl ovr		774	0.049	19.0	1.52	1177	0.66	508
---	--	-----	-------	------	------	------	------	-----



Page 2 and sometimes 3 is the Component Construction summary page. This outlines the insulation and window values used for the HVAC system design. If there are multiple HVAC systems, then there would be a separate component construction page for each system.

Project Information

For: Best Builder
 123 Main Street, Charleston, SC

Notes: Any changes to the insulation levels or windows could have an impact on HVAC system sizing

Design Information

Weather: Charleston Intl AP, SC, US

Winter Design Conditions

Outside db 30 °F
 Inside db 70 °F
 Design TD 40 °F

Ventilation Method MJ8

Heating Summary

Structure 19375 Btuh
 Ducts (R-8.0) 1751 Btuh
 Central vent (0 cfm) 0 Btuh
 Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 21126 Btuh

Infiltration

Method Simplified
 Construction quality Semi-tight
 Fireplaces 0

	Heating	Cooling
Area (ft²)	774	774
Volume (ft³)	15008	15008
Air changes/hour	0.53	0.28
Equiv. AVF (cfm)	133	70

Heating Equipment Summary

Make
 Trade
 Model
 AHRI ref

Efficiency 80 AFUE
 Heating input 0 Btuh
 Heating output 0 Btuh
 Temperature rise 0 °F
 Actual air flow 638 cfm
 Air flow factor 0.030 cfm/Btuh
 Static pressure 0.50 in H2O
 Space thermostat

Summer Design Conditions

Outside db 92 °F
 Inside db 75 °F
 Design TD 17 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 55 gr/lb

Sensible Cooling Equipment Load Sizing

Structure 12919 Btuh
 Ducts (R-8.0) 1197 Btuh
 Central vent (0 cfm) 0 Btuh
 Blower 0 Btuh
 Use manufacturer's data n
 Rate/swing multiplier 0.97
 Equipment sensible load 13707 Btuh

Latent Cooling Equipment Load Sizing

Structure 3237 Btuh
 Ducts 531 Btuh
 Central vent (0 cfm) 0 Btuh
 Equipment latent load 3768 Btuh
Equipment Total Load (Sen+Lat) 17475 Btuh
 Req. total capacity at 0.75 SHR 1.5 ton

Cooling Equipment Summary

Make
 Trade
 Cond
 Coil
 AHRI ref
 Efficiency 0 SEER


Sensible cooling 0 Btuh
 Latent cooling 0 Btuh
 Total cooling 0 Btuh
 Actual air flow 638 cfm
 Air flow factor 0.045 cfm/Btuh
 Static pressure 0.50 in H2O
 Load sensible heat ratio 0.79

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

The Project Summary page provides the design heating and cooling load for the HVAC unit. This outlines the;

- 1 – The heating summary suggests the heating design load for the unit in Btu’s / Hour
- 2 – The Sensible Cooling load is the amount of cooling required to drop the temperature inside the house. The Latent Cooling load determines the cooling required to remove moisture from the air. These are both combined to determine the total equipment load required from the unit. The HVAC contractor will select a unit to meet both the heating and cooling load for this system

1



The Drawing summary provides a suggested duct layout with duct sizing to each of the supply and return registers. As in any construction, field modifications with routing of ducts may be necessary. If the home has multiple levels, then there will be a separate Drawing sheet for each floor. If the home has multiple HVAC systems or multiple Zoning, then this would be represented as a different color on the drawing.

1 – The compass highlights the as designed orientation for the home.