



Accredited Analytical Resources, LLC.

28 July 2021

AAR Work Order: 2001857

Carmen Melendez
THE PEACE ROSE LLC
3079 Bordentown Ave.
Parlin, NJ 08859

Project: Peace Rose Water Test

Enclosed are the results of analyses for samples received by the laboratory on 11/13/2020 13:45. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Daniel Miguel
Technical Director



New Jersey Certification Number: 12007
New York Certification Number: 11109

Pennsylvania Certification Number: 68-02799
CT Certification Number: PH-0219

This report shall not be reproduced, except in its entirety, without the written consent of Accredited Analytical Resources, LLC.
The test results included in this report relate only to the samples analyzed.



THE PEACE ROSE LLC
 3079 Bordentown Ave.
 Parlin NJ, 08859

Project: Peace Rose Water Test
 Project Manager: Carmen Melendez

Reported:
 07/28/2021 14:54

Analytical Report for Samples

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Field Blank	2001857-01	Aqueous	11/13/2020 11:27	11/13/2020 13:45
1 Infant Kitchen	2001857-02	Potable	11/13/2020 10:54	11/13/2020 13:45
2 Hall Fountain	2001857-03	Potable	11/13/2020 10:59	11/13/2020 13:45
3 Kitchen Sink	2001857-04	Potable	11/13/2020 11:24	11/13/2020 13:45
4 Gym (4)	2001857-05	Potable	11/13/2020 11:25	11/13/2020 13:45
5 Montessori Outdoor Fountain	2001857-06	Potable	11/13/2020 10:57	11/13/2020 13:45
6 Infant Sink	2001857-07	Potable	11/13/2020 10:56	11/13/2020 13:45
7 Pre-School A 2/3 #1	2001857-08	Potable	11/13/2020 11:06	11/13/2020 13:45
8 Pre-School A 2/3 #2	2001857-09	Potable	11/13/2020 11:07	11/13/2020 13:45
9 Pre-School B 5/6 #1	2001857-10	Potable	11/13/2020 11:09	11/13/2020 13:45
10 Pre-School B 5/6 #2	2001857-11	Potable	11/13/2020 11:10	11/13/2020 13:45
11 Montessori Sink #1	2001857-12	Potable	11/13/2020 11:13	11/13/2020 13:45
12 Montessori Sink #2	2001857-13	Potable	11/13/2020 11:14	11/13/2020 13:45
13 Art	2001857-14	Potable	11/13/2020 11:03	11/13/2020 13:45

Notes and Definitions

* Values outside of QC limits

ND - Indicates compound analyzed for but not detected at or above the MDL

J - Indicates estimated value for TICs and all results when detected below the RL

B - Indicates compound found in associated blank

E - Concentration exceeds highest calibration standard

D - Indicates result is based on a dilution

P - Greater than 25% diff. between 2 GC columns.

MDL - Minimum detection limit

RL - Reporting limit

NFL - No Free Liquids

VC - The container(s) provided by the client for soil volatiles do not meet the requirements of EPA SW846-5035A. Results reported below 200 ug/kg may be biased low due to samples not being collected according to EPA SW846 5035A requirements.

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC
3079 Bordentown Ave.
Parlin NJ, 08859

Project: Peace Rose Water Test
Project Manager: Carmen Melendez

Reported:
07/28/2021 14:54

Methodology Summary

Total Metals by EPA 200 Series Methods:

EPA 200.5
EPA 200.7A

Condition of Samples on Receipt

Temperature °C	4.00
Chain of Custody Filled Out Properly	Yes
Received with Proper Containers	Yes
Received with Proper Volumes	Yes
Received Within Holding Time	Yes
Samples Received with Correct Preservation	Yes
Samples Received On Ice	Yes
Sample Received Via Field Services	No
Samples Hand Delivered	Yes

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC
 3079 Bordentown Ave.
 Parlin NJ, 08859

Project: Peace Rose Water Test
 Project Manager: Carmen Melendez

Reported:
 07/28/2021 14:54

Client ID: Field Blank
Lab ID: 2001857-01 (Aqueous)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	ND	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 14:27/LIT	EPA 200.5	
-----------	------	----	------	------	------	-----	----------------	--------------------	-----------	--

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	ND	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 15:00/LIT	EPA 200.7	
-----------	--------	----	-------	------	------	-----	----------------	--------------------	-----------	--

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC
 3079 Bordentown Ave.
 Parlin NJ, 08859

Project: Peace Rose Water Test
 Project Manager: Carmen Melendez

Reported:
 07/28/2021 14:54

Client ID: 1 Infant Kitchen
Lab ID: 2001857-02 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	ND	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 13:53/LIT	EPA 200.5	
-----------	------	----	------	------	------	-----	----------------	--------------------	-----------	--

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	138	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 15:06/LIT	EPA 200.7	D
-----------	---------------	------------	-------	------	------	-----	----------------	--------------------	-----------	---

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC
 3079 Bordentown Ave.
 Parlin NJ, 08859

Project: Peace Rose Water Test
 Project Manager: Carmen Melendez

Reported:
 07/28/2021 14:54

Client ID: 2 Hall Fountain
Lab ID: 2001857-03 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	ND	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 14:34/LIT	EPA 200.5	
-----------	------	----	------	------	------	-----	----------------	--------------------	-----------	--

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	684	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 15:11/LIT	EPA 200.7	D
-----------	---------------	------------	-------	------	------	-----	----------------	--------------------	-----------	---

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC
 3079 Bordentown Ave.
 Parlin NJ, 08859

Project: Peace Rose Water Test
 Project Manager: Carmen Melendez

Reported:
 07/28/2021 14:54

Client ID: 3 Kitchen Sink
Lab ID: 2001857-04 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	ND	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 14:42/LIT	EPA 200.5	
-----------	------	----	------	------	------	-----	----------------	--------------------	-----------	--

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	211	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 15:26/LIT	EPA 200.7	D
-----------	---------------	------------	-------	------	------	-----	----------------	--------------------	-----------	---

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC 3079 Bordentown Ave. Parlin NJ, 08859	Project: Peace Rose Water Test Project Manager: Carmen Melendez	Reported: 07/28/2021 14:54
--	--	--------------------------------------

Client ID: 4 Gym (4)
Lab ID: 2001857-05 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	ND	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 15:04/LIT	EPA 200.5	
-----------	------	----	------	------	------	-----	----------------	--------------------	-----------	--

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	249	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 15:31/LIT	EPA 200.7	D
-----------	---------------	------------	-------	------	------	-----	----------------	--------------------	-----------	---

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC 3079 Bordentown Ave. Parlin NJ, 08859	Project: Peace Rose Water Test Project Manager: Carmen Melendez	Reported: 07/28/2021 14:54
--	--	--------------------------------------

Client ID: 5 Montessori Outdoor Fountain
Lab ID: 2001857-06 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	7.43	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 15:12/LIT	EPA 200.5	D
-----------	-------------	-------------	------	------	------	-----	----------------	--------------------	-----------	---

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	163	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 15:36/LIT	EPA 200.7	D
-----------	---------------	------------	-------	------	------	-----	----------------	--------------------	-----------	---

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC
 3079 Bordentown Ave.
 Parlin NJ, 08859

Project: Peace Rose Water Test
 Project Manager: Carmen Melendez

Reported:
 07/28/2021 14:54

Client ID: 6 Infant Sink
Lab ID: 2001857-07 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	ND	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 15:19/LIT	EPA 200.5	
-----------	------	----	------	------	------	-----	----------------	--------------------	-----------	--

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	199	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 15:41/LIT	EPA 200.7	D
-----------	---------------	------------	-------	------	------	-----	----------------	--------------------	-----------	---

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC 3079 Bordentown Ave. Parlin NJ, 08859	Project: Peace Rose Water Test Project Manager: Carmen Melendez	Reported: 07/28/2021 14:54
--	--	--------------------------------------

Client ID: 7 Pre-School A 2/3 #1
Lab ID: 2001857-08 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	ND	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 15:27/LIT	EPA 200.5	
-----------	------	----	------	------	------	-----	----------------	--------------------	-----------	--

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	115	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 15:47/LIT	EPA 200.7	D
-----------	---------------	------------	-------	------	------	-----	----------------	--------------------	-----------	---

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC
 3079 Bordentown Ave.
 Parlin NJ, 08859

Project: Peace Rose Water Test
 Project Manager: Carmen Melendez

Reported:
 07/28/2021 14:54

Client ID: 8 Pre-School A 2/3 #2
Lab ID: 2001857-09 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	ND	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 15:34/LIT	EPA 200.5	
-----------	------	----	------	------	------	-----	----------------	--------------------	-----------	--

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	164	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 15:52/LIT	EPA 200.7	D
-----------	---------------	------------	-------	------	------	-----	----------------	--------------------	-----------	---

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC
 3079 Bordentown Ave.
 Parlin NJ, 08859

Project: Peace Rose Water Test
 Project Manager: Carmen Melendez

Reported:
 07/28/2021 14:54

Client ID: 9 Pre-School B 5/6 #1
Lab ID: 2001857-10 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	ND	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 15:42/LIT	EPA 200.5	
-----------	------	----	------	------	------	-----	----------------	--------------------	-----------	--

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	82.8	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 15:57/LIT	EPA 200.7	D
-----------	---------------	-------------	-------	------	------	-----	----------------	--------------------	-----------	---

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC
 3079 Bordentown Ave.
 Parlin NJ, 08859

Project: Peace Rose Water Test
 Project Manager: Carmen Melendez

Reported:
 07/28/2021 14:54

Client ID: 10 Pre-School B 5/6 #2
Lab ID: 2001857-11 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	5.32	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 15:49/LIT	EPA 200.5	D
-----------	-------------	-------------	------	------	------	-----	----------------	--------------------	-----------	---

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	150	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 16:02/LIT	EPA 200.7	D
-----------	---------------	------------	-------	------	------	-----	----------------	--------------------	-----------	---

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC
 3079 Bordentown Ave.
 Parlin NJ, 08859

Project: Peace Rose Water Test
 Project Manager: Carmen Melendez

Reported:
 07/28/2021 14:54

Client ID: 11 Montessori Sink #1
Lab ID: 2001857-12 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	ND	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 15:57/LIT	EPA 200.5
-----------	------	----	------	------	------	-----	----------------	--------------------	-----------

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	ND	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 16:08/LIT	EPA 200.7
-----------	--------	----	-------	------	------	-----	----------------	--------------------	-----------

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC
 3079 Bordentown Ave.
 Parlin NJ, 08859

Project: Peace Rose Water Test
 Project Manager: Carmen Melendez

Reported:
 07/28/2021 14:54

Client ID: 12 Montessori Sink #2
Lab ID: 2001857-13 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	ND	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 16:04/LIT	EPA 200.5	
-----------	------	----	------	------	------	-----	----------------	--------------------	-----------	--

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	96.7	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 16:17/LIT	EPA 200.7	D
-----------	---------------	-------------	-------	------	------	-----	----------------	--------------------	-----------	---

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



THE PEACE ROSE LLC
 3079 Bordentown Ave.
 Parlin NJ, 08859

Project: Peace Rose Water Test
 Project Manager: Carmen Melendez

Reported:
 07/28/2021 14:54

Client ID: 13 Art

Lab ID: 2001857-14 (Potable)

CAS #	Analyte	Result	MDL	RL	Units	Dilution	Prepared Date	Analyzed Date/By	Method	Notes
-------	---------	--------	-----	----	-------	----------	---------------	------------------	--------	-------

Accredited Analytical Resources LLC

Total Metals by EPA 200 Series Methods

Sample Prepared by Method:EPA 200.5

7439-92-1	Lead	ND	1.99	2.50	ug/L	0.5	11/16/20 08:16	11/17/20 16:12/LIT	EPA 200.5	
-----------	------	----	------	------	------	-----	----------------	--------------------	-----------	--

Sample Prepared by Method:EPA 200.7

7440-50-8	Copper	253	0.428	4.00	ug/L	0.5	11/16/20 08:45	11/17/20 14:40/LIT	EPA 200.7	D
-----------	---------------	------------	-------	------	------	-----	----------------	--------------------	-----------	---

Accredited Analytical Resources LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Daniel Miguel, Technical Director



20 PERSHING AVE, CARTERET, NJ 07008
 Tel. 732-969-6112 FAX 732-541-1383
 WEB: WWW.ACCREDITEDANALYTICAL.COM

CHAIN OF CUSTODY FORM

CLIENT NAME: The Peace Rose LLC
 ADDRESS: 3079 Bordertown Ave
 CITY: Parlin
 STATE: NJ ZIP: 08859

STATE AGENCY (CIRCLE ONE): (N) NY PA
 PROJECT NAME: Peace Rose Water Test
 CONTACT: Carmen Melendez
 OFFICE PHONE #: 646 825 1330
 OFFICE FAX #:
 INITIAL RESULTS TO: (same)
 EMAIL FOR INVOICE: carmen@thepeacrose.com

AAR QUOTE #
 AAR WORK ORDER # 2001857
 P.O. #

ANALYSIS
 PRES. CODE → 20
 CONT. CODE → P

COLLECTION INFORMATION

CUSTOMER SAMPLE # / ID	DATE / TIME SAMPLED	MATRIX CODE	DEPTH	# OF CONTAINERS	GRAB (G) COMP (C)	AAR SAMPLE #
<u>10 Preschool B Site #2</u>	<u>11/13/20 11:10a</u>				<u>✓</u>	<u>-11</u>
<u>11 Montessori Sink #1</u>	<u>11/13 11:13a</u>				<u>✓</u>	<u>-12</u>
<u>12 Montessori Sink #2</u>	<u>11/13 11:14a</u>				<u>✓</u>	<u>-13</u>
<u>13 Art</u>	<u>11/13 11:03a</u>				<u>✓</u>	<u>-14</u>

MATRIX CODES: S = SOIL A = AQUEOUS GW = GROUND WATER WW = WASTE WATER SW = SURFACE WATER P = POTABLE WATER O = OIL K = SOLID X = OTHER

CONTAINER TYPE CODES: G = GLASS P = PLASTIC E = ENCORE PRESERVATIVES CODES: 1 = HCL 2 = HNO₃ 3 = H₂SO₄ 4 = NaOH 5 = OTHER

TURNAROUND TIME: (CIRCLE ONE) STANDARD 5 DAY 72 HRS. 48 HRS. 24 HRS. OTHER
 (IF BLANK STANDARD WILL APPLY)

REPORT TYPE: RESULTS ONLY ✓ REDUCED FULL EDD EXCEL SPREADSHEET

COMMENTS: to Pres. upon receipt in lab 11/13/20 COOLER TEMP: 40C

PERSON(S) ASSUMING RESPONSIBILITY FOR SAMPLING: PRINT: Carmen Melendez SIGN: [Signature]

SIGN BELOW WHEN DELIVERING SAMPLES. EACH TIME SAMPLES CHANGE POSSESSION, INCLUDING COURIER DELIVERY, CUSTODY MUST BE DOCUMENTED.

RELINQUISHED BY: Print Name: <u>Carmen Melendez</u> Signature: <u>[Signature]</u> Agent of:	RECEIVED BY: Print Name: <u>D Miguel</u> Signature: <u>[Signature]</u> Agent of: <u>AAR</u> Date Received: <u>11/13/20</u> Time: <u>13:45</u>	RELINQUISHED BY:	RECEIVED BY:
RELINQUISHED BY:	RECEIVED BY:	RELINQUISHED BY:	RECEIVED BY: