



New Jersey Department of Health
Environmental and Chemical Laboratory Services
PO Box 361, Trenton, NJ 08625-0361
NJDEP Lab ID#: 11036
EPA Lab ID#: NJ01351

Client Address:
The Peace Rose Montessori School
3079 Bordentown Avenue
Parlin NJ, 8859

Report Date: 01/24/2025 13:47
Project: NJDCF Childcare Drinking Water

Client Sample ID: **Room 1 Big Sink**
Sample Location:
Field ID No: Room 1 Big Sink
Sample Type: First Draw

Lab Number: 24L0403-01
Sampled: 12/4/2024 7:12:00AM
Received: 12/5/2024 11:10:40AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	124		0.158	0.500	ug/L	01/22/2025	01/23/2025 13:55	EPA 200.8
Lead	0.131	JR	0.075	1.00	ug/L	01/22/2025	01/23/2025 13:55	EPA 200.8

NJDOH PHEL

Dave Riker, Organic Testing Laboratory Supervisor

Doug Haltmeier, Inorganic Testing Laboratory Supervisor

New Jersey Department of Health

Client Sample ID: **Room 1A**
 Sample Location:
 Field ID No: Room 1A
 Sample Type: First Draw

Lab Number: 24L0403-02
 Sampled: 12/4/2024 7:13:00AM
 Received: 12/5/2024 11:10:40AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	164		0.158	0.500	ug/L	01/22/2025	01/23/2025 13:59	EPA 200.8
Lead	1.42		0.075	1.00	ug/L	01/22/2025	01/23/2025 13:59	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

New Jersey Department of Health

Client Sample ID: **Room 2 Left Sink**
 Sample Location:
 Field ID No: Room 2 Left Sink
 Sample Type: First Draw


Lab Number: 24L0403-03
 Sampled: 12/4/2024 7:15:00AM
 Received: 12/5/2024 11:10:40AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	151		0.158	0.500	ug/L	01/22/2025	01/23/2025 14:03	EPA 200.8
Lead	0.200	JR	0.075	1.00	ug/L	01/22/2025	01/23/2025 14:03	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

New Jersey Department of Health

Client Sample ID: **Room 2 Middle Sink**
 Sample Location:
 Field ID No: Room 2 Middle Sink
 Sample Type: First Draw


Lab Number: 24L0403-04
 Sampled: 12/4/2024 7:16:00AM
 Received: 12/5/2024 11:10:40AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	186		0.158	0.500	ug/L	01/22/2025	01/23/2025 14:20	EPA 200.8
Lead	0.186	JR	0.075	1.00	ug/L	01/22/2025	01/23/2025 14:20	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

New Jersey Department of Health

Client Sample ID: **Room 3 Left Sink**
Sample Location:
Field ID No: Room 3 Left Sink
Sample Type: First Draw


Lab Number: 24L0403-05
Sampled: 12/4/2024 7:23:00AM
Received: 12/5/2024 11:10:40AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	236		0.158	0.500	ug/L	01/22/2025	01/23/2025 14:25	EPA 200.8
Lead	0.146	JR	0.075	1.00	ug/L	01/22/2025	01/23/2025 14:25	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

New Jersey Department of Health

Client Sample ID: **Room 4 Right Sink**
 Sample Location:
 Field ID No: Room 4 Right Sink
 Sample Type: First Draw


Lab Number: 24L0403-06
 Sampled: 12/4/2024 7:27:00AM
 Received: 12/5/2024 11:10:40AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	152		0.158	0.500	ug/L	01/22/2025	01/23/2025 14:29	EPA 200.8
Lead	0.159	JR	0.075	1.00	ug/L	01/22/2025	01/23/2025 14:29	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

New Jersey Department of Health

Client Sample ID: **Room 4 Middle Sink**
 Sample Location:
 Field ID No: Room 4 Middle Sink
 Sample Type: First Draw


Lab Number: 24L0403-07
 Sampled: 12/4/2024 7:28:00AM
 Received: 12/5/2024 11:10:40AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	222		0.158	0.500	ug/L	01/22/2025	01/23/2025 14:33	EPA 200.8
Lead	0.191	JR	0.075	1.00	ug/L	01/22/2025	01/23/2025 14:33	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

New Jersey Department of Health

Client Sample ID: **Room 5 Left Sink**
 Sample Location:
 Field ID No: Room 5 Left Sink
 Sample Type: First Draw


Lab Number: 24L0403-08
 Sampled: 12/4/2024 7:30:00AM
 Received: 12/5/2024 11:10:40AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	154		0.158	0.500	ug/L	01/22/2025	01/23/2025 14:37	EPA 200.8
Lead	0.418	JR	0.075	1.00	ug/L	01/22/2025	01/23/2025 14:37	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor




Doug Haltmeier, Inorganic Testing Laboratory Supervisor


Client Sample ID: **Kitchen**
Sample Location:
Field ID No: Kitchen
Sample Type: First Draw

Lab Number: 24L0403-09
Sampled: 12/4/2024 7:25:00AM
Received: 12/5/2024 11:10:40AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	152		0.158	0.500	ug/L	01/22/2025	01/23/2025 14:42	EPA 200.8
Lead	0.139	JR	0.075	1.00	ug/L	01/22/2025	01/23/2025 14:42	EPA 200.8

NJDOH PHEL


Dave Riker, Organic Testing Laboratory Supervisor


Doug Haltmeier, Inorganic Testing Laboratory Supervisor

New Jersey Department of Health

Client Sample ID: **Staff Bathroom**
 Sample Location:
 Field ID No: Staff Bathroom
 Sample Type: First Draw

Lab Number: 24L0403-11
 Sampled: 12/4/2024 7:18:00AM
 Received: 12/5/2024 11:10:40AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	198		0.158	0.500	ug/L	01/22/2025	01/23/2025 14:50	EPA 200.8
Lead	3.41		0.075	1.00	ug/L	01/22/2025	01/23/2025 14:50	EPA 200.8

Notes and definitions:


J Approximate Value
 JR Approximate value. Result is below the reporting level but greater than the method detection limit.

Case Narrative Section:

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor



Retest

New Jersey Department of Health
Environmental and Chemical Laboratory Services
PO Box 361, Trenton, NJ 08625-0361
NJDEP Lab ID#: 11036
EPA Lab ID#: NJ01351

Client Address:
The Peace Rose Montessori School
3079 Bordentown Avenue
Parlin NJ, 8859

Report Date: 03/26/2025 12:37
Project: NJDCF Childcare Drinking Water

Client Sample ID: **Fountain**
Sample Location:
Field ID No: Fountain
Sample Type: First Draw

Lab Number: 25C0605-01
Sampled: 3/5/2025 7:02:00AM
Received: 3/6/2025 11:05:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	278		0.158	0.500	ug/L	03/25/2025	03/25/2025 17:31	EPA 200.8
Lead	0.141	JR	0.075	1.00	ug/L	03/25/2025	03/25/2025 17:31	EPA 200.8

Notes and definitions:

J Approximate Value
JR Approximate value. Result is below the reporting level but greater than the method detection limit.

Case Narrative Section:

NJDOH PHEL

Dave Riker, Organic Testing Laboratory Supervisor

Doug Haltmeier, Inorganic Testing Laboratory Supervisor