

OPERATIONS REPORT – Burlington Junction

June 2021

City of Burlington
Junction

Phone-660-725-
4514

Mayor Dean Kelly
660-725-4514

Forman-Scott
Conn-660-725-
7333

Utility1- Skyeler
Rohlmeier-660-
582-0836

Sectary/Clerk
Melissa Cook
660-725-4514

Office Hours
Mon-Fri
8am-12pm

Water Treatment

- Water treatment system is running well.
- Iron and Manganese readings are consistantly low.
- Plants running average of 12 hours a day.

Distribution System

- No issue
- All water meters read
- Several meters need replaced waiting on meter rings

Wastewater / Sewer

- No Flow
- Got 2 out the 3 main valves working
- Teleconfrence with DNR July 27th 1pm

Montly Training

-

Streets/Parks

- Waiting for asphalt
- Mowing
- Mower Bids

Regulatory

- Bacteriological samples were taken and submitted.
- Results were coliform absent, all samples considered safe.

Concerns for the Month

- Lagoon project

Positives for the Month

- Water Treatment facility is operating very well.
- Valves working at lagoon

WATER QUALITY SAMPLING SUMMARY

Bacteriological	ROUTINE	SPECIAL	REPLACEMENT	REPEAT
Samples	5	0	0	0

Free Chlorine	MONTHLYAVG.	MAXIMUM	MINIMUM
	mg/l	2.91	1.00

OPERATIONS REPORT – Burlington Junction

TOTAL METERS	TOTAL ACTIVE READS	% COMPLETED	REREADS	ESTIMATES
266	245	100	0	

MASTER METER

DESCRIPTION	Report Period May 2021		
METERED GALLONS PRODUCED	958876		
METERED GALLONS SOLD	820567		
DIFFERENCE (GALLONS)	138309		
WATER LOSS FOR FLUSHING (GALLONS)	50000		
WATER LOSS FOR BREAKS/FIRE (GALLONS)	3000		
PLANT USAGE	4500		
NET UNACCOUNTED WATER LOSS (GALLONS)	70809		
NET UNACCOUNTED WATER LOSS (%)	7.38%		