

OPERATIONS REPORT – Burlington Junction

February 2021

City of Burlington
Junction

Phone-660-725-
4514

Mayor Dean Kelly
660-725-4514

Forman-Scott
Conn-660-725-
7333

Utility1- Skyeler
Rohlmeier-660-
582-0836

Sectary/Clerk
Melissa Cook
660-725-4514

Office Hours
Mon-Fri
8am-12pm

Water Treatment

- Water treatment system is running well.
- Iron and Manganese readings are consistantly low.
- Plants running average of 5 hours a day.
- Regenerated both filters
- Skyeler will be taking a class in March for his water license instead of going to Kansas City DNR reginal office

Distribution System

- No issue
- Water meters were read

Wastewater / Sewer

- No sewer or lagoon issues.
- Samples drawn and taken to White Cloud 1/5/21
- Working on more info bout grant .

Montly Training

- Trenching and excavation/Distribution system

Streets/Parks

- Bladed snow

Regulatory

- Bacteriological samples were taken and submitted.
- Results were coliform absent, all samples considered safe.

Concerns for the Month

- Keeping looking at options for waterplant refinaceing
- Keep looking into option on lagoon

Positives for the Month

- Water Treatment facility is operating very well.

WATER QUALITY SAMPLING SUMMARY