



ArcelorMittal

**VANDERBIJLPARK RELIABILITY
ENGINEERING**

Danie JD Steyn

Reliability Engineering

Manager ArcelorMittal South

Africa – Vanderbijlpark

Works: Delfos Boulevard Vanderbijlpark

Phone 016 889 9111

Email: Danie.Steyn@arcelormittal.com

California Environmental Protection Agency
 **Air Resources Board**

Tested & Documented



ArcelorMittal

Single Engine Fuel Economy Test under operational condition at ArcelorMittal South Africa – Vanderbijlpark

Test Engine:

Caterpillar Loco Engine No. 64

Test Period:

09/16/2017 – 12/16/2017

Location:

ArcelorMittal South Africa – Vanderbijlpark

Reliability Engineering Department

Goal:

**To establish confirmation of improved fuel economy
with**

**Omstar Dx1 Synthetic Ester
added to the Engine Oil and Fuel**



Omstar DX1

Loco 64

| | # | Task | Responsible Person |
|--------------|----|-----------------------------------|------------------------|
| Baseline | 1 | Weekly Samples | From COAST |
| | 2 | Fuel Consumed in Past 2 Weeks | From Mark |
| | 3 | Mileage/Hours in Past 2 Weeks | From Mark |
| Conditioning | 4 | Additive to Oil During Oil Change | Scheduled Service Date |
| | 5 | Additive to Fuel* | |
| | 6 | Note Fuel Consumed | |
| | 7 | Note Mileage and Hours | |
| Additive | 8 | Additive to fuel (Lower Ratio)* | |
| | 14 | Fuel Consumed in 2 Weeks | |
| | 15 | Mileage in 2 Weeks | |
| Report | 17 | Comparison | |
| | | Fuel and Mileage | |
| | | Vibration | |
| | | Sample test (Blot and Particle) | |

2 Week Running time

2 Week Running Time

* Additive also to be inserted into fuel at every refueling.

* Additive also to be inserted into fuel at every refueling.

| Mixing Ratios | | | |
|----------------|------|------------|------|
| First Time Use | | Sustaining | |
| Oil | | Oil | |
| DX1 | Oil | None | |
| 1 | 5 | | |
| Fuel | | Fuel | |
| DX1 | Fuel | DX1 | Fuel |
| 1 | 256 | 1 | 1280 |



OMSTAR
 ENVIRONMENTAL PRODUCTS DX1
 D-1280X, INC.




Oil contamination Test Nitrification Level



Sample Number: 362824
 Customer: Loco Shop
 Site: Loco
 Machine: LOCO NO.64
 Unit: Engine

Test value versus Sample Date

- NIT / Nitration Level
- NIT / Nitration Trendline
- NIT Max Limit
- NIT Min Limit





OMSTAR
 ENVIRONMENTAL PRODUCTS DX1
 D-1280X, INC.




Oil contamination Test Chromium Level



Sample Number: 362824
 Customer: Loco Shop
 Site: Loco
 Machine: LOCO NO.64
 Unit: Engine

- Cr / Chromium Level
- Cr / Chromium Trendline
- Cr Max Limit
- Cr Min Limit

Test value versus Sample Date



Omstar Dx1

No Chromium particles detected in the oil

