



Driver Leasing, Inc.  
2801 Loop 335 N  
Amarillo, TX 79108  
Phone 806-353-3990

TO David Grotegut  
Craig Cooper

In our investigation of water quality and quantity on the land parcel for the development of residential housing for David Grotegut and Craig Cooper, we found a sufficient result on the constructed test well. Driver performed an eight-hour pump test that drew the water level down to 32' above the pump. The rate at which this was conducted was 12 GPM.

Brice Graham  
806-654-1556  
Head Driller and Pump Installer