



Hocker Incorporated
13402 Weiman Road Houston, TX 77041
713-464-5829 Fax 713-464-3192

**ASTM E317-16 Performance Evaluation
Ultrasonic Flaw Detector**

Customer PO #:	86832
Certification #:	24-1357
Calibration Date:	10/7/2024

F-UTFL Rev-0

Meets ASTM E317-16 Minimum Requirements?


YES

Due Date:


10/7/2025

Company:	P & B Testing				Equipment Model & Serial #	Sonatest MS 333 S/N: 3401542C		Equipment Condition As Found:	
Address:	6645 W.TIDWELL								
City:	Houston		Contact:	Buck Snider		Lab Conditions:			New
State:	Texas		Phone:	(713)290-8490		Temp:	70°F	X	Good
Zip:	77092		Email:	QA@pbtesting.com		Hum. %:	50%		Poor
Country:	USA								
Performance Evaluation Equipment:				Serial:	NIST:	Cert. Blocks C to G:		Serial:	NIST:
Calib. Block A		ASTM-E317 Block		SN 03-8399	03-19698-A	ASTM E127 1-0300		SN 15-8035	14-20265-A
Calib. Block B		ASTM Type RA		SN 04-5671	04-25714-A	ASTM E127 2-0300		SN 15-8036	14-21740-A
Transducer "A"		FCHR-5050 Hi Res		SN 931/37	n/a	ASTM E127 3-0300		SN 15-8037	
Transducer "B"		PSLM-5050 5mhz 1/2"		SN 504/03	n/a	ASTM E127 4-0300		SN 15-8038	
Transducer "C"		PSLM-5050 5mhz 1/2"		SN 424/20	n/a	ASTM E127 5-0300		SN 15-8039	
Calibrated Attenuator		S/N: SO383925		NIST #:	1821-1022/1109579/9000-1439,1230,1336_Q1664				
Horizontal Limit Linearity				Vertical Limit Linearity					
Horiz. Accuracy Limit + or -		2.0%		Verticle Accuracy Limit + or -				2.0%	
Meets Accuracy Required?		Yes		Meets Accuracy Required?				Yes	
Horiz. Accuracy Deviation		0.0%		Vert. Accuracy Deviation				-1.0%	
Horiz. Screen Width used?		10"		Equipment Overall Pass/ Fail Result:				Pass	
% Horiz. Screen Width				% Vertical Screen Height					
Echo #	Actual %	Ideal	Deviation	Ideal %	Actual %	Ideal%	Actual%	Ideal%	Actual%
1	0.0%	0.0%	0.0%	+1db steps		-2db steps		-4db Steps	
2	10.0%	10.0%	0.0%	50.0%	50.0%	50.0%	50.0%	16.0%	15.0%
3	20.0%	20.0%	0.0%	56.0%	56.0%	40.0%	40.0%	10.0%	9.0%
4	30.0%	30.0%	0.0%	63.0%	63.0%	31.0%	32.0%	6.0%	5.0%
5	40.0%	40.0%	0.0%	71.0%	72.0%	25.0%	25.0%	5.0%	4.0%
6	50.0%	50.0%	0.0%	79.0%	80.0%	20.0%	20.0%	3.0%	2.0%
7	60.0%	60.0%	0.0%	89.0%	90.0%	16.0%	15.0%	2.0%	1.0%
8	70.0%	70.0%	0.0%	100.0%	100.0%				
9	80.0%	80.0%	0.0%	Maximum Vertical Deviation				-1.0%	
10	90.0%	90.0%	0.0%						
11	100.0%	100.0%	0.0%	Sensitivity & Noise					
Maximum Horizontal Deviation				0.0%	Test Block Number	Sig. Ampl.	Break Pt.	Noise Lvl.	Hole Size
Accuracy Of Calibrated Gain Controls					ASTM E127 1-0300	60.0%	15.0%	1.0%	1/64
Ideal	Actual	Ideal	Actual		ASTM E127 2-0300	60.0%	16.0%	1.0%	1/32
1	1	10	10		ASTM E127 3-0300	60.0%	17.0%	1.0%	3/64
2	2	12	12		ASTM E127 4-0300	60.0%	17.0%	1.0%	1/16
4	4	14	14		ASTM E127 5-0300	60.0%	18.0%	1.0%	5/64
6	6	20	20	Gain Control Deviation DB				0	
Near Surface Resolution at 80%				Far Surface Resolution at 80%					
Depth	Break Pt.	Noise %	Depth	Break Pt.	Noise %	Max Noise Level (Sensitivity & Noise Test)		1.0%	
0.7"	18.0%	1.0%	.01"	18.0%	1.0%				
0.5"	18.0%	1.0%	.02"	10.0%	1.0%	Max Noise Level (Resolution Test)		1.0%	
0.3"	15.0%	1.0%	.03"	10.0%	1.0%				

Horizontal Linearity As Received!



Vertical Linearity As Received!



Notes:

This performance evaluation was done in accordance with ASTM-E317-16 and Hocker Incorporated procedure CP-UTFL Rev 0. Test equipment and calibration blocks used to perform this evaluation are traceable to the National Institute of Standards and Technology. NIST numbers listed in this document and supporting documentation is on file. This performance evaluation is made in conformance with ANSI/NCSL 2540.3-2006 and/or ISO 10012, and with 10CFR21.

Technician Signature:

F-UTFL Rev-0 05/01/2018

Technician Performing Evaluation: Roger Kimmons

Date: 10/7/2024

Approval Signature:

Approved By: Derrick Schumann

Buck Snider