

# Comparison of the Two Methods

| Selection Criterion                              | CSA A23.2-8B                                                    | CSA A23.2-3B                                                                   |
|--------------------------------------------------|-----------------------------------------------------------------|--------------------------------------------------------------------------------|
| Primary focus                                    | Water-soluble sulphates in construction materials               | Sulphate conditions affecting concrete durability                              |
| Typical materials                                | Aggregates, recycled aggregates, granular materials             | Soils, aggregates, fills and materials surrounding concrete                    |
| Main reported parameter                          | Water-soluble sulphate content                                  | Sulphate content for durability and exposure assessment                        |
| Typical purpose                                  | Material qualification and quality control                      | Concrete durability and exposure evaluation                                    |
| Common projects                                  | Aggregate qualification, recycled materials, acceptance testing | Foundations, infrastructure, durability studies, sulfate attack investigations |
| Suitable for recycled crushed-concrete aggregate | Yes                                                             | Possible, but generally not the primary application                            |
| Suitable for concrete exposure assessment        | Limited                                                         | Yes                                                                            |
| Main engineering question                        | Does the material contain elevated levels of soluble sulphates? | Could sulphate conditions affect the durability of concrete?                   |