



**STRAND**  
ASSOCIATES®

Excellence in Engineering Since 1946

# Case Studies in Finding the Biological Sweet Spot

OTCO Class III & IV Workshop July 26, 2018

Kevin R. Earnest, PE (OH, IN)

# Goals


- Share training and workshops designed to develop adequate monitoring plans
- Review of databases and spreadsheet tools that can assist in turning the data into information
- Development of unique protocols to meet site specific needs

# Case Studies

- Utilizing SCADA and Database Tools
- Example: Bensenville, IL – Startup Training
- Example: Waterloo, IA – Data to Information
- Other Operational Conversations (as time allows)

# SCADA Basics

- What does SCADA mean?
  - Supervisory
  - Control
  - And
  - Data
  - Acquisition



Smash  
Computers to  
Avoid  
Disasters  
After-hours

# SCADA Basics

- How large/small can a SCADA System be?
  - Single pump station and master computer
  - Wastewater Treatment Plant
  - Regional water/wastewater systems

# Reporting Basics

- What does a Reporting System do?

Collect Data

Report Data

Trend Data




# Reporting Basics

- What can a Reporting System be used for?
  - Long-term data storage
  - Operator logs/entry
  - OEPA-required reports
  - Lab analysis
    - Data manager
    - QA/QC
  - Billing
  - Process optimization and troubleshooting
  - Future planning/trends

# Optimizing Your Reporting Program

- Planning, Communication, and Teamwork are Necessary to Develop a Relevant - User Friendly System.




# Optimizing Your Reporting Program


Apples  
Apples  
Apples


IT needs to be  
comprehensive

I Agree

Oranges  
Oranges  
Oranges







Some of the data is entered manually. Entry pages can range from simple monthly forms to more complicated custom forms. The custom forms can take raw data such as weights and volumes and calculate data such as concentrations.

# Data Entry

The "Calc" should be selected to inform Ops to perform the various calculations.

Date  
(Cursor)

	Daily Com	Daily Pumping Totals (1,000 Gal)	Unmetered Water Use Date	Unmetered Water Location	Unmetered Water Use	Less: Other utility use (1,000 Gals)	Less: Water sold (1,000 Gals)	If more than 25% Indicate Causes	Maximum Gallons pumped in one day	Date of Maximum	Cal
1	Sat										
2	Sun										
3	Mon										
4	Tue										
5	Wed										
6	Thu										
7	Fri										
8	Sat										
9	Sun										
10	Mon										
11	Tue										
12	Wed										
13	Thu										
14	Fri										
15	Sat										
16	Sun										
17	Mon										
18	Tue										
19	Wed										
20	Thu										
21	Fri										
22	Sat										
23	Sun										
24	Mon										
25	Tue										
26	Wed										
27	Thu										
28	Fri										
29	Sat										
30	Sun										
31	Mon										
	MIN										
	MAX										

Variable  
(cursor)

On a "Monthly Entry Form" the entries are arranged by day-of-month and variable.

This is an example of a monthly entry form, this form is simple and shows all data for an entire month. Many of these forms can be used and if the same variable is listed on more than one it only will need to be entered into one. This is a very common and easy to use entry form.

# Data Entry

Custom Data Entry - Daily Data Entry

File Edit Format Help

Start Date: 01/05/2004 Current Date: Monday, January 05, 2004 Comment Calc

D4 Entry Min: 0 Entry Max: 15 Show Calcs

Daily Entry For Monday, January 05, 2004

Inf Flow	MGD	1101	SSV30	mL/L
Inf BOD	mg/L	1103	SVI	mL/g
Inf BOD Ld	lbs/day	1151	FC BlkHgt	Feet
Inf TSS	mg/L	1171	Aer Effic	#BOD/K
Inf TSS Ld	lbs/day	2406	CL2 Added	lbs/Day
Surch Calc	\$	2408	CL2 Dose	lbs/MG
Inf pH	SU	4001	Eff Flow	MGD
Inf NH3-N	mg/L	4011	Eff BOD	mg/L
Inf NH3-N Ld	lbs/day	4012	Eff BOD Ld	lbs/day
PE BOD	mg/L	4013	Eff BOD WkAvg	mg/l
PE BOD LD	lbs/Day	4016	BOD % Rem	%
PE TSS	mg/L	4017	BOD GGA	mg/l
PE TSS LD	lbs/Day	4018	Eff BOD Dup	mg/l


**TSS Benchsheet**

	Inf TSS	PE TSS	RAS Conc
Sample & Tare	<input type="text"/> g	<input type="text"/> g	<input type="text"/> g
Tare	<input type="text"/> g	<input type="text"/> g	<input type="text"/> g
Solids	<input type="text"/> g	<input type="text"/> g	<input type="text"/> g
Sample Volume	<input type="text"/> ml	<input type="text"/> ml	<input type="text"/> ml
Suspended Solids	223 mg/L	67 mg/L	9,600 mg/L

These forms take more to set-up and are more complicated but can serve more sophisticated purposes such as performing calculations.


All for the same date.

Variables could be arranged to match field sheets or other personalized needs.




# Optimizing Your Reporting Program

## Calculations




# Optimizing Your Reporting Program


## Calculations



# Optimizing Your Reporting Program

## Calculations





# Optimizing Your Reporting Program

- A variable list should:
  - include information that has a purpose
  - avoid overwhelming those collecting the data
  - be reviewed periodically
  - be clean and well organized (like items should be grouped together e.g. *influent data*)



# Optimizing Your Reporting Program

## Begin With The End In Mind

The eventual users need to develop a concept of what they want to do with the reports so that they can provide direction to the programmer. To do this the user will need to be or become familiar with his/her options.

### Some Common Uses Include:

- Regulatory Reporting
- Process Control Reporting
- Run Time Reporting
- Lab Data Entry
- Field Data Entry
- Trending

Wastewater Discharge Monitoring Long Report

For DMR Use Only

Facility Name: O Tawa WASTEWATER TREATMENT FACILITY  
 Facility Address: 233 N Campbell Rd  
 O Tawa W155555  
 Facility Contact: Jason Thomas, WWTP Supervisor  
 Phone Number: (555) 555-5365  
 Reporting Period: 07/01/2005 - 07/31/2005  
 Form Due Date: 08/15/2005  
 Permit Number: SSSSSSS

Date Received: DOC: 12386  
 FID: SSSSSSS  
 Region: Marlborough  
 Permit District: Jaba Dec  
 Reviewer: Jason Savitski  
 Office: Jase Dec

Sample Point	701	701	701	701	701	701
Description	INFLUENT TO PLANT	INFLUENT TO PLANT	INFLUENT TO PLANT	INFLUENT TO PLANT	INFLUENT TO PLANT	INFLUENT TO PLANT
Instrument	00211	00066	00457	00027	00133	00147
Description	Flow Rate	BOD5 Day	Suspended Solids, Total	Calcium, Total Recoverable	Chromium, Total Recoverable	Copper, Total Recoverable
Units	MGD	mg/L	mg/L	ug/L	ug/L	ug/L
Sample Type	Continuous	24-Hr Flow Prop Comp	24-Hr Flow Prop Comp	24-Hr Flow Prop Comp	24-Hr Flow Prop Comp	24-Hr Flow Prop Comp
Frequency	Daily	Daily	Daily	Monthly	Monthly	Monthly
Remarks	Day 1					
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
Total						

This is an example of a regulatory report that was developed to include the information that the operator would need to report to the state.



# Phosphorus

Date	In Phos Ld lbs/day	MLVSS Avg mg/l	RAS Flow KGAL	RASQ:InfQ Ratio	Recycle Speed %	Ef Phos Ld lbs/day	FeCl3 daily gal/day	Fe:P ratio	BPR SS ratio Anoxic:Anaerobic	Eff P mg/l
3/1/2002			805	0.42	60		41.85		1.09	
3/2/2002			791	0.42	60		41.85		1.09	
3/3/2002	64	2,280	769	0.42	60	5	41.85	1.13	0.92	0.30
3/4/2002			801	0.42	60	5	41.85		1.03	0.30
3/5/2002	69	1,993	792	0.42	60		30.44		1.08	
3/6/2002			786	0.42	60		30.44		1.07	
3/7/2002	65	2,020	812	0.43	60	5	30.44	0.77	0.92	0.30
3/8/2002			825	0.43	60		30.44		1.09	
3/9/2002			1,318	0.43	60		30.44		0.75	
3/10/2002	67	2,473	909	0.43	60	5	30.44	0.84	1.02	0.30
3/11/2002			892	0.43	60	5	30.44		0.99	0.30
3/12/2002	65	3,260	928	0.43	58		30.44		1.02	
3/13/2002									1.06	
3/14/2002								0.78	1.74	0.30
3/15/2002									1.54	
3/16/2002									1.62	
3/17/2002								0.00	1.45	0.30
3/18/2002								0.00	1.81	0.30
3/19/2002									1.56	0.30
3/20/2002									1.68	0.30
3/21/2002								0.00	1.49	0.30
3/22/2002			914	0.43	49		0.00		1.61	
3/23/2002			925	0.43	49		0.00		1.82	
3/24/2002	63	2,920	893	0.43	49	5	0.00	0.00	1.56	0.30
3/25/2002			878	0.43	49	7	0.00		1.59	0.40
3/26/2002	62	2,687	876	0.43	49		0.00		1.64	
3/27/2002			898	0.43	49		0.00		1.69	
3/28/2002	68	3,153	888	0.43	49	7	0.00	0.00	1.66	0.40
3/29/2002			912	0.43	49				1.55	
3/30/2002			926	0.43	49		0.00		1.64	
3/31/2002	62	2,660	837	0.43	49	7	0.00	0.00	1.82	0.40
Minimum	62	1,993	769	0.40	49	5	0.00	0.00	0.75	0.30
Maximum	69	3,360	1,318	0.43	60	7	41.85	1.13	1.82	0.40
Total	839	33,047	27,619	13.17	1,657	82	498.39	3.52	42.59	4.80
Average	65	2,754	891	0.43	53	5	17.19	0.35	1.37	0.32

This is an example of a process control report that was developed to include the information that the operator would want to know related to a specific process.

# Phosphorus

Date	In Phos Ld lbs/day	MLVSS Avg mg/l	RAS Flow KGAL	RASQ:InflQ Ratio	Recycle Speed %	ET Phos Ld lbs/day	FeCl3 daily gal/day	Fe:P ratio	BPR SS ratio Anoxic:Anaerobic	Eff P mg/l
3/1/2002			805	0.42	60		41.85		1.09	
3/2/2002			791	0.42	60		41.85		1.09	
3/3/2002	64	2,280	769	0.42	60	5	41.85	1.13	0.92	0.30
3/4/2002			801	0.42	60	5	41.85		1.03	0.30
3/5/2002	69	1,993	792	0.42	60		30.44		1.08	
3/6/2002			786	0.42	60		30.44		1.07	
3/7/2002	65	2,020	812	0.43	60	5	30.44	0.77	0.92	0.30
3/8/2002			825	0.43	60		30.44		1.09	
3/9/2002			1,318	0.43	60		30.44		0.75	
3/10/2002	67	2,473	909	0.43	60	5	30.44	0.84	1.02	0.30
3/11/2002			892	0.43	60	5	30.44		0.99	0.30
3/12/2002	65	3,260	928	0.43	58		30.44		1.02	
3/13/2002			1,016	0.43	53		30.44		1.06	
3/14/2002	63	3,360	899	0.43	51	5	30.44	0.78	1.74	0.30
3/15/2002			904	0.42	51		26.63		1.54	
3/16/2002			936	0.43	49		0.00		1.62	
3/17/2002	67	3,100	922	0.43	49	5	0.00	0.00	1.45	0.30
3/18/2002	62		910	0.42	49	5	0.00	0.00	1.81	0.30
3/19/2002			843	0.40	49	5			1.56	0.30
3/20/2002			904	0.43	49	5	0.00		1.68	0.30
3/21/2002	62	3,140	904	0.42	49	5	0.00	0.00	1.49	0.30
3/22/2002			914	0.43	49		0.00		1.61	
3/23/2002			925	0.43	49		0.00		1.82	
3/24/2002	63	2,920	893	0.43	49	5	0.00	0.00	1.56	0.30
3/25/2002			878	0.43	49	7	0.00		1.59	0.40
3/26/2002	62	2,687	876	0.43	49		0.00		1.64	
3/27/2002			898	0.43	49		0.00		1.69	
3/28/2002	68	3,153	888	0.43	49	7	0.00	0.00	1.66	0.40
3/29/2002			912	0.43	49				1.55	
3/30/2002			926	0.43	49		0.00		1.64	
3/31/2002	62	2,660	837	0.43	49	7	0.00	0.00	1.82	0.40
Minimum	62	1,993	769	0.40	49	5	0.00	0.00	0.75	0.30
Maximum	69	3,360	1,318	0.43	60	7	41.85	1.13	1.82	0.40
Total	839	33,047	27,619	13.17	1,657	82	498.39	3.52	42.59	4.80
Average	65	2,754	891	0.43	53	5	17.19	0.35	1.37	0.32


# Area B & C Primary Clarifiers Monthly Run Times Page 1

For Date: July, 2006

	Primary Clarifier 1 Run Time	Primary Clarifier 2 Run Time	Primary Clarifier 3 Run Time	Primary Clarifier 4 Run Time	Primary Bludge Pump 1 Run Time	Primary Bludge Pump 2 Run Time	Primary Bludge Pump 3 Run Time	Primary Bludge Pump 4 Run Time
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
<b>TOTAL</b>								
<b>AVERAGE</b>								
<b>MAXIMUM</b>								
<b>MINIMUM</b>								

This is an example of a report that was developed to allow SCADA information (run times) to be reviewed by the operators.

### Data Over Time




Date ( 10/1/2003 to 10/31/2003 )  
/ 611 Primary Eff / 11 Influent BOD / 4011 Effluent BOD

# Philosophy

- Create a Comprehensive Parameter List
  - Do not collect data that you do not know how you will use, it only complicates things
  - Do set the computer up to do math to eliminate opportunities for error and to get data fast
- Maintain Good Communication With All Involved (especially between programmer and operator)
- Get The Most Out Of Training
- Develop An Understanding Of What You Intend To Do With The Program Early In The Process

# Bensenville, IL Wastewater Treatment Facility

## History of Construction



1940s

1960s

1970s

1980s

1990s

***Most of the plant  
was more than 40 –  
50 years old***


# Project Need and Drivers

- Plant age and deficiencies
- Controls/automation
- Regulatory changes (P-removal)
- Sanitary Sewer Overflows/Surcharging




# Key Considerations - Simplify the WWTF

## Existing WWTF - 11 Steps & 2 Digestion Processes



## Simplified WWTF - 8 Steps & 1 Digestion Process




- *Lower Capital \$*
- *Lower Operating \$*
- *Lower Maintenance \$*

- *Easier to Operate*
- *Easier to Maintain*
- *Improved Flexibility*


# Major Challenges Overcome During Construction

- Taking Existing Processes Out of Service While Meeting Effluent Limits
- Extremely Tight Site
- Aeration Tank Modifications in Multiple Stages
- Underground Utilities/Site Piping
- Influent Pumping Modifications

# Existing Site Layout



# Bensenville WWTF Flow Schematic




Legend:

- Total Flow (Normal and Excess Flows)
- Normal Flows up to 12.0 MGD
- Wet Weather Flows Above 12.0 MGD up to 30.0 MGD

# BNR Upgrades

- Biological Phosphorus Removal
  - AO or A2O Process
- Remove BOD and Ammonia
  - Plug Flow Operation
  - Fine Bubble Aeration/Turbo Blowers/DO/ORP Control
- Provide Flexibility
  - Take Tanks out of Service
  - Multiple Nitrate Recycle Pumping Locations
- Remove Nitrate
  - Energy Savings
  - Settling Characteristics
  - Nitrogen Removal
- Alkalinity Restoration



# Start-up Training Timing

- Timing
  - Too Early = Limited Urgency
  - Too Late = Too Much Burden on Operator



# Start-up Operator Involvement

- Involvement
  - Too Much = Too Much Burden on Operator
  - Too Little = Lost Learning Opportunity
- Roles
  - Contractor
    - Construct
    - Coordinate
  - Engineer
    - Big Picture Training
    - Advocate for Owner
  - Manufacturer
    - Small Detail Training
  - Owner/Operator
    - Participation
    - Operation

# Contract Information Organized and Searchable

Strand Associates, Inc.® (SA)

Wastewater Treatment Plant Improvements  
Electronic Operations and Maintenance Manual

Village of Bensenville  
DuPage County, Illinois

Vol. I Engineer's  
O&M Manuals

Vol. II Manufacturer's  
O&M Manuals

Training  
Presentations

Plans



Simple Menus Navigate Information  
Categories



Links to Searchable PDFs Allow Quick  
Access

## Division 11 Process Equipment

File  
Directory

11290 Slide, Sluice, Weir, and Stop Gates	11320 & 11329 Grit Collector and Grit Washer	11374 High Speed Turbo Blower
11310 Centrifugal Sludge Pumps	11331 Mechanically Cleaned Fine Screens	11375 Aeration Equipment
11311 Submersible Pumps	11334 Screenings Wash Presses	11399 Plant Water Filter
11312 Influent Screw Pumps	11337 Final Clarifier Collectors	11400 Nitrate Recycle Pumps
11315 Booster Pumps	11347 Polymer Feed Equipment	11410 Anaerobic and Anoxic Mixers
11317 Rotary Lobe Pumps	11360 Belt Thickener & Filter Press	11610 Sampler
11319 Grit Pump	11370 Positive Displacement Blowers	



# Training Modules Consistent with O&M Manuals

File Directory

## Training Presentations

Kick-off Training	Activated Sludge	Biosolids Dewatering and Storage
Screening	Final Clarifiers and RAS Pumping Start-up	
Grit Removal	Thickening	
Influent Pumping and Lift Station No. 14	Aerobic Digestion	

# Kick-off Training


## ■ Outline

1. Strand Training/Startup Team
2. Contractor's Schedule
3. Process Overviews
4. Resources



## ■ Final Clarification – Manufacturer Conversations

1. Lubrication
2. Preventive Maintenance
3. Clearances
  - Scum
  - Header
4. Manifold
5. Inspection
6. Winter Considerations



Source – Walker Process Shop Drawing



# Database Development Provides Training Value

- Parameters
  - From Lab
  - From Field
  - From SCADA
  - Calculated
- Reports
  - Compliance
  - Operations
- Trends

## Parameter List Development Prior to Building Database

	A	B	C	D	E	F
1	Parameter Name	Variable Information				
2	Process - Location	Parameter	Units	Equipment	Decimal YTD	
3	Aeration Blower 1	Secondary Treatment	Run Time	hours	B-90-01	1
4	Aeration Blower 1	Secondary Treatment	Starts	Count	B-90-01	0
5	Aeration Blower 2	Secondary Treatment	Run Time	hours	B-90-02	1
6	Aeration Blower 2	Secondary Treatment	Starts	Count	B-90-02	0
7	Aeration Blower 3	Secondary Treatment	Run Time	hours	B-90-03	1
8	Aeration Blower 3	Secondary Treatment	Starts	Count	B-90-03	0
9	Aeration Combined ML 30 min SSV	Secondary Treatment				0
10	Aeration Combined ML 5 min SSV	Secondary Treatment				0
11	Aeration Combined F/M	Secondary Treatment	F/M	lbs BOD/lb MLVSS	CALCULATE	2
12	Aeration Combined Filament Abundance	Secondary Treatment				0
13	Aeration Combined MLSS	Secondary Treatment				0
14	Aeration Combined MLSS % Volatile	Secondary Treatment				2
15	Aeration Combined SRT (MCRT)	Secondary Treatment	SRT	Days	CALCULATE	1
16	Aeration North Anoxic 1 ORP	Secondary Treatment	ORP Average	mV	AIT-20-01	0
17	Aeration North Anoxic 1 ORP	Secondary Treatment	ORP Maximum	mV	AIT-20-01	0
18	Aeration North Anoxic 1 ORP	Secondary Treatment	ORP Minimum	mV	AIT-20-01	0
19	Aeration North F/M	Secondary Treatment				3
20	Aeration North Influent Flow	Secondary Treatment	Total	MG	CALCULATE	3
21	Aeration North Influent Flow	Secondary Treatment	Min	MGD	CALCULATE	3
22	Aeration North Influent Flow	Secondary Treatment	Max	MGD	CALCULATE	3
23	Aeration North ML 30 min SSV	Secondary Treatment		mis		0



# Operator Training Designed to Challenge Operators

## Quiz Prior to Training Creates Challenge and Provides Feedback to Trainers

### Pre-Quiz Activated Sludge

1. Describe anaerobic conditions, anoxic conditions, and aerobic conditions.  
Anaerobic:  
Anoxic:  
Aerobic:
2. Describe biochemical oxygen demand (BOD) and how it's removed in the activated sludge process.  
BOD:  
  
Activated Sludge Process:
3. What is the purpose of biological nutrient removal (BNR) and nitrate recycle pumping?  
BNR:  
  
Nitrate Recycle Pumping:
4. During ideal biological nutrient removal, in which tank(s) should microorganisms release phosphorus (P) and which tanks(s) should phosphorus uptake by microorganisms occur?
  - a. Release P in Anoxic Tank; uptake P in Anaerobic Tank
  - b. Release P in Anaerobic Tank and Aerobic Tank; uptake P in Anoxic Tank
  - c. Release P in Aerobic Tank; uptake P in Anaerobic Tank and in Anoxic Tank
  - d. Release P in Anaerobic Tank; uptake P in Aerobic Tank
5. Circle True or False for each statement regarding nitrifying bacteria.  
T F - Nitrifiers reproduce at a rate faster than heterotrophic bacteria  
T F - Loss of alkalinity may inhibit complete nitrification  
T F - At lower temps, nitrifiers reproduce slower  
T F - Nitrifiers in the anoxic tank do not require oxygen for the nitrification process

# Operator Training Covered Details from Theory to Implementation

## Blend of Theory and Site Specific Information


### Denitrification Theory

#### Denitrification

- 
- Oxygen/Energy Recovery
  - Allowing denitrification to occur in controlled environments allows a facility to recover some of the aeration expense incurred during nitrification.


16

### Biological Phosphorus Treatment



17

### Biological P Removal - Theory




18

### Biological P Removal - Principles

- Key Wastewater Characteristics
  - Influent Phosphorus Concentration
  - Influent BOD<sub>5</sub> Concentration
  - Fraction of Readily Biodegradable
  - BOD<sub>5</sub> to P Ratio
  - Influent TKN
  - Influent Volatile Fatty Acids (VFAs)


19



20

### Aeration Tanks

- Remove Phosphorus
  - Perform Biological Phosphorus Removal
- Remove Ammonia
  - Plug Flow: Serpentine Pattern
- Remove Nitrate
  - Energy Savings
  - Settling Characteristics
  - Nitrogen Removal
  - Alkalinity Restoration



21

### Design Criteria

- See Table 5.2-2 of O&M Manual for all design criteria


Element	Design Value
Activated Sludge Treatment Trains	2
Number of Trains/Train	2
Flow (MGD)	1.50
Flow (MGD)	2.00 (MG 1-10-19)
Average Water Depth (ft)	10.0
Depth (m)	3.05
Volume: Total (gal)	3,940,000
Volume: Anoxic (gal)	200,000
Volume: Aerobic (gal)	3,740,000
Volume: Anoxic (m <sup>3</sup> )	758
Volume: Aerobic (m <sup>3</sup> )	11,100
Flow: Hydraulic Retention Time (hrs)	10.4
Flow: Hydraulic Retention Time (days)	0.43
Flow: Hydraulic Retention Time (m <sup>3</sup> /day)	20.0



22

### Aeration Basin

- Number of Trains: 2
- Passes per Train: 5
- Total Volume: 3,940,000 gal
- Loading Rate
  - Daily Average: 124 lb BOD/1000 of or 6,555 lb/day



23

### Major Components



Fand du Lac, WI

- Floating Mixers
  - Provides mixing to Anaerobic Tanks and Anoxic Tanks

Design Criteria	
Type	Floating
Number	Anaerobic Tank - 1 Anoxic Tank - 2
Motor	5 hp each

24

### Major Components



Fand du Lac, WI


- Nitrate Recycle Pump
  - Transfers ML from Aeration Tanks to Anoxic Tanks

Design Criteria	
Type	Propeller
Number	4
Motor	20 hp
Capacity	16,300 gpm

25

### Major Components

- Blowers
  - Provide air to aeration tanks



Design Criteria	
Type	High Speed Centrifugal
Number	2 + 1 standby
Motor	200 hp
Capacity	16,300 gpm
Minimum Air	2000 cfm


21

### Operation



22

### Routine Process Schematic




23

### Routine Operation

- Influent Splitter Box and RAS Splitter Box
  - The RAS and PI flows are divided in their respective splitter boxes
  - The RAS and PI combine to form ML
    - RAS flow to combine to ML – controlled by Stop gates
    - PI flow to combine to ML – controlled by DOW gates
  - During normal operation, flow should be evenly split to each treatment train from the influent splitter box

24




25

# Operator Training Continues During Operations


## Image of Tool Built to “Profile” BNR System to Characterize Each Intended Environment

- Parameters

- Phosphorus
- Nitrate
- Dissolved Oxygen
- Oxidation Reduction Potential




# Operator Training and Optimization Continues During Operations




# Early Operation Learning Opportunities

Weekly Average Effluent Total Phosphorus




No Limit (1 mg/L Target)

# Wet Weather Workshops Developed Strategies Based on Capacity Fundamentals




Date	21-Jan-16			
Influent	3	4.7	12	20
PAS Flow	4.5	7.05	7.05	7.05
Clarifier Combined Q	7.5	11.75	19.05	27.05
Clarifiers in Service	2	2	2	2
Clarifier sq ft	12720	12720	12720	12720
Clarifier Load	156.375	244387.5	397192.5	562392.5
Clarifier Load	<b>12.29</b>	<b>19.26</b>	<b>31.23</b>	<b>44.34</b>
SVI	100	100	100	100
MLSS	2500	2500	2500	2500



**Tools Developed to Review Wet Weather Impacts On Fundamental Control Indices Such as Detention Times and Solids Loading Rates**

# Operator Standard of Care Added Great Value to Project



**Staff Implemented Labels and Communication Tools**

# Open House Ideas



**Held Duck Races in Final Clarifier**



**Highlighted Other Public Works Departments**



**Invited Other Organizations**



**Staged Smaller Tour Groups**

# Waterloo, Iowa

# Microthrix parvicella:


the bête noire (black beast) of filaments

“Microthrix parvicella, a gram positive, unbranched filament, can confidently be said to be the most troublesome filamentous bacterium in activated sludge”

- Elizabeth Seviour and Robert Seviour Australian microbiologists with the Biotechnology Research Centre at La Trobe University, Bendigo

# M. Parvicella Characteristics


- Associated with
  - Low F:M Ratios
  - High Fat and Grease
  - Low Temperatures
  - Selectors



# Aesthetics



# Inventory Management




**Aeration Tank**

**Profile View**

# Inventory Management


What percentage of my biomass is in the foam?



Aeration Tank

Profile View


# Inventory Management



**Aeration Tank**

**Profile View**

# Inventory Management




# Freezing Concerns




# Settleability/Capacity Limitation

Clarifier Capacity is Impacted by Settling Characteristics



# Foam Trapping





At least the foam is not trapped

# Foam Trapping


## Aeration Tank

### Profile View




## Final Clarifier

### Profile View



Wasting

# Foam Trapping – Co-Thickening



Wasting

Co-Thickening

# Inventory Control and Sludge Age Impacts Foaming Filaments

- Conventional Wisdom and Experience Indicate Sludge Age to be a Factor
  - Higher sludge ages allow slower growing filaments to compete
    - 12 days is a divide at some facilities


# Countering the Triggers

- Eliminate Foam Trapping
- Control F.O.G.
- Reduce Sludge Age
- Provide Plug Flow Features for all zones
- Avoid low D.O. Zones
- Consider Chemical Treatment

# Fundamental: Alkalinity Impacts Nitrification


- pH/ Alkalinity
  - Nitrifiers are pH sensitive (best 7.5 - 9, can nitrify down to 4.5)
  - Bicarbonate alkalinity is needed for a carbon source (7.14 mg Alk./ mg NH<sub>3</sub> nitrified)
  - Significant changes in pH can be toxic to nitrifiers or inhibit their ability to completely nitrify
  - Loss of alkalinity may inhibit complete nitrification

# Fundamental: Nitrification and Denitrification – Historical Theory



Air Mixing Hinders  
Denitrification

# Waterloo Wastewater Facilities Includes Two Main WWTPs and Off-site Anaerobic Lagoon



## Anaerobic Lagoon

- Treats > 50% of total load
- Lagoon effluent enters Satellite WWTP collection system
- Creates carbon limited conditions @ Main WWTPs
- > 800,000 CF/day gas

## Main WWTFs

- Easton WWTP (domestic)
- Satellite WWTP (industrial)

# Two Separate Biological Units Easton & Satellite

**Satellite Facility  
Designed to Accept  
Designated Industrial  
Waste only**



**Easton Facility  
Designed to Accept  
Domestic and Minor  
Industrial Waste only**

**Current Mode of Operation was  
To Combine the Waste and Treat  
Only Thru the Easton Facility**

# Existing WWTP Design Criteria

	Easton	Satellite	Combined
<u>Design Flow</u>			
Annual Average	20.4	6.7	27.1
Average Wet Weather	26.7	8.1	34.8
Peak Flow to Biological Treatment	36.0	11.1	47.1
<u>BOD Loading</u>			
Average Day	24,000	38,800	62,800
Maximum Month	30,000	58,000	88,000
<u>TKN Loading</u>			
Average Day	4,500	7,025	11,525
Maximum Month	7,500	13,550	21,050


# Treatment Capacity with Current Operation

	Current Value	Easton Plant Design	% of Easton Design Capacity
<b>Combined Influent Flow, mgd</b>			
Average Day	17.2	20.4	84%
<b>Combined Influent Loads, lbs/day</b>			
BOD <sub>5</sub>	28,645	24,000	119%
TSS	33,114	18,000	184%
TKN	8,241	4,500	183%

Satellite influent contribution:


35% of BOD, 30% of TSS, and 60% of TKN

# Challenges and Operational Responses



	A	B	HF	HG	HI	II	III	HR
5	Home	Links	11213	66	5366	141680700	41156524	
6			Total	85.73	0.57	-4.66	0.00	0.00
7			Min	207.60	0.69	72.61	712982.00	#####
8			Max	107.82	0.63	61.50	392467.31	115931.05
9			Average	104	104	104	361	355
10			Count					
15	East Eff	Metals Eff	RAS/WAS	Var 206	Var 207	Var 208	Var 209	Var 210
16	East Eff	Metals Eff	Statistics	Dig Calcs	Dig Calcs	Dig Calcs	F B Data	F B Data
17	East Eff	Metals Eff	Statistics	CALCULATIONS				F B DATA
18	East Eff	Metals Eff	Statistics	AVG TEMP	THK DRFT	VOL %	REDUCTION	THK SLDS
19	East Eff	Metals Eff	Statistics	AR 1-4	Limit			FB SLDS
20				F	%	%	Gal	Gal
880				5/9/2018				
881				5/10/2018				
882				5/11/2018				
883				5/12/2018				
884				5/13/2018				
885				5/14/2018				
886				5/15/2018				
887				5/16/2018				
888				5/17/2018				
889				5/18/2018				
890				5/19/2018				
891				5/20/2018				
892				5/21/2018				
893				5/22/2018				
894				5/23/2018				
895				5/24/2018				
896				5/25/2018				
897				5/26/2018				
898				5/27/2018				
899				5/28/2018				
900				5/29/2018				
901				5/30/2018				
902								
903								

# Challenge: Nitrogen Load Ratio High From Industrial Sector




# Challenge: Nitrification Alkalinity Demands Are Significant


- Nitrogen Load – Alkalinity Balance Fragile
- Denitrification Rate Impacted by:
  - BOD:N Ratio
  - Aerated anoxic zone
- SOP to monitor alkalinity and supplement magnesium hydroxide necessary at times
  - pH <6.6 Add Magnesium Hydroxide
  - Alkalinity Minimums

	Alkalinity
Units	mg/L
5/15/2017	250
5/16/2017	225
5/18/2017	175
5/21/2017	200
5/23/2017	160
5/25/2017	165
6/5/2017	115
6/6/2017	165
6/8/2017	100

# Challenge – Filaments: Microthrix



# Settling Issues Occur in Winter



# Operational Responses – Microscopy Assistance and Training

**TO:** BRIAN BOWMAN  
**FROM:** TONI GLYMPH-MARTIN  
**SUBJECT:** WATERLOO, IA – MICROSCOPIC EVALUATION  
**DATE:** 8/2/2017



The following samples were collected on 7/31/17 and observed on 8/1/17:

- Mixed Liquor
- RAS


#### Observations:

Shelled amoebae were dominant in both the mixed liquor and the RAS samples. Only a small amount of filamentous bacteria was observed in the samples. Some exocellular lipopolysaccharide was observed within the floc in both samples however, the amount continues to decrease. Healthy active protozoa (stalked ciliates and crawling ciliates) were observed. Zooglea was also present in both samples but not in significant amounts.

#### Discussion:

##### *Exocellular lipopolysaccharide*

The amount of exocellular lipopolysaccharide present in the mixed liquor and RAS samples continue to decrease when compared to the samples observed in April. Floc was a healthy brown color indicating that the plant is operating at a sufficient F/M ratio and that sufficient nutrients are present.




# Operational Responses – Operational Adjustments

- Capacity in service
- Wasting rate sludge age based on filament elimination
- WAS decant
- FOG program continues to be a point of emphasis
- Lagoon management to equalize flows/loads as practical
- DO control an operator emphasis


# Nitrification and Filament Reduction have Different Ideal Sludge Ages

- Lower Benefits Filament Removal
- Higher Benefits Nitrification




# Nitrification and Filament Reduction have Different Ideal Sludge Ages

- Lower Benefits Filament Removal
- Higher Benefits Nitrification



# Challenge – Wasting Limitations



**Current WAS  
Storage  
Limits Operations**

# Operational Response: WAS Storage Tank Decant Automation



Air Valve Original



WAS Tank 3, Air Off




Valve Automated



Automated Valve Tied to Tank Level

# Operational Response: Weekend Wasting a Priority



# Challenge - Data Collected In Monthly Sheets

Reports 2009	4/25/2017 8:42 AM	File folder
Reports 2010	4/25/2017 8:42 AM	File folder
Reports 2011	4/25/2017 8:42 AM	File folder
Reports 2012	4/25/2017 8:42 AM	File folder
Reports 2013	4/25/2017 8:42 AM	File folder
Reports 2014	7/19/2017 10:40 AM	File folder
Reports 2015	2/5/2018 2:35 PM	File folder
Reports 2016	10/9/2017 3:46 PM	File folder
Reports 2017	7/3/2017 9:28 AM	File folder

DNR 2009.xls	3/12/2010 8:49 AM	Microsoft Excel 97...	535 KB
Easton Performance 2009.xls	2/15/2017 2:37 PM	Microsoft Excel 97...	724 KB
Industry 2009.xls	1/26/2010 12:06 PM	Microsoft Excel 97...	874 KB
Landfill 2009.xls	1/20/2010 10:06 AM	Microsoft Excel 97...	70 KB
Sludge 2009.xls	1/12/2010 10:11 AM	Microsoft Excel 97...	379 KB

!	5	0.101	0.000
!	5	0.146	0.000
Sept 2009	Oct 2009	Nov 2009	<b>Dec 2009</b>

# Operational Responses - Existing Spreadsheets Combined for Comprehensive View


- ~200 Variables
- Buttons to minimize random searching for information.

	A	B	HF	HG	HH	HI	HJ	HK
5		Total	11213	66	5356	141680700	41155524	
6	Home	Links	Min	85.73	0.57	-4.66	0.00	0.00
7			Max	207.60	0.69	72.51	712582.00	#####
8			Average	107.82	0.63	51.50	392467.31	115931.05
9	<-- Click Plus to Expand		Count	104	104	104	361	355
15	East Inf	Metals Eff	RAS/WAS	Var 206	Var 207	Var 208	Var 209	Var 210
16	East Eff		Primaries	Dig Calcs	Dig Calcs	Dig Calcs	F. B Data	F. B Data
17	Sat Inf	Comb Eff Statistics	TAS	CALCULATIONS			F.B DATA	
18	Sat Eff		Digesters	AVG TEMP	TANK 2BELT VOL%	VOL % REDUCTION	THK SLDG	FB SLDG
19	Comb Inf	EQ OF	Limits					
20	Comb Eff	AB 1-4		F	%	%	Gal	Gal
880		5/9/2018						
881		5/10/2018						
882		5/11/2018						
883		5/12/2018						
884		5/13/2018						
885		5/14/2018						
886		5/15/2018						
887		5/16/2018						
888		5/17/2018						
889		5/18/2018						
890		5/19/2018						
891		5/20/2018						
892		5/21/2018						
893		5/22/2018						
894		5/23/2018						
895		5/24/2018						
896		5/25/2018						
897		5/26/2018						
898		5/27/2018						
899		5/28/2018						
900		5/29/2018						
901		5/30/2018						
902								
903								

# Spreadsheet Hyperlinks Limit Issues with Spreadsheet Size


	A	B	C	D	E	F
1	<b>Waterloo Operations Spreadsheet Hyperlink Table</b>					
2						
3	<b><u>DASHBOARDS</u></b>		<b><u>DATA ENTRY</u></b>		<b><u>FIGURES</u></b> <i>click chart name to jump directly to specific charts</i>	
4	Dashboard		Data Entry Home		Flows and Loads	
5	Wasting Dashboard		East Inf		Clarifier Considerations	
6	100 Day Highlights		EQ OF		Performance	
7			East Eff		Effluent BOD and TSS	
8			AB 1-4		SVI	
9			Sat Inf		RAS vs SVI	
10			RAS/WAS		MLSS vs RAS SS	
11			Sat Eff		Blanket Depth	
12			Primaries		Influent BOD Load vs Influent Load	
13			Comb Inf		Units in Service	
14			TAS		Wasting Considerations	
15			Comb Eff		Nitrification	
16			Digesters		SLR vs SVI	
17			Metals Eff		HRT vs Eff NH3	
18			Limits		Solids Inventory vs Eff NH3	
19			Comb Eff Statistics		Sludge Age vs Eff NH3	
20					pH vs Eff NH3	
21					Temperature vs Eff NH3	
22					Influent Load vs Eff NH3	
23					Vol Load vs Eff NH3	
24					Volumetric Loading	

# Spreadsheet Develops Correlation



# Dashboards Allow Quick Reference

- Key Indices
  - Performance
  - Wasting
  - 100 Day Troubleshooter
- Date Adjustable



# Use of Functions Allows “Dashboard” Functionality


	A	B	C
17			0
18		Parameter	BOD Vol Load
19		Units	lbs/1000 cu ft
20		Variable	Var SAI22
21		2 Week Min	6.07
22		2 Week Max	22.76
23		2 Week Average	14.90
24	20	5/13/2018	9.0
25		5/12/2018	16.3

Date Offset


Formula in C24...

```
=VLOOKUP($B24,'Data Sheet'!$B$21:$HJ$901,MATCH(C$20,'Data Sheet'!$B$15:$HJ$15,0),FALSE)
```


# Dashboards Provide Quick Reference to Stress



March 2018





May 2018



February 2017

# Spreadsheet Develops Correlation




# Spreadsheet Develops Correlation


## February 2017

## March 2018

TSS Concentration (mg/L)



# Spreadsheet Allows for “What If” Scenarios





# Questions and Answers



**STRAND**  
ASSOCIATES®

Excellence in Engineering Since 1946