

**Procrastinator Workshop**

**Columbus, Ohio**

**12/5/2018**

**Components of a Good Backflow Program**

**OTCO-B13195-OM 0.50 hr**

**Presented By Gary A. Espenschied**

**Backflow Coordinator for**

**The Operator Training Committee of Ohio Inc.**



**Procrastinator Workshop**

**Columbus, Ohio**

**12/5/2018**

**Components of a Good Backflow Program**

**OTCO-B13195-OM 0.50 hr**

**Presented By Gary A. Espenschied  
Backflow Coordinator for  
The Operator Training Committee of Ohio Inc.**

**The following checklist has been taken directly from the Ohio EPA Backflow  
Prevention and Cross-Connection Control Manual Four Edition- 2015**



## **CHECKLIST FOR A GOOD BACKFLOW PREVENTION PROGRAM**

In order to ensure a public water system has and maintains an adequate backflow prevention program, the following components will be addressed during a system's sanitary survey by the field office staff of Ohio EPA. A public water system must have these components addressed and be ready to discuss them at the time of a survey:

1. Does the water system have a cross-connection control ordinance or other legal mechanisms that are used to control cross-connections? (Indicate all mechanisms used.)
  - a. Ordinances
  - b. Service Contract
  - c. Rental Agreement?
  - d. By-Laws?
  - e. Other (explain in notes)?

•In order to have an enforceable program, the system needs to have either an ordinance on the books or requirements in the by-laws.



2. Does the cross-connection control program include the following:
- a. Requires installation and operation of appropriate type of approved backflow preventer?
    - The backflow preventers have to appropriately protect the system in accordance with the potential degree of hazard and must be testable (OAC 3745-95-04)
  - b. Provides right-of-entry for inspection?
    - Rules must permit entrance into a premises served by the PWS to conduct a thorough inspection of all water uses on-site.
  - c. Conducts inspections/tests for all installed backflow preventers every 12 months?
    - The installed assemblies/air gaps have to be inspected and tested at least once every 12 months (not annually). The most recent inspection/test report must be made available.



## STATE OF OHIO Annual Test & Maintenance Report for Backflow Prevention Assemblies

**Facility Name:** \_\_\_\_\_  
**Address:** \_\_\_\_\_  
**Contact Person:** \_\_\_\_\_  
**Assembly Information:** \_\_\_\_\_  
**Installation Information:** \_\_\_\_\_  
 Make: \_\_\_\_\_ Containment: \_\_\_\_\_ Isolation: \_\_\_\_\_  
 Model: \_\_\_\_\_ Meter Pit: \_\_\_\_\_ Basement: \_\_\_\_\_ Floor Number: \_\_\_\_\_  
 Size: \_\_\_\_\_ Penthouse: \_\_\_\_\_ Boiler Room: \_\_\_\_\_ Room Number: \_\_\_\_\_  
 Serial Number: \_\_\_\_\_ Mechanical Room: \_\_\_\_\_ Protection Provided: \_\_\_\_\_

Double Check Assembly		Reduced Pressure Assembly		Pressure Vacuum Breaker	
Outlet Valve	Pass / Fail	1 <sup>st</sup> Check Valve	Pass / Fail	Air Inlet Valve	Pass / Fail
1 <sup>st</sup> Check Valve	Pass / Fail	Relief Valve	Pass / Fail	Check Valve	Pass / Fail
2 <sup>nd</sup> Check Valve	Pass / Fail	Opening Point	Pass / Fail		
		2 <sup>nd</sup> Check Valve	Pass / Fail		
		Outlet Valve	Pass / Fail		

**Repairs & Materials Used:** \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Double Check Assembly		Reduced Pressure Assembly		Pressure Vacuum Breaker	
Outlet Valve	Pass / Fail	1 <sup>st</sup> Check Valve	Pass / Fail	Air Inlet Valve	Pass / Fail
Re-Test After	Pass / Fail	Relief Valve	Pass / Fail	Check Valve	Pass / Fail
1 <sup>st</sup> Check Valve	Pass / Fail	Opening Point	Pass / Fail		
2 <sup>nd</sup> Check Valve	Pass / Fail	2 <sup>nd</sup> Check Valve	Pass / Fail		
		Outlet Valve	Pass / Fail		

**Comments:** \_\_\_\_\_

**TESTER CERTIFICATION:** *I hereby certify that the above data is correct and that the backflow prevention device is in proper working condition.*

**Tester Name (Printed):** \_\_\_\_\_ **Signature:** \_\_\_\_\_  
 OTCO Certified Tester #: \_\_\_\_\_ **OTCO Certified Tester Exp. Date:** \_\_\_\_/\_\_\_\_/\_\_\_\_  
 Department of Commerce Certified Tester  
**Company Name:** \_\_\_\_\_ **Ohio Certificate #:** \_\_\_\_\_ **Contractor #:** \_\_\_\_\_ **Date:** \_\_\_\_\_  
*I hereby certify that the above backflow prevention device has been in constant use at this location during the entire prescribed interval between test periods and during any other test periods and that the device was not bypassed, made inoperative or removed without proper authorization. I further certify that I have the authority and responsibility to answer the above.*  
**Owner/Officer (Printed):** \_\_\_\_\_ **Signature:** \_\_\_\_\_  
**Title:** \_\_\_\_\_ **Date:** \_\_\_\_\_  
 Updated 07/15/16



- d. Enforces discontinuance of service to any facility where suitable or operable backflow preventers have not been provided for a cross-connection?
- . The PWS has to have the right to cut off water service to any service connection where the backflow preventers are not properly maintained and tested.
- e. Require appropriate protection and inspection of all other booster pump installations?



## LOW PRESSURE CUT-OFF CONTROLLER TEST REPORT

Premises Address: \_\_\_\_\_ Company Name: \_\_\_\_\_ Type  
 Contact Name: \_\_\_\_\_ Contact Phone No: \_\_\_\_\_  
 of Controller: Fire Pump \_\_\_\_\_ Domestic Booster Pump \_\_\_\_\_ Pressure Sustaining Valve \_\_\_\_\_ Manuf: \_\_\_\_\_  
 Model No: \_\_\_\_\_ Serial No: \_\_\_\_\_ Type of Inspection: Initial  
 Annual \_\_\_\_\_ Date of Inspection: \_\_\_\_\_  
 \*\*\*\*\*

YES NO  
 \_\_\_\_\_ Found the sensing line seal intact  
 \_\_\_\_\_ Found the normal power light (green) on

**MANUAL START**  
 \_\_\_\_\_ Low suction light (red) comes on when suction pressure reaches 10 psig  
 \_\_\_\_\_ The alarm sounds after a minimum 30 second delay  
 \_\_\_\_\_ The pump shuts off immediately after the low suction pressure alarm sounds  
 \_\_\_\_\_ The pump has automatic restart when the sensing line is recharged

**AUTOMATIC START**  
 \_\_\_\_\_ Low suction light (red) comes on when suction pressure reaches 10 psig  
 \_\_\_\_\_ The alarm sounds after a minimum 30 second delay  
 \_\_\_\_\_ The pump shuts off immediately after the low-suction pressure alarm sounds  
 \_\_\_\_\_ The pump has automatic restart when the sensing line is recharged

**RESET PUMP**  
 \_\_\_\_\_ Opened outlet valve at pump discharge  
 \_\_\_\_\_ Pump restarted in manual start mode  
 \_\_\_\_\_ Pump restarted in automatic start mode  
 \_\_\_\_\_ Resetted sensing line valve in open position

I certify that the low pressure cut-off controller test as described above was performed by me on the date indicated and the findings were as indicated:

**INSPECTOR:** \_\_\_\_\_ Printed Name: \_\_\_\_\_  
 Signature \_\_\_\_\_  
 Cert. Tester No: \_\_\_\_\_ Date: \_\_\_\_\_  
 \*\*\*\*\*

I certify that the inspection was performed on the date indicated and that the following statement is true. The low-suction pressure cut-off controller has been in use during the interval between inspections and during that period has not been bypassed or otherwise made ineffective.

**Company Representative:** \_\_\_\_\_ Date: \_\_\_\_\_  
 Name (Please Print) \_\_\_\_\_ Title: \_\_\_\_\_  
 Signature \_\_\_\_\_



f. Ensure that customers with auxiliary water systems (i.e. private wells) have the appropriate backflow protection and inspection?

. Service connections must have a physical separation between the PWS and the auxiliary water system and a proper backflow preventer unless the PWS follows all the requirements of OAC 3745-95-04 (C)(2)

3. Who does the water system accept to perform the every 12-month inspection on the backflow prevention assemblies?

- a. Department of Commerce Certified Tester
- b. OTCO Certified Tester
- c. Licensed Plumber
- d. PWS Personnel
- e. Other



4. Have all existing customers required to have backflow prevention been identified?
  - Not just industrial, institutional and larger commercial users, but also small commercial users, rural customers with auxiliary water systems or yard hydrants and residential users with underground irrigation systems or booster pumps must be surveyed.
5. Is there a mechanism to identify the need for backflow prevention on new service connections?
  - PWS should have construction inspection completed prior to connecting initial tap



## SAMPLE CROSS CONNECTION QUESTIONNAIRE

Company Name: _____	Address: _____	Contact Name: _____	Contact Phone: _____
Meter No: _____	Meter Size: _____	Use Type: Commercial    Industrial    Residential    Fire    Combined    Irrigation:	
Inspector Name: _____	Company Name: _____	Inspection Date: _____	

**DOMESTIC SYSTEM:**

Description of Water Use(s) at Premises: \_\_\_\_\_

Existing Backflow Preventer Installed: Yes No    Mant: \_\_\_\_\_    Model: \_\_\_\_\_    Size: \_\_\_\_\_    Serial No: \_\_\_\_\_    Date Last Test: \_\_\_\_\_

Heating/Forced Air    Electric    Solar    Boilers    Chem Treatment: Yes No    Direct Boiler Make-Up From City Water: Yes No    ASSE 1013 Installed: Yes No

Boiler Make-Up at Chem Tank: Yes No    Air-Gap: Yes No    Cooling: None    Forced Air    Cooling Tower    Chiller    Chem Treatment: Yes No    Direct Chiller

Make-Up Line: Yes No    ASSE 1013 Installed: Yes No    Chiller Make-Up at Chem Tank: Yes No    Air-Gap: Yes No    Air-Gap at Tower Make-Up: Yes No

Dishwasher: Yes No    VB Installed: Yes No    Soap/Sanitizer/Rinse/Wax Educators/Aspirators: Yes No    (describe each in comments)    VB Installed: Yes No

Garbage Disposal with Direct Connection: Yes No    VB Installed: Yes No    Carbonated Beverage Machine: Yes No    ASSE 1032 Installed on Line: Yes No

Hose Faucet (s): Yes No    VB Installed: Yes No    Ice Machine: Yes No    Air-Gap at Ice Machine Drain Line: Yes No    Hydro-Aspirator (s): Yes No

Type: Lab    Dental    Medical    Irrigation    Hand-Held Sprayer    Process    (describe each in comments)    VB Installed: Yes No    Therapy/Str/Sonic Baths: Yes No

Submerged Inlet: Yes No    VB Installed: Yes No    Lab Faucets: Yes No    VB Installed: Yes No    Tanks/Vats: None    Wash    Dip    Rinse    Dye

Cooling    Plating    Air-Gap at Make-Up Line: Yes No    Swimming Pool/Fountain: Yes No    Air-Gap: Yes No    Jacuzzi: Yes No    Air-Gap: Yes No

Commercial Laundry Equipmt: Yes No    VB Installed: Yes No    Hot Water Heater (s): Yes No    How Many: \_\_\_\_\_    Thermal Expansion Tank: Yes No

Air-Gap at Water Heater Drain: Yes No    Shampoo Hose: Yes No    VB Installed: Yes No    Domestic Water Pump Installed: Yes No    Capacity: \_\_\_\_\_ GPM

Low-Suction Pressure Cut-Off Controller Installed on Pump: Yes No    Mant: \_\_\_\_\_    Model: \_\_\_\_\_    Serial No: \_\_\_\_\_

Other Domestic Water Source (s) at Premises: Yes No    Type: Well    Cistern    Storage Tower    Reservoir    City Service    City Service No: \_\_\_\_\_

Interconnected: Yes No    If Yes, Where is Interconnection: \_\_\_\_\_  
 ----- enter descriptions/comments concerning the domestic system on the back of this form -----



6. Does the system periodically resurvey all customers to ensure that cross-connections have been identified?

- Service connections must be re-surveyed with an on-site investigation or other approved documented methodology to determine current water use practices and changes which may warrant additional protection.



**CHAPTER 11 – CROSS-CONNECTION CONTROL SURVEYS  
SAMPLE SURVEY FORMS**

This form is intended for use as a generic survey form:

Company Name: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 Type of Business: \_\_\_\_\_  
 Contact Person: \_\_\_\_\_  
 Contact Person's Phone Number: \_\_\_\_\_  
 Meter Number: \_\_\_\_\_  
 Meter Size: \_\_\_\_\_  
 Existing Backflow Preventer Installed: \_\_\_\_\_

Yes	No	Size	Manufacturer	Model	Serial Number	Date Last Tested

HEATING		KITCHEN		MISC EQUIPMENT	
<input type="checkbox"/> Forced Air	<input type="checkbox"/> Electric	<input type="checkbox"/> Dishwasher	<input type="checkbox"/> Soap Eductor	<input type="checkbox"/> Hose Bibs	<input type="checkbox"/> Educator
<input type="checkbox"/> Solar	<input type="checkbox"/> Boiler	<input type="checkbox"/> Garbage Disposal	<input type="checkbox"/> CO2 Dispenser	<input type="checkbox"/> Aspirator	<input type="checkbox"/> Lab Faucet
<input type="checkbox"/> Chemically Treated From City Water	<input type="checkbox"/> Make-up Water From City Water	<input type="checkbox"/> Ice Machine	<input type="checkbox"/> Hose Bibs	<input type="checkbox"/> Shampoo Hose	<input type="checkbox"/> Wax Educator
<input type="checkbox"/> Feed from Chemical Feed Tank	<input type="checkbox"/> Feed from Chemical Feed Tank	<input type="checkbox"/> Other	<input type="checkbox"/> Other	<input type="checkbox"/> Thermal Expansion Tank	<input type="checkbox"/> Other
<input type="checkbox"/> ASSE 1013 Installed at Make-up	<input type="checkbox"/> ASSE 1013 Installed at Make-up	<input type="checkbox"/> ASSE 1001 Installed	<input type="checkbox"/> ASSE 1001 Installed	<input type="checkbox"/> ASSE 1011	<input type="checkbox"/> ASSE 1001
		<input type="checkbox"/> ASSE 1001 Installed	<input type="checkbox"/> ASSE 1001 Installed	<input type="checkbox"/> ASSE 1001	<input type="checkbox"/> ASSE 1001
		<input type="checkbox"/> ASSE 1032 Installed	<input type="checkbox"/> Air-Gap at Drain Line	<input type="checkbox"/> ASSE 1001	<input type="checkbox"/> ASSE 1001
		<input type="checkbox"/> ASSE 1011 Installed	<input type="checkbox"/> ASSE 1011 Installed	<input type="checkbox"/> ASSE 1001	<input type="checkbox"/> ASSE 1001
				<input type="checkbox"/> Yes	<input type="checkbox"/> No
				<input type="checkbox"/> Other	
				<input type="checkbox"/> Other	

COOLING		THERAPY/POOL/TANKS/RESERVOIRS		AUXILIARY WATER	
<input type="checkbox"/> None	<input type="checkbox"/> Forced Air	<input type="checkbox"/> Sizz/Sonic Bath	<input type="checkbox"/> Jacuzzi	<input type="checkbox"/> Well/Cistern	<input type="checkbox"/> Tower
<input type="checkbox"/> Chiller	<input type="checkbox"/> Cooling Tower	<input type="checkbox"/> Whirlpool	<input type="checkbox"/> Fountain	<input type="checkbox"/> Reservoir	<input type="checkbox"/> Interconnected
<input type="checkbox"/> Chemically Treated	<input type="checkbox"/> Make-up Water From City Water	<input type="checkbox"/> Irrigation	<input type="checkbox"/> Conant Laundry	<input type="checkbox"/> 4-Way/Swing	<input type="checkbox"/> Yes
<input type="checkbox"/> Feed from Chemical Feed Tank	<input type="checkbox"/> ASSE 1013 Installed at Make-up	<input type="checkbox"/> Swimming Pool	<input type="checkbox"/> Wash, Dip, or Rinse Tanks	<input type="checkbox"/> Domestic Pump LPS Serial Num.	<input type="checkbox"/> Fire Pump LPS Serial Num.
<input type="checkbox"/> Air-Gap at Make-up	<input type="checkbox"/> Air-Gap at Make-up	<input type="checkbox"/> ASSE 1001 Installed	<input type="checkbox"/> ASSE 1013 Installed	<input type="checkbox"/> With LPS	<input type="checkbox"/> With LPS
		<input type="checkbox"/> ASSE 1001 Installed	<input type="checkbox"/> ASSE 1013 Installed	<input type="checkbox"/> Backflow Preventer on Fire Model #/of Device	<input type="checkbox"/> ASSE
		<input type="checkbox"/> ASSE 1013 Installed	<input type="checkbox"/> ASSE 1013 Installed	<input type="checkbox"/> Serial Number	<input type="checkbox"/> Serial Number

Comments: \_\_\_\_\_

Survey by: \_\_\_\_\_ Date: \_\_\_\_\_  
 Company: \_\_\_\_\_ Company Phone Number: \_\_\_\_\_



7. Are backflow preventers at treatment plants and other facilities owned by the water system/ municipality tested every 12 months?

• The installed assemblies/air gaps have to be inspected and tested at least once every 12 months. The most recent inspection/test report must be made available.



## INTERCHANGEABLE CONNECTION INSPECTION REPORT

Premises Address: \_\_\_\_\_ Company Name: \_\_\_\_\_

Contact Name: \_\_\_\_\_ Contact Phone No: \_\_\_\_\_

Location of Interchangeable Connection: \_\_\_\_\_

Type of Connection: 4-Way \_\_\_\_\_ Swing \_\_\_\_\_ Meter Number: \_\_\_\_\_

Type of Inspection: Initial \_\_\_\_\_ Annual \_\_\_\_\_ Date of Inspection: \_\_\_\_\_

YES      NO

\_\_\_\_\_ The interchangeable connection was found to be properly installed in accordance with the requirements of the Ohio Environmental Protection Agency and the plans as approved

\_\_\_\_\_ The interchangeable connection has not been bypassed, removed or relocated

\_\_\_\_\_ The reduced pressure principle backflow preventer installed as part of the interchangeable connection has been tested for tightness and proper operation (test report attached).

I certify that the interchangeable connection as described above was inspected by me on the date indicated and the following findings were made.

COMMENTS: \_\_\_\_\_

INSPECTOR: \_\_\_\_\_ Printed Name: \_\_\_\_\_  
Signature: \_\_\_\_\_

Cert. Tester No: \_\_\_\_\_ Date: \_\_\_\_\_

\*\*\*\*\*

I certify that the foregoing inspection was performed on the date indicated and that the following statement is true. The interchangeable connection as described above has been in uninterrupted use during the entire prescribed interval between inspections and that during that period has not been bypassed or otherwise made ineffective.

Company Representative:

Name (Please Print) \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_ Title: \_\_\_\_\_



8. air gaps provided on all bulk water sale stations?
- All bulk water stations have to be equipped with air gaps which cannot be compromised.
9. Who in the organization is trained in cross-connection control?
- The whole public water system staff needs to be trained in cross-connection control in order to be able to run a good program. It takes more than just the chief operator to get the work done.





**Gary A. Espenschied**  
**Backflow Coordinator for**

**The Operator Training Committee of Ohio Inc.**

**Email address: [gary@otco.org](mailto:gary@otco.org)**

